

WELL RECORD

Compiled from historic source records and property-owner field measurements

Property Address:	1140 Plett Rd., Haring Twp., MI	Permit No.:	5879
County:	Wexford	Tax ID:	2209-34-2208
Total Depth:	70 ft BTOC / 68.5 ft BGS	Completion:	Unknown
Source:	Historic permit packet + owner field meas.	Date Measured:	UPDATED: 05/06/2026

WELL CONSTRUCTION

Casing Material: Steel (owner reported)
Top of Casing: 15 in above grade
Well Diameter: 4 in (per 1975 plot)
Total Depth: 70 ft BTOC / 68.5 ft BGS
Measuring Point: Top of steel casing (TOC)

DRILLING

Drilling Method: Not listed in source packet
Drilling Contractor: Not listed
Driller: Not listed
License No.: Not listed

STATIC WATER LEVEL

10.0 ft below top of casing
(= 8.75 ft below ground surface; 60 ft water column)

LITHOLOGY / SOIL LOG

From	To	Description
0	0.5	Topsoil
0.5	4	Loamy fine sand, gravel
4	—	Rock at 48 in.
6	—	Seasonal water table
—	—	Septic soil-boring data

NOTES

Compiled from available historic health-department sheets and owner field measurements. The 1975 permit plot shows a 4-inch well; the 2005 septic permit/inspection packet shows the water-well location and a 75-ft minimum well isolation. Construction fields not present in source records are intentionally marked as Not listed.

SOURCE NOTE & DISCLAIMER

This sheet is a non-certified summary compiled by the property owner from the attached source packet (historic permit and septic-inspection records) and from owner field measurements. It is not a driller-certified well-completion log and was not prepared by a licensed professional. Construction fields not present in the source records are marked as Not listed or Not provided. For informational reference only.

Compiled by:
Property Owner Elevation Distribution Ilc

Date:
05/06/2026

WELL CONSTRUCTION DIAGRAM

