

EQP 2017 (12/96)

~~2200 24 2201~~

1. LOCATION OF WELL

County
Wexford

Township Name
Haring

Fraction	NW _{1/4}	NW	NW
----------	-------------------	----	----

Section No.
34


Town No.
22

Range No.
9

Distance and Direction from Road Intersection
9408 East 13th Street

Street Address & City of Well Location

Locate with 'x' in Section Below



Sketch Map

2. FORMATION DESCRIPTION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUM

RECEIVED
NATIONAL BUREAU OF
SURVEYING
FEB 14 1968

FIG. 14 93

UNPUBLISHED
GROUND WATER SUPPLY SEC.

USE A 2ND SHEET IF NEEDED

USE A 2ND SHEET IF NEEDED

15. ABANDONED WELL PLUGGED?

☒ Yes ☐ No

Casing Diameter 2 in.

Depth 41 ft.

PLUGGING MATERIAL:

 Neat Cement

☐ Bentonite Slurry☐ Cement/Bentonite Slurry

☐ Concrete Grout

 Bentonite Chips

No. of Bags

Casing Removed?

☐ Yes ☒ No

16. REMARKS: (Elevation, Source of Data, etc.)

17. DRILLING MACHINE OPERATOR:

☐ Employee

☐ Subcontractor

Name _____

18. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

THOS FLINT & SON
REGISTERED BUSINESS NAME

2057
REGISTRATION NO.

Address 10243 35th Rd CADILLAC

Signed

Full Name _____
AUTHORIZED REPRESENTATIVE


Date 6-7-8

RECEIVED AUG 12 1998 GEOLOGICAL SURVEY COPY

EQP 2017 (12/96)

WATER WELL AND PUMP RECORD

Completion is required under authority of Part 127 Act 368 PA 1978
 Failure to comply is a misdemeanor

TAX NO: 2209-34-1102		PERMIT NO: 28338	
1. LOCATION OF WELL County Wexford		Township Name Haring	
Distance and Direction from Road Intersection 5240 South Crosby Road		Fraction 1/4 1/4 1/4	Section No. 34
Street Address & City of Well Location		Town No. 22	Range No. 9
Locate with 'x' in Section Below 		3. OWNER OF WELL Address Phyllis Lamphere 5240 S. Crosby Road Cadillac, MI 49601 Address Same as Well Location ☒ Yes ☐ No	
2. FORMATION DESCRIPTION SAND SAND + STONES BROWN CLAY WATER SAND		4. WELL DEPTH: 134 ft. Date Completed 8-3-98 ☐ New Well ☒ Replacement Well	
		5. ☐ Cable Tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow Rod ☐ Auger/Bored ☐ Jetted ☐	
		6. USE: ☒ Household ☐ Type I Public ☐ Type III Public ☐ Irrigation ☐ Type IIa Public ☐ Heat Pump ☐ Test Well ☐ Type IIb Public ☐	
		7. CASING: ☐ Steel ☐ Threaded ☒ Plastic ☐ Welded ☒ Other concrete Diameter: 3 in. to 129 ft. depth BORE HOLE: 2 1/4 in. to 135 ft. depth Diameter: 2 1/4 in. to 135 ft. depth	
THICKNESS OF STRATUM 65 30 7 33		Height: Above/Below Surface: 1 ft. Weight: 129 lbs./ft.	
		8. SCREEN: ☐ Not Installed ☐ Gravel-Packed ☒ Steel Type 5 Steel Diameter 3" Slot/Gauge 12 Length: 134 5' Set Between 129 ft. and 134 5' FITTINGS: ☒ Pack-Checker ☐ Bremer Check ☐ Blank Above Screen 1 1/2 ft. Other	
		9. STATIC WATER LEVEL: 102 ft. Below Land Surface ☐ Flowing	
		10. PUMPING LEVEL: Below Land Surface 102 ft. After 10 hrs. Pumping at 10 G.P.M. ☐ Plunger ☐ Bailor ☒ Air ☐ Test Pump	
15. ABANDONED WELL PLUGGED? ☒ Yes ☐ No Casing Diameter 2 in. Depth 6 ft. PLUGGING MATERIAL: ☐ Neat Cement ☐ Bentonite Slurry ☐ Cement/Bentonite Slurry ☐ Concrete Grout ☒ Bentonite Chips No. of Bags 38 Casing Removed? ☐ Yes ☒ No		11. WELL HEAD COMPLETION: ☒ Pitless Adapter ☒ 12" Above Grade ☐ Basement Offset ☐ Well House	
		12. WELL GROUTED? ☐ No ☒ Yes From 5 to 120 ☐ Neat Cement ☒ Bentonite ☒ Other Grout well No. of Bags 7 1/2 Additives	
		13. NEAREST SOURCE OF POSSIBLE CONTAMINATION: Type septic Distance 50 ft. Direction West Type septic Distance 50 ft. Direction West	
		14. PUMP: ☐ Not Installed ☒ Pump Installation Only Manufacturer's Name Could Model Number DL507 HP 3/4 Volts 230 Length of Drop Pipe 125 ft. Capacity 10 G.P.M. TYPE: ☒ Submersible ☐ Jet ☐ Other PRESSURE TANK: Manufacturer's Name X-trail Model Number 250 Capacity 136 Gallons 44	
16. REMARKS: (Elevation, Source of Data, etc.)		17. DRILLING MACHINE OPERATOR: ☐ Employee ☐ Subcontractor Name _____	

18. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Atkins Well Dats. **57-2211**
 REGISTERED BUSINESS NAME **7640 W. Walker Martin Mich 4966**
 Address **Shelby** Date **8-3-98**
 Signed **[Signature]** AUTHORIZED REPRESENTATIVE

WATER WELL AND PUMP RECORD

Completion is required under authority of Part 127 Act 368 PA 1978
Failure to comply is a misdemeanor

TAX NO: 2209-BA-011				PERMIT NO: 27414	
1. LOCATION OF WELL		Township Name Haring		Section No. 34	
County Wexford		Fraction 1/4 1/4 1/4		Town No. 22	
				Range No. 9	
Distance and Direction from Road Intersection 9886 East 13th Street Baker's Acres II		3. OWNER OF WELL Bruce & Maureen Loper Address 1012 Warbler Lane Cadillac, MI 49601 Address Same as Well Location ☐ Yes ☒ No			
Street Address & City of Well Location		4. WELL DEPTH: 91' Date Completed 8/3/98 ☒ New Well ☐ Replacement Well			
Locate with 'x' in Section Below		5. ☐ Cable Tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow Rod ☐ Auger/Bored ☐ Jetted ☐			
		6. USE: ☒ Household ☐ Type I Public ☐ Type III Public ☐ Irrigation ☐ Type IIa Public ☐ Heat Pump ☐ Test Well ☐ Type IIb Public ☐			
		7. CASING: ☐ Steel ☐ Threaded ☒ Plastic ☐ Welded ☐ Other Diameter: 5 in. to 8 1/2 ft. depth Weight: _____ lbs./ft. BORE HOLE: Diameter: 9 1/2 in. to 7 7/8 ft. depth _____ in. to _____ ft. depth			
2. FORMATION DESCRIPTION		8. SCREEN: ☐ Not Installed ☒ Gravel-Packed Type PVC W.O.P. Diameter 4" Slot/Gauze 20 Length: 5' Set Between 8 1/2 ft. and 9 1/2 ft. FITTINGS: ☒ K-Packer ☐ Bremer Check ☒ Blank Above Screen 2' ft. Other _____			
CLAY		9. STATIC WATER LEVEL: 55 ft. Below Land Surface ☐ Flowing			
Sand + Gravel		10. PUMPING LEVEL: Below Land Surface _____ ft. After 3/4 hrs. Pumping at 50 G.P.M. ☐ Plunger ☐ Bailor ☐ Air ☐ Test Pump			
CLAY + SAND		11. WELL HEAD COMPLETION: ☒ Pitless Adapter ☒ 12" Above Grade ☐ Basement Offset ☐ Well House			
SAND		12. WELL GROUTED? ☐ No ☒ Yes From 0 to _____ ft. ☐ Neat Cement ☐ Bentonite ☐ Other _____ No. of Bags 6 Additives _____			
COUNTY OF WEXFORD RECEIVED SEP 2 - 1998 DEED #10		13. NEAREST SOURCE OF POSSIBLE CONTAMINATION: Type Septic Distance 85 ft. Direction SW Type _____ Distance _____ ft. Direction _____			
		14. PUMP: ☐ Not Installed ☐ Pump Installation Only Manufacturer's Name Red Jacket Model Number _____ HP 1/2 Volts 230 Length of Drop Pipe 80 ft. Capacity 10 G.P.M. TYPE: ☒ Submersible ☐ Jet ☐ Other _____ PRESSURE TANK: Manufacturer's Name Well X Trol Model Number WX20S Capacity 40 Gallons 10			
USE A 2ND SHEET IF NEEDED		15. ABANDONED WELL PLUGGED? ☐ Yes ☐ No Casing Diameter _____ in. Depth _____ ft. PLUGGING MATERIAL: ☐ Neat Cement ☐ Bentonite Slurry ☐ Cement/Bentonite Slurry ☐ Concrete Grout ☐ Bentonite Chps No. of Bags _____ Casing Removed? ☐ Yes ☐ No			
16. REMARKS: (Elevation, Source of Data, etc.)		18. WATER WELL CONTRACTOR'S CERTIFICATION: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kastl Well Drilling 832175 REGISTERED BUSINESS NAME Address 9287 W. 30th Ave Hargittia MI 49658 Signed Michael MacEachern Date 8-3-98 AUTHORIZED REPRESENTATIVE			
17. DRILLING MACHINE OPERATOR: ☒ Employee ☐ Subcontractor Name Michael MacEachern					

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER & RADIOLOGICAL PROTECTION DIVISION
WATER WELL AND PUMP RECORD**

Completion is required under authority of Part 127 Act 368 PA 1978
Failure to comply is a misdemeanor

TAX NO:

PERMIT NO:

27816

2209 34 3201
1. LOCATION OF WELL

County
Wexford

Township Name
Haring

Fraction
NW₄ NW NW

Section No.
34

Town No.
22


Range No.
9

Distance and Direction from Road Intersection
9408 East 13th Street

Street Address & City of Well Location

Locate with 'x' in Section Below

Sketch Map



2. FORMATION DESCRIPTION

THICKNESS
OF
STRATUM

DEPTH TO
BOTTOM OF
STRATUM

CLAY
COARSE SAND

9 **9**
132 **141**

3. OWNER OF WELL

Address **John Putvin**
4578 Timber Ridge
Cadillac, MI 49601

Address Same as Well Location ☐ Yes ☒ No

4. WELL DEPTH:

Date Completed

☐ New Well

☒ Replacement Well

5. ☐ Cable Tool

☒ Rotary

☐ Driven

☐ Dug

☐ Hollow Rod

☐ Auger/Bored

☐ Jetted

☐

6. USE:

☒ Household

☐ Type I Public

☐ Type III Public

☐ Irrigation

☐ Type IIa Public

☐ Heat Pump

☐ Test Well

☐ Type IIb Public

☐

7. CASING:

☐ Steel

☐ Threaded

☒ Plastic

☐ Welded

☐ Other

Height: Above/Below

Surface: _____ ft

Diameter: **5** in. to **132** ft. depth

Weight: _____ lbs./ft.

_____ in. to _____ ft. depth

BORE HOLE:

Diameter: **2 1/8** in. to **141** ft. depth

☐ Drive Shoe

☐ Shale Packer

_____ in. to _____ ft. depth

8. SCREEN: ☐ Not Installed

☒ Gravel-Packed

Type

SK

Diameter **3 3/4**

Slot/Gauge **20**

Length: **44**

Set Between **151** ft. and **141** ft.

FITTINGS: ☒ K-Packer

☐ Bremor Check

☐ Blank Above Screen **3** ft. Other _____

9. STATIC WATER LEVEL:

20 ft. Below Land Surface

☐ Flowing

10. PUMPING LEVEL: Below Land Surface

25 ft. After **2** hrs. Pumping at **15** G.P.M.

☐ Plunger

☐ Bailor

☐ Air

☒ Test Pump

11. WELL HEAD COMPLETION:

☒ Pitless Adapter

☐ 12" Above Grade

☐ Basement Offset

☐ Well House

12. WELL GROUTED? ☐ No ☒ Yes

From **151** to **4** ft.

☐ Neat Cement

☐ Bentonite

☐ Other

No. of Bags **9**

Additives **AQUA GROUT**

13. NEAREST SOURCE OF POSSIBLE CONTAMINATION:

Type **SEPTIC**

Distance **50** ft.

Direction **S**

Type _____

Distance _____ ft.

Direction _____

USE A 2ND SHEET IF NEEDED

15. ABANDONED WELL PLUGGED? ☒ Yes ☐ No

Casing Diameter **2** in.

Depth **141** ft.

PLUGGING MATERIAL:

☐ Neat Cement

☐ Bentonite Slurry

☐ Cement/Bentonite Slurry

☐ Concrete Grout

☒ Bentonite Chips

No. of Bags **2**

Casing Removed? ☐ Yes ☒ No

16. REMARKS: (Elevation, Source of Data, etc.)

17. DRILLING MACHINE OPERATOR:

☐ Employee ☐ Subcontractor

Name **John Flint**

18. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

John Flint & Son

2057

REGISTERED BUSINESS NAME

REGISTRATION NO.

Address **10312 29th CADILLAC**

Signed **John Flint**

Date **6-98**

AUTHORIZED REPRESENTATIVE

RECEIVED AUG 12 1998

LOCAL HEALTH DEPT. COPY

EQP 2017..(12/96)

TAX NO:
2209 BA-002

MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER WELL AND PUMP RECORD

PERMIT NO:
25930

1. LOCATION OF WELL

County
Wexford

Township Name
Leaning

Fraction
1/4 1/4 1/4

Section No.
34

Town No.
22

Range No.
9


Distance and Direction from Road Intersection

Crosby Road
Baker's Acres 02

Street Address & City of Well Location

Locate with 'x' in Section Below

Sketch Map



2. FORMATION DESCRIPTION

THICKNESS
OF STRATUM

DEPTH TO
BOTTOM OF
STRATUM

Sand
Sandy + Stone
Sand
Water Sand.

42 42
12 54
15 69
25 94

3. OWNER OF WELL

Carl Hutchinson
Address
1489 East Simpson Road
Lake City, MI 49651

Address Same as Well Location ☐ Yes ☒ No

4. WELL DEPTH:

Date Completed

94 ft. 6/25/97

☒ New Well
☐ Replacement Well

5. ☒ Cable Tool

☐ Rotary

☒ Driven ☐ Dug

☐ Hollow Rod

☐ Auger/Bored

☐ Jetted ☐

6. USE: ☒ Household

☐ Type I Public

☐ Type III Public

☐ Irrigation

☐ Type IIa Public

☐ Heat Pump

☐ Test Well

☐ Type IIb Public

☐

7. CASING:

☒ Steel

☒ Threaded

☐ Plastic

☐ Welded

☐ Other

Height: Above/Below
Surface: 1 ft

Diameter: 4 in. to 90 ft. depth

Weight: 11 lbs./ft.

BORE HOLE:

Diameter: in. to ft. depth

in. to ft. depth

☒ Drive Shoe

☐ Shale Packer

8. SCREEN:

☐ Not Installed

☐ Gravel-Packed

Type

3.5 ft. 10

Diameter

10

Length

Set Between

90

ft. and

94

ft.

FITTINGS:

☒ K-Packer

☐ Bremer Check

☐ Blank Above Screen

1 1/2

ft. Other

9. STATIC WATER LEVEL:

68 ft. Below Land Surface

☐ Flowing

10. PUMPING LEVEL: Below Land Surface

72 ft. After

12 hrs. Pumping at

15 G.P.M.

☐ Plunger

☐ Bailer

☐ Air

☒ Test Pump

11. WELL HEAD COMPLETION:

☐ Pitless Adapter

☒ 12" Above Grade

☐ Basement Offset

☐ Well House

12. WELL GROUTED?

☐ No ☒ Yes

From 6 to 80 ft.

☐ Neat Cement

☒ Bentonite

☐ Other

No. of Bags

4 1/2

Additives

Enamptis 88

13. NEAREST SOURCE OF POSSIBLE CONTAMINATION:

Type

Distance

ft. Direction

Type

Distance

ft. Direction

15. ABANDONED WELL PLUGGED?

☐ Yes ☐ No

Casing Diameter in.

Depth ft.

PLUGGING MATERIAL:

☐ Neat Cement

☐ Bentonite Slurry

☐ Cement/Bentonite Slurry

☐ Concrete Grout

☐ Bentonite Chips

No. of Bags

Casing Removed?

☐ Yes ☐ No

16. REMARKS: (Elevation, Source of Data, etc.)

17. DRILLING MACHINE OPERATOR:

☐ Employee ☐ Subcontractor

Name

18. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Atens well drs.

REGISTERED BUSINESS NAME

Address

Signed

AUTHORIZED REPRESENTATIVE

REGISTRATION NO.

Address

Date

Authority: Act 368 PA 1978

Completion: Required

Penalty: Conviction of a violation of any provision is a misdemeanor.

GEOLOGICAL SURVEY COPY

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER & RADIOLOGICAL PROTECTION DIVISION
WATER WELL AND PUMP RECORD**

Completion is required under authority of Part 127 Act 368 PA 1978
Failure to comply is a misdemeanor

TAX NO:

PERMIT NO:

26150

330917-111-11
1. LOCATION OF WELL

County

Wexford

Township Name

Haring

Fraction

1/4

1/4

1/4

Section No.

34

Town No.

22

Range No.

9


Distance and Direction from Road Intersection

Plett Road

Street Address & City of Well Location

Locate with 'x' in Section Below

Sketch Map



2. FORMATION DESCRIPTION

THICKNESS
OF
STRATUM

DEPTH TO
BOTTOM OF
STRATUM

SAND
clay
SAND

50

50

4

54

56

110

USE 2ND SHEET IF NEEDED
GROUND WATER SUPPLY SEC.

15. ABANDONED WELL PLUGGED?

☐ Yes ☐ No

Casing Diameter _____ in.

Depth _____ ft.

PLUGGING MATERIAL:

☐ Cement/Bentonite Slurry

☐ Neat Cement

☐ Bentonite Slurry

☐ Concrete Grout

☐ Bentonite Chips

No. of Bags _____

Casing Removed?

☐ Yes ☐ No

16. REMARKS: (Elevation, Source of Data, etc.)

17. DRILLING MACHINE OPERATOR:

☐ Employee ☐ Subcontractor

Name Mike 7/6/5

3. OWNER OF WELL

Address Charles H. Wiltzer

7862 West Meyering Road

McBain, MI 49657

Address Same as Well Location ☐ Yes ☒ No

4. WELL DEPTH:

Date Completed

☒ New Well

☐ Replacement Well

5. ☐ Cable Tool

☒ Rotary

☐ Driven

☐ Dug

☐ Hollow Rod

☐ Auger/Bored

☐ Jetted

☐

6. USE:

☐ Household

☐ Type I Public

☐ Type III Public

☐ Irrigation

☐ Type IIa Public

☐ Heat Pump

☐ Test Well

☒ Type IIb Public

☐

7. CASING:

☐ Steel

☐ Threaded

Height: Above/Below

☒ Plastic

☐ Welded

Surface: _____ ft

☐ Other

Diameter: 5 in. to 106 ft. depth

Weight: _____ lbs./ft.

_____ in. to _____ ft. depth

BORE HOLE:

Diameter: 2 1/8 in. to 110 ft. depth

☐ Drive Shoe

_____ in. to _____ ft. depth

☐ Shale Packer

8. SCREEN: ☐ Not Installed

☒ Gravel-Packed

Type 5/16

Diameter 3 3/4

Slot/Gauze 20

Length: 4 ft

Set Between 106 ft. and 110 ft.

FITTINGS: ☒ J-K-Packer

☐ Bremner Check

☐ Blank Above Screen 3 ft. Other _____

9. STATIC WATER LEVEL:

40 ft. Below Land Surface

☐ Flowing

10. PUMPING LEVEL: Below Land Surface

45 ft. After 2 hrs. Pumping at 15 G.P.M.

☐ Plunger

☐ Bailor

☐ Air

☒ Test Pump

11. WELL HEAD COMPLETION:

☒ Pitless Adapter

☐ 12" Above Grade

☐ Basement Offset

☐ Well House

12. WELL GROUTED?

☐ No ☒ Yes

From 100 to 6 ft.

☐ Neat Cement

☐ Bentonite

☐ Other

No. of Bags 8

Additives ARMA GROUT

13. NEAREST SOURCE OF POSSIBLE CONTAMINATION:

Type Septic

Distance _____ ft. Direction _____

Type Septic

Distance 75+ ft. Direction E

14. PUMP: ☐ Not Installed

☐ Pump Installation Only

Manufacturer's Name F.E.W.

Model Number 4F10A02

HP 3/4

Volts 220

Length of Drop Pipe 80 ft.

Capacity 10 G.P.M.

TYPE: ☒ Submersible

☐ Jet

☐ Other

PRESSURE TANK:

Manufacturer's Name WELL WHITE

Model Number 12 W.M.

Capacity 80 Gallons

12

18. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

REGISTERED BUSINESS NAME THOMAS HINTLSON

REGISTRATION NO. 2057

Address 10213 S. 39 RD

Signed Mike 7/6/5

Date 9-97

TAX NO:

2209-PA-003

MICHIGAN DEPARTMENT OF PUBLIC HEALTH
WATER WELL AND PUMP RECORD

PERMIT NO:

24720

1. LOCATION OF WELL

County
WexfordTownship Name
HaringFraction
1/4 1/4 1/4Section No.
34Town No.
22Range No.
9


Distance and Direction from Road Intersection

Crosby Road
Baker's Acres 03

Street Address & City of Well Location

Locate with 'x' in Section Below

Sketch Map



2. FORMATION DESCRIPTION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUM

SAND	40	40
SANDY + STONE	12	52
SAND	16	68
WATER BEARING SAND	27	95

RECEIVED
Mich. Dept. of Public Health

JAN 28 1997

BUREAU OF ENVIRONMENTAL AND
OCCUPATIONAL HEALTH-GWQS

USE A 2ND SHEET IF NEEDED

15. ABANDONED WELL PLUGGED?

☐ Yes ☐ No

Casing Diameter _____ in. Depth _____ ft.

PLUGGING MATERIAL:

☐ Neat Cement ☐ Bentonite Slurry
☐ Cement/Bentonite Slurry ☐ Concrete Grout ☐ Bentonite Chips
No. of Bags _____ Casing Removed? ☐ Yes ☐ No

16. REMARKS: (Elevation, Source of Data, etc.)

17. DRILLING MACHINE OPERATOR:

☐ Employee ☐ Subcontractor

Name _____

3. OWNER OF WELL

Address
Carl Hutchinson
1489 East Simpson Road
Lake City, MI 49651Address Same as Well Location ☒ Yes ☐ No

4. WELL DEPTH:

Date Completed

☒ New Well
☐ Replacement Well5. ☒ Cable Tool☐ Rotary☒ Driven ☐ Dug
☐ Hollow Rod ☐ Auger/Bored ☐ Jetted ☐

6. USE:

☒ Household☐ Type I Public☐ Type IIa Public☐ Type IIb Public☐ Type III Public☐ Heat Pump☐ Test Well

7. CASING:

☒ Steel☐ Plastic☐ Other☒ Threaded☐ WeldedHeight: Above/Below
Surface: _____ ft.

Diameter: _____ in. to _____ ft. depth

Weight: _____ lbs./ft.

_____ in. to _____ ft. depth

BORE HOLE:

Diameter: _____ in. to _____ ft. depth

_____ in. to _____ ft. depth

☒ Drive Shoe☐ Shale Packer

8. SCREEN:

☐ Not Installed☐ Gravel-Packed

Type _____

Diameter _____

Slot/Gauze _____

Length: _____

Set Between _____ ft. and _____ ft.

FITTINGS:

☒ K-Packer☐ Bremer Check☒ Blank Above Screen

_____ ft. Other _____

9. STATIC WATER LEVEL:

_____ ft. Below Land Surface

☐ Flowing

10. PUMPING LEVEL: Below Land Surface

_____ ft. After _____ hrs. Pumping at _____ G.P.M.

☐ Plunger ☐ Bailer ☐ Air☒ Test Pump

11. WELL HEAD COMPLETION:

☒ Casing Adapter☐ Basement Offset☒ 2" Above Grade☐ Well House

12. WELL GROUTED?

☐ No ☒ Yes☐ Neat Cement☐ Bentonite

No. of Bags _____

Additives _____

From _____ to _____ ft.

☒ Other Groutwell

13. NEAREST SOURCE OF POSSIBLE CONTAMINATION:

Type _____

Distance _____ ft.

Direction _____

Type _____

Distance _____ ft.

Direction _____

14. PUMP:

☐ Not Installed☐ Pump Installation Only

Manufacturer's Name _____

Model Number _____

Length of Drop Pipe _____ ft.

TYPE: ☒ Submersible ☐ Jet ☐ Other

PRESSURE TANK:

Manufacturer's Name _____

Model Number _____

Capacity _____ Gallons

15. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Atter's Well Dals
REGISTERED BUSINESS NAME

Address _____

Signed _____

AUTHORIZED REPRESENTATIVE

2211
REGISTRATION NO.

49663

Date 11-19-96

GEOLOGICAL SURVEY COPY

Authority: Act 368 PA 1976

Completion: Required

Penalty: Conviction of a violation of any provision is a misdemeanor.

TAX NO:
2208-TRA-08MICHIGAN DEPARTMENT OF PUBLIC HEALTH
WATER WELL AND PUMP RECORD

PERMIT NO:

24360

1. LOCATION OF WELL

County
WexfordTownship Name
HaringFraction
1/4

NE NE

Section No.:
34Town No.
22Range No.
9

Distance and Direction from Road Intersection


9960 East 13th Street

Bakers Acres 08

Street Address & City of Well Location

Locate with 'x' in Section Below

Sketch Map



2. FORMATION DESCRIPTION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUM

TOP

SAND

1

1

Brown clay + sand + gravel

3

4

SAND + GRAVEL

11

15

SAND + GRAVEL + clay stringer

61

76

SAND + gravel stringer

22

98

SAND + gravel

22

120

SAND + gravel

43

163

15. ABANDONED WELL PLUGGED?

☐ Yes ☐ No

Casing Diameter _____ in.

Depth _____ ft.

PLUGGING MATERIAL:

☐ Neat Cement ☐ Bentonite Slurry☐ Cement/Bentonite Slurry ☐ Concrete Grout ☐ Bentonite Chips

No. of Bags _____

Casing Removed? ☐ Yes ☐ No

18. REMARKS: (Elevation, Source of Data, etc.)

17. DRILLING MACHINE OPERATOR:

☒ Employee ☐ SubcontractorName Rivard

GW-2-228 9/93

3. OWNER OF WELL

Address Robert B. Howell207 North Crosby RoadCadillac, MI 49601Address Same as Well Location ☐ Yes ☒ No

4. WELL DEPTH:

Date Completed

163 ft.6-20-96☒ New Well☐ Replacement Well5. ☐ Cable Tool☒ Rotary☐ Driven☐ Dug☐ Hollow Rod☐ Auger/Bored☐ Jetted☐6. USE: ☒ Household☐ Type I Public☐ Type III Public☐ Irrigation☐ Type IIA Public☐ Heat Pump☐ Test Well☐ Type IIB Public☐7. CASING: ☐ Steel☐ Threaded☒ Plastic☐ Welded☐ Other _____

Height: Above/Below

Surface: 1 ft.Diameter: 5 in. to 156 depth

_____ in. to _____ ft. depth

BORE HOLE 8 1/2 163Diameter: 8 1/2 in. to _____ ft. depth

_____ in. to _____ ft. depth

☐ Drive Shoe☐ Shale Packer8. SCREEN: ☐ Not Installed☒ Gravel-PackedType Johnson WOPDiameter Full 4"Slot/Gauze 012Length: 5 FeetSet Between 158 ft. and 163 ft.FITTINGS: ☐ K-Packer☐ Bremer Check☒ Blank Above Screen 2 ft. Other _____

9. STATIC WATER LEVEL:

81 ft. Below Land Surface☐ Flowing

10. PUMPING LEVEL: Below Land Surface

_____ ft. After _____ hrs. Pumping at _____ G.P.M.

☐ Plunger☐ Bailor☒ Air☐ Test Pump

11. WELL HEAD COMPLETION:

☒ Pitless Adapter☒ 12" Above Grade☐ Basement Offset☐ Well House12. WELL GROUTED? ☐ No☒ YesFrom 0 to 148 ft.☐ Neat Cement☒ Bentonite☐ Other _____No. of Bags 8Additives AQUA-GROUT

13. NEAREST SOURCE OF POSSIBLE CONTAMINATION:

Type septic system Distance not installed yet ft. Direction not installed yet

Type _____ Distance _____ ft. Direction _____

14. PUMP: ☐ Not Installed☐ Pump Installation OnlyManufacturer's Name Flint & WallingModel Number 106pmHP 1Volts 230Length of Drop Pipe 140 ft.Capacity 10 G.P.M.TYPE: ☒ Submersible☐ Jet☐ Other _____

PRESSURE TANK:

Manufacturer's Name WellmateModel Number WR140Capacity 44 Gallons86

15. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Jim Jeffers Water Well Drilling, 83-1981

REGISTERED BUSINESS NAME

Address 4498 12 Road Mesick MI 49668Signed Jim JeffersDate 6-21-96

AUTHORIZED REPRESENTATIVE

GEOLOGICAL SURVEY COPY

Authority: Act 368 PA 1978
Completion: Required
Penalty: Conviction of a violation of any provision is a misdemeanor.

TAX NO:

MICHIGAN DEPARTMENT OF PUBLIC HEALTH WATER WELL AND PUMP RECORD

PERMIT NO:

2209341201

22457

1. LOCATION OF WELL

County
WexfordTownship Name
HARINGFraction
1/4 1/4 1/4Section No.
34Town No.
22Range No.
09


Distance and Direction from Road Intersection

9600 E. 36 MILE ROAD

Street Address & City of Well Location

Locate with 'x' in Section Below

Sketch Map



2. FORMATION DESCRIPTION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUM

SAND	50	50
CLAY	2	52
SAND	60	112
COURSE SAND	38	150

RECEIVED
Mich. Dept. of Public Health

OCT 09 1995

BUREAU OF ENVIRONMENTAL AND
OCCUPATIONAL HEALTH-GWQS

USE A 2ND SHEET IF NEEDED

15. ABANDONED WELL PLUGGED?

☐ Yes ☐ No

Casing Diameter _____ In. Depth _____ ft.

PLUGGING MATERIAL:

☐ Cement/Bentonite Slurry☐ Neat Cement☐ Bentonite Slurry☐ Concrete Grout☐ Bentonite Chips

No. of Bags _____

Casing Removed?

☐ Yes ☐ No

16. REMARKS: (Elevation, Source of Data, etc.)

Pump will pump 856 GPM AT 60 PSI

17. DRILLING MACHINE OPERATOR:

☐ Employee ☐ Subcontractor

Name

7 Mile 4th

3. OWNER OF WELL

Address BAKER COLLEGE
%MORGAN CONSTRUCTION CO.
FLINT, MI 48507

Address Same as Well Location ☒ Yes ☐ No

4. WELL DEPTH:

Date Completed

☒ New Well☐ Replacement Well

150 ft.

9/19/95

☐ Cable Tool☒ Rotary☐ Driven☐ Dug☐ Hollow Rod☐ Auger/Bored☐ Jetted☐

6. USE:

☐ Household☐ Type I Public☐ Type IIa Public☐ Type IIb Public☐ Irrigation☐ Test Well☐ Type III Public☐ Heat Pump☒ FIRE PROT.

7. CASING:

☐ Steel☒ Plastic☐ Threaded☐ Welded☐ Other

Diameter: 5 in. to 135 ft. depth

in. to ft. depth

BORE HOLE:

Diameter: 7 7/8 in. to 150 ft. depth

in. to ft. depth

Height: Above/Below
Surface: _____ ft.

Weight: _____ lbs./ft.

☐ Drive Shoe☐ Shale Packer

8. SCREEN:

☐ Not Installed☒ Gravel-Packed

Type SKS

Slot/Gauze 20

Set Between 135 ft. and 150 ft.

FITTINGS: ☒ K-Packer☐ Blank Above Screen

3 ft. Other

9. STATIC WATER LEVEL:

45 ft. Below Land Surface

☐ Flowing

10. PUMPING LEVEL: Below Land Surface

65 ft. After 2 hrs. Pumping at 100 G.P.M.

☐ Plunger ☐ Bailor ☐ Air☒ Test Pump

11. WELL HEAD COMPLETION:

☒ Pitless Adapter☐ Basement Offset☐ 12" Above Grade☐ Well House

12. WELL GROUTED?

☐ No ☒ Yes

From 30 to 5 ft.

☐ Neat Cement☒ Bentonite☐ Other

No. of Bags 10

Additives AQUA GROUT

13. NEAREST SOURCE OF POSSIBLE CONTAMINATION:

Type SEWERLINE

Distance 80 ft. Direction W

Type _____ Distance _____ ft. Direction _____

14. PUMP:

☐ Not Installed☐ Pump Installation Only

Manufacturer's Name FEW

Model Number 4F85A25

HP 7 1/2

Volts 460

Length of Drop Pipe 110 ft.

Capacity 85 G.P.M.

TYPE: ☒ Submersible ☐ Jet ☐ Other

PRESSURE TANK:

Manufacturer's Name WELL MATE

Model Number 3-10M35

Capacity 145 Gallons

600

15. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

THOS FLINT LSON

REGISTERED BUSINESS NAME

Address 10213 S 37 RD

Signed 7 Mile 4th

AUTHORIZED REPRESENTATIVE

Date 9-25-95

REGISTRATION NO.

GEOLOGICAL SURVEY COPY

Authority: Act 358 PA 1978

Completion: Required

Penalty: Conviction of a violation of any provision is a misdemeanor.

TAX NO:

2209-34-2286

MICHIGAN DEPARTMENT OF PUBLIC HEALTH
WATER WELL AND PUMP RECORD

PERMIT NO:

24325

1. LOCATION OF WELL

County

Wexford

Township Name

Haring

Fraction

1/4 1/4 1/4

Section No.

34

Town No.

22

Range No.


9

Distance and Direction from Road Intersection

1118 Plett Road

Street Address & City of Well Location

Locate with 'x' in Section Below



2. FORMATION DESCRIPTION

THICKNESS
OF STRATUMDEPTH TO
BOTTOM OF
STRATUM

SAND
CLAY
SAND
LATERAL SAND

17

17

3

20

25

45

30

75

3. OWNER OF WELL

Address: **Clifford A. Pauley**
1118 Plett Road
Cadillac, MI 49601

Address Same as Well Location ☒ Yes ☐ No

4. WELL DEPTH:

Date Completed

75 ft.

4/20/96

☐ New Well☒ Replacement Well5. ☐ Cable Tool☐ Rotary☐ Driven☐ Dug☐ Hollow Rod☐ Auger/Bored☒ Jetted☐ Heat Pump

6. USE:

☒ Household☐ Type I Public☐ Type III Public☐ Irrigation☐ Type IIa Public☐ Heat Pump☐ Test Well☐ Type IIb Public☐ Heat Pump

7. CASING:

☒ Steel☒ Threaded☐ Plastic☐ Welded☐ Other

Height: Above/Below

Surface: 1 ft

Diameter: 2 in. to 71 ft. depth

Weight: lbs./ft.

in. to ft. depth

BORE HOLE:

Diameter: in. to ft. depth

in. to ft. depth

☒ Drive Shoe☐ Shale Packer

8. SCREEN:

☐ Not Installed☐ Gravel-Packed

Type

80 S.S. 80.

Diameter

1 1/4

Slot/Gauze

80

Length:

41

Set Between

71 ft. and

75 ft.

FITTINGS:

☒ K-Packer☒ Bremer Check☐ Blank Above Screen

ft. Other

9. STATIC WATER LEVEL:

64 ft. Below Land Surface

☐ Flowing

10. PUMPING LEVEL: Below Land Surface

44 ft. After

hrs. Pumping at

G.P.M.

☒ Plunger☐ Baller☐ Air☐ Test Pump

11. WELL HEAD COMPLETION:

☐ Pitless Adapter☒ 12" Above Grade☐ Basement Offset☒ Well House

12. WELL GROUTED?

☐ No☒ Yes

From

to

☐ Neat Cement☒ Bentonite☒ Other

96 ft. Well

No. of Bags

112

Additives

13. NEAREST SOURCE OF POSSIBLE CONTAMINATION:

Type

Septic

Distance

50 ft.

Type

50 ft.

Direction

SOUTH

14. PUMP:

☒ Not Installed☐ Pump Installation Only

Manufacturer's Name

Model Number

HP

Volts

Length of Drop Pipe

ft.

Capacity

G.P.M.

TYPE:

☐ Submersible☐ Jet☐ Other

PRESSURE TANK:

Manufacturer's Name

Model Number

Capacity

Gallons

15. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

ATEN Delg.
REGISTERED BUSINESS NAME

REGISTRATION NO.

Address

4273 W. Dickerson

Signed

AUTHORIZED REPRESENTATIVE

Date

4/20/96

Mantua Mich 49663

GEOLOGICAL SURVEY COPY

Penalty: Conviction of a violation of any provision is a misdemeanor.

ATEN Delg.
REGISTERED BUSINESS NAME

REGISTRATION NO.

Address

4273 W. Dickerson

Signed

AUTHORIZED REPRESENTATIVE

Date

4/20/96

Mantua Mich 49663

GEOLOGICAL SURVEY COPY

Penalty: Conviction of a violation of any provision is a misdemeanor.

ATEN Delg.
REGISTERED BUSINESS NAME

REGISTRATION NO.

Address

4273 W. Dickerson

Signed

AUTHORIZED REPRESENTATIVE

Date

4/20/96

Mantua Mich 49663

GEOLOGICAL SURVEY COPY

Penalty: Conviction of a violation of any provision is a misdemeanor.

MAR 07 1978

WATER WELL RECORD
ACT 294 PA 1966MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH

1 LOCATION OF WELL

County Wexford Township Name Haring Fraction NE 1/4 NE 1/4 SE 1/4 Section Number 34 Town Number 22 Range Number 9 E/W.


Distance And Direction from Road Intersections

5066 Crosby Rd.

Street address & City of Well Location

Locate with "X" in section below

Sketch Map:



2 FORMATION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUM

Sand Coarse 40 40
Fine Gravel 59 99

3 OWNER OF WELL:

Richard Clous
Address 5066 Crosby Rd.
Cadillac, Mich. 49601

4 WELL DEPTH: (completed) Date of Completion

99 ft. 7-27-77

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☒ Hollow rod ☐ Jotted ☐ Borad ☐

6 USE: ☒ Domestic ☐ Public Supply ☐ Industry
☐ Irrigation ☐ Air Conditioning ☐ Commercial
☐ Test Well ☐

7 CASING: Threaded ☐ Welded ☐ Height: Above/Below

Diam. _____ ft.

Surface _____ ft.

Weight 375 lbs./ft.Drive Shoe? Yes ☒ No ☐

8 SCREEN:

Type: SS Drop Dia.: 1 1/4Slot/Gauze 60 Length 4 ft.Set between 95 ft. and 99 ft.

Fittings:

9 STATIC WATER LEVEL

80 ft. below land surface

10 PUMPING LEVEL below land surface

83 ft. after 1/2 hrs. pumping _____ g.p.m.

_____ ft. after _____ hrs. pumping _____ g.p.m.

11 WATER QUALITY in Parts Per Million:

Iron (Fe) _____ Chlorides (Cl) _____

Hardness _____ Other _____

12 WELL HEAD COMPLETION: ☐ In Approved Pit☒ Pitless Adapter ☐ 12" Above Grade13 Well Grouted? ☐ Yes ☐ No☐ Neat Cement ☐ Bentonite ☐

Depth: From _____ ft. to _____ ft.

14 Nearest Source of possible contamination:

70 feet NE Direction Septic Tank Type _____Well disinfected upon completion ☒ Yes ☐ No

15 PUMP:

☐ Not installedManufacturer's Name Gould PumpModel Number _____ HP 1 Volts 220Length of Drop Pipe 90 ft. capacity _____ G.P.M.Type: ☐ Submersible☒ Jet ☐ Reciprocating

USE A 2ND SHEET IF NEEDED

16 Remarks, elevation, source of data, etc.

ADDED INFO BY DRILLER, ITEM NO. 163321973

*CORRECTED BY

**ADDITION BY 1325

ELEVATION

DEPTH TO ROCK

17 WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Muller Wells & Drills
REGISTERED BUSINESS NAME

REGISTRATION NO.

2610-S-41 RD Cap
Address

Signed Lloyd Miller
AUTHORIZED REPRESENTATIVE

Date _____

GEOLOGICAL SURVEY COPY

MAR 03 1971

WATER WELL RECORD

ACT 294 PA 1966


MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH

1 LOCATION OF WELL

County <u>Wayne</u>	Township Name <u>Haring</u>	Fraction <u>SW 1/4 SE 1/4</u>	Section Number <u>34</u>	Town Number <u>22 N.S.</u>	Range Number <u>9 E.W.</u>
------------------------	--------------------------------	----------------------------------	-----------------------------	-------------------------------	-------------------------------

Distance And Direction from Road Intersections
Well located 1/4 mile West of 45
mile Rd. on M 55 E.
100 ft north of M 55.

Street address & City of Well Location



2 FORMATION

FORMATION	THICKNESS OF STRATUM	DEPTH TO BOTTOM OF STRATUM
<u>Sand & Gravel</u>	<u>112 ft.</u>	<u>112 ft.</u>
<u>all the way</u>		

3 OWNER OF WELL:

Ralph. Douglas
 Address East 55
Cadillac, Mich.

4 WELL DEPTH: (completed) Date of Completion

112 ft. July 30, 1970

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☒ Hollow rod ☐ Jetted ☐ Bored

6 USE: ☒ Domestic ☐ Public Supply ☐ Industry
☐ Irrigation ☐ Air Conditioning ☐ Commercial
☐ Test Well

7 CASING: Threaded ☒ Welded ☐

Height: Above/Below Surface 5 Below
 Weight 375 lbs./ft.
 Drive Shoe? Yes ☐ No ☐

8 SCREEN:

Type: Drop pipe Dia.: 1 1/4
 Slot/Gauze 60 Length 4 ft.
 Set between 108 ft. and 112 ft.
 Fittings:

9 STATIC WATER LEVEL

90 ft. below land surface

10 PUMPING LEVEL below land surface

90 ft. after 1/2 hrs. pumping _____ g.p.m.
 _____ ft. after _____ hrs. pumping _____ g.p.m.

11 WATER QUALITY in Parts Per Million:

Iron (Fe) _____ Chlorides (Cl) _____
 Hardness _____ Other _____

12 WELL HEAD COMPLETION:

☐ In Approved Pit
☒ Pitless Adapter ☐ 12" Above Grade

13 Well Grouted? ☐ Yes ☐ No

☐ Neat Cement ☐ Bentonite ☐ _____

Depth: From _____ ft. to _____ ft.

14 Nearest Source of possible contamination

50 feet NE Direction Septic tank Type
 Well disinfected upon completion ☒ Yes ☐ No

15 PUMP:

☐ Not installed 7, M.

Manufacturer's Name _____ HP 1 1/2 Volts 220

Length of Drop Pipe 100 ft. capacity _____ G.P.M.

Type: ☐ Submersible
☒ Jet ☐ Reciprocating

16 Remarks, elevation, source of data, etc.

_____ CRITER, _____

LOCATED BY _____

WARRANTY BY _____

elev 21358'

17 WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Miller Well Drilling 1089

REGISTERED BUSINESS NAME _____ REGISTRATION NO. _____
 Address 2104-6th Ave, Cadillac, Mich.

Signed Lloyd Miller Date 2-24-71
 AUTHORIZED REPRESENTATIVE

WATER WELL RECORD

ACT 294 PA 1965

MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH

1 LOCATION OF WELL

County Wayne Township Name Haring Fraction SW 1/4 SW 1/4 SE 1/4 Section Number 34 Town Number 22 N. 8. Range Number 9 E. W.



Distance And Direction from Road Intersections

Well located 1/2 mile W of 45 mile
Rt. on M 55 Mi. Rd East,
150 ft. N of M. 55.

Street Address and City of Well Location

Locate with "X" in section below

Sketch Map:



2 FORMATION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUM

Sand & Gravel
All the Way

122 ft. 122 ft.

3 OWNER OF WELL:

Lewis Ward.
Address E. Division
Cadillac, Mich.

4 WELL DEPTH: (completed) Date of Completion

122 ft. June 1970

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☒ Hollow rod ☐ Jotted ☐ Borod ☐
6 USE: ☒ Domestic ☐ Public Supply ☐ Industry
☐ Irrigation ☐ Air Conditioning ☐ Commercial
☐ Test Well ☐

7 CASING: Threaded ☐ Welded ☐

Diam.

Height: Above/Below

Surf. 5 Below

2 in. to 122 ft. Depth

Weight 375 lbs./ft.

in. to ft. Depth

Drive Shoe? Yes ☒ No ☐

8 SCREEN:

Type Drop screen Dia.: 1 1/4Slot/Gauze 60 Length 4 ft.Set between 118 ft. and 122 ft.

Fittings:

9 STATIC WATER LEVEL

90 ft. below land surface

10 PUMPING LEVEL below land surface

90 ft. after 1/2 hrs. pumping g.p.m.

ft. after hrs. pumping g.p.m.

11 WATER QUALITY in Parts Per Million:

Iron (Fe) Chlorides (Cl)

Hardness Other

12 WELL HEAD COMPLETION: ☒ In Approved Pit

☐ Pitless Adapter ☐ 12" Above Grade

13 Well Grouted? ☐ Yes ☐ No

☐ Neat Cement ☐ Bentonite ☐

Depth: From ft. to ft.

14 Nearest Source of possible contamination

75 feet N.W. Direction Septic tank Type

Well disinfected upon completion ☒ Yes ☐ No

15 PUMP:

☐ Not installed

Manufacturer's Name F. M.

Model Number HP 1 1/2 Volts 220

Length of Drop Pipe 105 ft. capacity G.P.M.

Type: ☐ Submersible ☒ Jet ☐ Reciprocating

USE A 2ND SHEET IF NEEDED

16 Remarks, elevation, source of data, etc.

BY DRILLER, ITEM NO.

*CORRECTED BY:

**ADDITION BY:

elev 1380'

17 WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true

to the best of my knowledge and belief.

Mullers Well Drilling 1089

REGISTERED BUSINESS NAME

REGISTRATION NO.

Address

2104- 6th Ave, Cadillac, Mich.

Signed

Lloyd Miller

Date

2-24-71

AUTHORIZED REPRESENTATIVE

APR 11 1978

WATER WELL RECORD

ACT 294 PA 1965

MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH

1 LOCATION OF WELL

County **Wexford** Township Name **Harring** Fraction **SE 1/4 SE 1/4 SE 1/4** Section Number **311** Town Number **22 (N.S.)** Range Number **7 E.W.**


Distance And Direction from Road Intersections

m 55 x Crosby Rd
1 Block N. on Crosby

Street address & City of Well Location

Locate with "X" in section below

Sketch Map:



2 FORMATION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUM

0-5 sand

5-30 clay

30-90 sand and gravel

90-120 clay

120-130 waater and sand course

3 OWNER OF WELL:

Address **Royal Hamilton**
Crosby Rd

4 WELL DEPTH: (completed) Date of Completion

130 ft.

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jatted ☐ Bored ☐

6 USE: ☒ Domestic ☐ Public Supply ☐ Industry
☐ Irrigation ☐ Air Conditioning ☐ Commercial
☐ Test Well ☐

7 CASING: Threaded ☐ Welded ☒ Height: Above/Below
Diam. _____ ft.
Surface _____ ft.
Weight _____ lbs./ft.
Drive Shoe? Yes ☒ No ☐

8 SCREEN:

Type: **ss** Dia.: **3 3/4**Slot/Gauze **10 slot** Length **4**

Set between _____ ft. and _____ ft.

Fittings: **k packer**

9 STATIC WATER LEVEL

90 ft. below land surface

10 PUMPING LEVEL below land surface

_____ ft. after _____ hrs. pumping _____ G.P.M.

_____ ft. after _____ hrs. pumping _____ G.P.M.

11 WATER QUALITY in Parts Per Million:

Iron (Fe) _____ Chlorides (Cl) _____

Hardness _____ Other _____

12 WELL HEAD COMPLETION: ☐ In Approved Pit
☒ Pitless Adapter ☐ 12" Above Grade

13 Well Grouted? ☐ Yes ☐ No☒ Neat Cement ☐ Bentonite ☐

Depth: From _____ ft. to _____ ft.

14 Nearest Source of possible contamination

60 feet **S** Direction **SEPTIC** TypeWell disinfected upon completion ☒ Yes ☐ No15 PUMP: ☐ Not installedManufacturer's Name **FTW**Model Number _____ HP **34** Volts **240**Length of Drop Pipe **105** ft. capacity _____ G.P.M.Type: ☒ Submersible☐ Jet☐ Reciprocating

16 Remarks, elevation, source of data, etc.

ADDED INFO BY DRILLER, ITEM NO.

*COMPLETED BY

**ADDITION BY

ELEVATION **1340**

DEPTH TO ROCK

17 WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true
to the best of my knowledge and belief.

Thomas Flint & son, inc. 0519

REGISTERED BUSINESS NAME

REGISTRATION NO.

Cadillac Mi.**Oct 77**

Address

Signed **Mike Flint**

AUTHORIZED REPRESENTATIVE

Date **1977**

WATER WELL RECORD

ACT 294 PA 1965

MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH

1 LOCATION OF WELL

County Westland Township Name Harving Fraction SE 1/4 SE 1/4 SE 1/4 Section Number 34 Town Number 20 N/4 Range Number 9 N/4


Distance And Direction from Road Intersections

1 mile east of Academy Rd
NE 1/4
St. 55000

Street address & City of Well Location

Locate with "X" in section below

Sketch Map:



2 FORMATION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUM

sand	48	48
water sand to find	7	55
clay with muddel		
sand	30	85
clay	14	99
Hard Pan sand	10	109
Water sand & gravel	21	130

3 OWNER OF WELL:

THE CHURCH OF THE NAZARENE
 Address
Cadillac, Mich.

4 WELL DEPTH: (completed) Date of Completion

130 ft. MAY 28, 1970

5 ☒ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☐

6 USE: ☐ Domestic ☐ Public Supply ☐ Industry
☐ Irrigation ☐ Air Conditioning ☐ Commercial
☐ Test Well ☒ CHURCH

7 CASING: Threaded ☒ Welded ☐ Height: Above Below

Diam. 4 in. to 126 ft. Depth
4 in. to 126 ft. Depth
 Weight 11 lbs./ft.
 Drive Shoe? Yes ☒ No ☐

8 SCREEN:

Type: Johnson Dia.: 3
 Slot Gauge 7 Length 4
 Set between 126 ft. and 130 ft.
 Fittings: Head Parker

9 STATIC WATER LEVEL

100 ft. below land surface
 10 PUMPING LEVEL below land surface
100 ft. after 3000 g.p.m.
100 ft. after 3000 g.p.m.

11 WATER QUALITY in Parts Per Million:

Iron (Fe) _____ Chlorides (Cl) _____
 Hardness _____ Other _____

12 WELL HEAD COMPLETION: ☒ In Approved Pit
☒ Pitless Adapter ☐ 12" Above Grade

13 Well Grouted? ☐ Yes ☐ No
☐ Neat Cement ☐ Bentonite ☒ jet sand
 Depth: From _____ ft. to _____ ft.

14 Nearest Source of possible contamination:
super not in
 feet _____ Direction _____ Type _____
 Well disinfected upon completion ☒ Yes ☐ No

15 PUMP: ☐ Not installed

Manufacturer's Name Burke
 Model Number 15 HP 1 1/2 Volts 230
 Length of Drop Pipe 108 ft. capacity 1200 G.P.M.
 Type: ☒ Submersible ☐ Jet ☐ Reciprocating

16 Remarks, elevation, source of data, etc.

100 ft. below land surface

FOGEL, P. D. 1970

WATER WELL BY

17 WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my supervision and this report is true
 to the best of my knowledge and belief.
E. J. M. Mullen 0549
 REGISTERED BUSINESS NAME REGISTRATION NO.

Address Donald E. Ely
 Signed Donald E. Ely Date _____
 AUTHORIZED REPRESENTATIVE

MAR 07 1978

WATER WELL RECORD

ACT 294 PA 1965

MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH

1 LOCATION OF WELL

County Wexford Township Name HARING Fraction 1/4 1/4 1/4 Section Number 34 Town Number 22 N/S. Range Number 9 E/W.


Distance And Direction from Road Intersections

LOT 10 BAKERS ACRES
E-13TH ST. CADILLAC, Mich. 49601

Street address & City of Well Location

Locate with "X" in section below

Sketch Map:



3 OWNER OF WELL:

MATHIAS FORBES
Address LOT 10 E. 13TH ST.
CADILLAC, Mich. 49601

4 WELL DEPTH: (completed) Date of Completion

98 ft.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug

☒ Hollow rod ☐ Jotted ☐ Bored ☐

6 USE: ☒ Domestic ☐ Public Supply ☐ Industry

☐ Irrigation ☐ Air Conditioning ☐ Commercial

☐ Test Well ☐

7 CASING: Threaded ☐ Welded ☐ Height: Above/Below
Diam. _____ ft.

2 in. to 98 ft. Depth

_____ in. to _____ ft. Depth

Weight 375 lbs./ft.

Drive Shoe? Yes ☒ No ☐

8 SCREEN:

Type: SS DROP Dia.: 1 1/4

Slot/Gauze 60 Length 4 ft.

Set between 94 ft. and 98 ft.

Fittings: _____

9 STATIC WATER LEVEL

78 ft. below land surface

10 PUMPING LEVEL below land surface

78 ft. after 1/2 hrs. pumping _____ G.P.M.

_____ ft. after _____ hrs. pumping _____ G.P.M.

11 WATER QUALITY in Parts Per Million:

Iron (Fe) _____ Chlorides (Cl) _____

Hardness _____ Other _____

12 WELL HEAD COMPLETION:

☐ In Approved Pit

☒ Pitless Adapter ☐ 12" Above Grade

13 Well Grouted? ☐ Yes ☐ No

☐ Neat Cement ☐ Bentonite ☐

Depth: From _____ ft. to _____ ft.

14 Nearest Source of possible contamination

75 feet SW Direction Septic Type

Well disinfected upon completion ☒ Yes ☐ No

15 PUMP:

☐ Not installed

Manufacturer's Name Miller Pump

Model Number _____ H.P. 3/4 Volts

Length of Drop Pipe 84 ft. capacity _____ G.P.M.

Type: ☐ Submersible

☒ Jet ☐ Reciprocating

USE A 2ND SHEET IF NEEDED

16 Remarks, elevation, source of data, etc.

RECEIVED
MICHIGAN DEPARTMENT OF PUBLIC HEALTH
MAR 8 1978

ADDED INFO BY DRILLER, ITEM NO. _____

*CORRECTED BY _____

**ADDITION BY _____

ELEVATION _____

17 WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my supervision and this report is true to the best of my knowledge and belief.

Miller Well Drilling 1089

REGISTERED BUSINESS NAME

REGISTRATION NO.

Address 2610-S-4th Cadillac, Mich.

Signed Lloyd Miller Date 2-15-78

AUTHORIZED REPRESENTATIVE

JUN 19 1975

WATER WELL RECORD

ACT 294 PA 1965

MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH

1 LOCATION OF WELL

County Wexford Township Name HARING Fraction SE 1/4 SE 1/4 Section Number 34 Town Number 22 N.B. Range Number 9 A.W.


Distance And Direction from Road Intersections

211 Crosby St

Street address & City of Well Location

Locate with "X" in section below

Sketch Map:



2 FORMATION

THICKNESS
OF
STRATUMDEPTH TO
BOTTOM OF
STRATUMSAND7020CLAY & SAND6010130WATER SAND17130149

3 OWNER OF WELL:

DOUGLAS SHAW

Address

211 Crosby St CADILLAC

4 WELL DEPTH: (completed) Date of Completion

147

ft.

5 ☒ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jotted ☐ Bored ☐

6 USE: ☒ Domestic ☐ Public Supply ☐ Industry
☐ Irrigation ☐ Air Conditioning ☐ Commercial
☐ Test Well ☐

7 CASING: Threaded ☒ Welded ☐ Diam.4"

Height: Above/Below

Surface _____ ft.

Weight _____ lbs./ft.

Drive Shoe? Yes ☒ No ☐

8 SCREEN:

Type: Johnson Dia.: 3 3/4Slot/Gauze 10 Length _____

Set between _____ ft. and _____ ft.

Fittings:

N PACHER

9 STATIC WATER LEVEL

_____ ft. below land surface

10 PUMPING LEVEL below land surface

_____ ft. after _____ hrs. pumping _____ g.p.m.

_____ ft. after _____ hrs. pumping _____ g.p.m.

11 WATER QUALITY in Parts Per Million:

Iron (Fe) _____ Chlorides (Cl) _____

Hardness _____ Other _____

12 WELL HEAD COMPLETION:

☐ In Approved Pit
☐ Pitless Adapter ☐ 12" Above Grade

13 Well Grouted? ☐ Yes ☐ No☐ Neat Cement ☐ Bentonite ☐

Depth: From _____ ft. to _____ ft.

14 Nearest Source of possible contamination

_____ feet _____ Direction _____ Type

Well disinfected upon completion ☐ Yes ☐ No

15 PUMP:

☐ Not installedManufacturer's Name F&WModel Number _____ HP 1 Volts 220Length of Drop Pipe _____ ft. capacity 10 G.P.M.Type: ☒ Submersible☐ Jot☐ Reciprocating

USE A 2ND SHEET IF NEEDED

16 Remarks, elevation, source of data, etc.

STARTED INTO BY WELLER, ITEM NO.CONTROLLED BY CP

TESTED BY

ELEVATION

DEPTH TO ROCK

17 WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.



Thos Hunt & SonREGISTRATION NO. 0519Address 10013 S. 39 M. RdSigned Thos Hunt

Date _____

WATER WELL AND PUMP RECORD

PERMIT NUMBER

16762

1 LOCATION OF WELL			3 OWNER OF WELL:		
County <u>Wexford</u>	Township Name <u>Haring</u>	Fraction <u>1/4</u>	Section Number <u>34</u>	Town Number <u>2200</u>	Range Number <u>9</u>
Distance And Direction From Road Intersection <u>9600 E. 13th St.</u>			Address <u>Baker College</u> <u>13th St. N. 49601</u> <u>Cadillac, MI</u>		
Street Address & City of Well Location			Address Same As Well Location? ☒ Yes ☐ No		
Locate with "X" in Section Below			4 WELL DEPTH: <u>130</u> FT. Date Completed <u>7</u> / <u>91</u>		
Sketch Map: 			☒ New Well ☐ Replacement Well		
			5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Auger ☐ Jetted ☐		
			6 USE: ☐ Domestic ☐ Type I Public ☐ Type III Public ☐ Irrigation ☐ Type IIa Public ☐ Heat pump ☐ Test Well ☐ Type IIb Public ☐		
			7 CASING: ☐ Steel ☐ Threaded ☐ Welded ☒ Plastic ☐ Height: Above/Below _____ in. to _____ ft. depth _____ in. to _____ ft. depth Grouted Drill Hole Diameter <u>9</u> in. to _____ ft. depth _____ in. to _____ ft. depth		
2 FORMATION DESCRIPTION			8 SCREEN: ☐ Not installed		
			Type <u>S/S</u> Diameter <u>3 3/4</u>		
			Slot/Gauge <u>15</u> Length <u>12 ft</u>		
			Set between <u>118</u> ft. and <u>130</u> ft.		
			FITTINGS: ☒ K-Packer ☐ Lead Packer ☐ Bremer Check ☐ Blank above screen <u>3</u> ft. Other _____		
THICKNESS OF STRATUM			9 STATIC WATER LEVEL: <u>65</u> ft. below land surface ☐ Flow		
DEPTH TO BOTTOM OF STRATUM			10 PUMPING LEVEL: below land surface		
<u>SAND</u> <u>40</u> <u>40</u>			<u>80</u> ft. after <u>2</u> hrs. pumping at <u>45</u> G.P.M.		
<u>clay</u> <u>5</u> <u>45</u>			_____ ft. after _____ hrs. pumping at _____ G.P.M.		
<u>SAND-COARSE</u> <u>45</u> <u>90</u>			11 WELL HEAD COMPLETION: ☒ Pitless adapter ☐ 12" above grade		
<u>clay</u> <u>4</u> <u>94</u>			☐ Basement offset ☐ Approved pit		
<u>COARSE SAND</u> <u>36</u> <u>130</u>			12 WELL GROUTED? ☐ No ☒ Yes From <u>115</u> to <u>5</u> ft.		
			☐ Neat cement ☒ Bentonite ☐ Other _____		
			No. of bags of cement _____ Additives _____		
			13 Nearest source of possible contamination		
			Type <u>Septic</u> Distance <u>200</u> ft. Direction <u>W</u>		
			Well disinfected upon completion? ☒ Yes ☐ No		
			Was old well plugged? ☐ Yes ☐ No		
			14 PUMP: ☐ Not Installed ☐ Pump Installation Only		
			Manufacturer's name _____		
			Model number <u>4FA35A30</u> HP <u>3</u> Volts <u>230</u>		
			Length of Drop Pipe <u>105</u> ft. capacity <u>35</u> G.P.M.		
			TYPE: ☒ Submersible ☐ Jet		
			PRESSURE TANK: _____		
			Manufacturer's name <u>XERO</u>		
			Model number <u>350 E302</u> Capacity _____ Gallons		
15. Remarks, elevation, source of data, etc.			16 WATER WELL CONTRACTOR'S CERTIFICATION:		
			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
			<u>ATMOS FLINTESON</u> REGISTERED BUSINESS NAME Address <u>10213 39 Rd</u> Signed <u>Mike Flint</u> Date <u>9-91</u>		
			Authority: _____ Completion: _____ Penalty: _____		
17. Rig Operator's Name: <u>Mike Flint</u>			Act 368 PA 1978 Required Conviction of a violation of any provision is a misdemeanor.		

WATER WELL AND PUMP RECORD

PART 127 ACT 368, P.A. 1978

PERMIT NUMBER

13078

1 LOCATION OF WELL		FRACTION		SECTION NUMBER		TOWN NUMBER		RANGE NUMBER	
County <u>Wexford</u>		Township Name <u>Haring</u>		<u>N 1/4 S 1/4 E 1/4</u>		<u>34</u>		<u>24</u>	
Distance And Direction From Road Intersection		Sketch Map:		3 OWNER OF WELL <u>Ray Griswald</u>		Address <u>9051 E 18 1/2 Rd. Cadillac, Mich.</u>		Address Same As Well Location? ☐ Yes ☒ No	
Street Address & City of Well Location		Locate with "X" in Section Below		4 WELL DEPTH: (completed) <u>102</u> ft.		Date of Completion <u>6-8-88</u>		5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug	
Sketch Map:		6 USE: ☒ Domestic ☐ Type I Public ☐ Type III Public		7 CASING: ☒ Steel ☒ Threaded ☐ Plastic ☐ Welded		Height Above/Below Surface <u>11</u> ft.		Weight <u>11</u> lbs./ft.	
Sketch Map:		8 SCREEN: ☐ Not Installed		Type <u>SS Drop</u> Diameter <u>3</u>		Slot/Gauze <u>7</u> Length <u>5 ft.</u>		Set between <u>97</u> ft and <u>102</u> ft.	
Sketch Map:		9 STATIC WATER LEVEL: <u>77</u> ft. below land surface ☐ Flow		10 PUMPING LEVEL: below land surface		11 WELL HEAD COMPLETION: ☐ P-toss adapter ☒ 12" above grade		12 WELL GROUTED? ☐ No ☒ Yes From <u>0</u> to <u>8</u> ft.	
Sketch Map:		13 Nearest source of possible contamination		Type <u>Septic</u> Distance <u>60 ft.</u> Direction <u>S</u>		Well disinfected upon completion? ☒ Yes ☐ No		14 PUMP: ☐ Not Installed ☐ Pump Installation Only	
Sketch Map:		15. Remarks, elevation, source of data, etc.		16. WATER WELL CONTRACTOR'S CERTIFICATION:		Manufacturer's name <u>FM</u>		Model number <u>3/4</u> HP <u>120</u>	
Sketch Map:		16. WATER WELL CONTRACTOR'S CERTIFICATION:		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		Length of Drop Pipe <u>80</u> ft capacity <u>60</u> G.P.M.		TYPE: ☒ Submersible ☐ Jet	
Sketch Map:		16. WATER WELL CONTRACTOR'S CERTIFICATION:		Address <u>10-5-41 Rd. Cadillac, Mich.</u>		PRESSURE TANK: Manufacturer's name <u>WW Tank</u>		Model number <u>60</u> Capacity <u>60</u> Gallons	
Sketch Map:		16. WATER WELL CONTRACTOR'S CERTIFICATION:		Signed <u>Joyd Miller</u>		Date <u>6-12-88</u>		AUTHORIZED REPRESENTATIVE	

MICHIGAN DEPARTMENT OF PUBLIC HEALTH

WATER WELL AND PUMP RECORD

 PERMIT NUMBER

1 LOCATION OF WELL		3 OWNER OF WELL:	
County WEXFORD	Township Name HARRIS	Fraction 1/4 11E NW 1/4	Section Number 34 Town Number 22 NIS Range Number 9 E/W
Distance And Direction From Road Intersection		Address 9380 E 36 Rd CADILLAC	
Street Address & City of Well Location		Address Same As Well Location? ☒ Yes ☐ No	
Locate with "X" in Section Below		4 WELL DEPTH: (completed) 125 ft. Date of Completion 1200 86	
Sketch Map: 		5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Auger ☐ Jetted ☐	
		6 USE: ☒ Domestic ☐ Type I Public ☐ Type III Public ☐ Irrigation ☐ Type IIa Public ☐ Heat pump ☐ Test Well ☐ Type IIb Public ☐	
2 FORMATION DESCRIPTION		7 CASING: ☐ Steel ☐ Threaded Height: Above/Below ☒ Plastic ☐ Welded Surface _____ ft. _____ in. to _____ ft. depth Weight _____ lbs./ft. _____ in. to _____ ft. depth Drive Shoe ☐ Yes Grouted Drill Hole Diameter ☐ No _____ in. to _____ ft. depth	
		8 SCREEN: ☐ Not Installed Type SLT THOMSON Diameter _____ Slot/Screen 10 Length _____ Set between _____ ft. and _____ ft. FITTINGS: ☒ K-Packer ☐ Lead Packer ☐ Brammer Check ☐ Blank above screen 3 ft. Other _____	
THICKNESS OF STRATUM DEPTH TO BOTTOM OF STRATUM		9 STATIC WATER LEVEL: 85 ft. below land surface ☐ Flow	
		10 PUMPING LEVEL: below land surface _____ ft. after _____ hrs. pumping at _____ G.P.M. _____ ft. after _____ hrs. pumping at _____ G.P.M.	
SAND CLAY & SAND GRAVEL CLAY SAND		11 WELL HEAD COMPLETION: ☐ Pitless adapter ☐ 12" above grade ☐ Basement offset ☐ Approved pit	
		12 WELL GROUTED? ☐ No ☐ Yes From _____ to _____ ft. ☐ Neat cement ☐ Bentonite ☐ Other _____ No. of bags of cement _____ Additives _____	
15. Remarks, elevation, source of data, etc.		13 Nearest source of possible contamination Type _____ Distance _____ ft. Direction _____ Well disinfected upon completion? ☐ Yes ☐ No	
		14 PUMP: ☐ Not Installed ☐ Pump Installation Only Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of Drop Pipe _____ ft. capacity _____ G.P.M. TYPE: ☐ Submersible ☐ Jet PRESSURE TANK: Manufacturer's name _____ Model number _____ Capacity _____ Gallons	

USE A 2ND SHEET IF NEEDED

 RECEIVED
 Mich. Dept. of Public Health

 OCT 08 1986
 Bureau of Environmental and
 Occupational Health

 WATER WELL CONTRACTOR'S CERTIFICATION:
 This well was drilled under my jurisdiction and this report is true
 to the best of my knowledge and belief.

 REGISTERED BUSINESS NAME _____ REGISTRATION NO. _____
 Address _____
 Signed _____ Date _____
 AUTHORIZED REPRESENTATIVE


 Authority: Act 380 PA 1878
 Completion: Required
 Penalty: Conviction of a violation
 of any provision is a
 misdemeanor.

GEOLOGICAL SURVEY COPY

WATER WELL AND PUMP RECORD

PART 127 ACT 368, P.A. 1978

PERMIT NUMBER

1 LOCATION OF WELL					
County	Township Name	Fraction	Section Number	Town Number	Range Number
Wexford	CLAM LAKE	NE 1/4 SE 1/4 SE 1/4	34	22 N/4	9 NW
Distance And Direction From Road intersection 405 Crosby Rd					
Street Address & City of Well Location		3 OWNER OF WELL: WILLIAM AND KAREN PANASIWIZ Address 405 N. Crosby Rd, Cadillac Mich. 49601 Address Same As Well Location? ☒ Yes ☐ No			
Locate with "X" in Section Below 		4 WELL DEPTH: (completed) 105 ft. Date of Completion MAY 5, 1986			
2 FORMATION DESCRIPTION Clay Sand and Gravel		THICKNESS OF STRATUM		DEPTH TO BOTTOM OF STRATUM	
		15		15	
		90		105	
		5 CASING: ☒ Steel ☐ Threaded ☐ Plastic ☒ Welded Diameter 4 in. to 100 ft. depth 3 in. to 105 ft. depth Groutod Drill Hole Diameter in to ft. depth in to ft. depth			
		6 USE: ☒ Domestic ☐ Type I Public ☐ Type III Public ☐ Irrigation ☐ Type IIa Public ☐ Heat pump ☐ Test Well ☐ Type IIb Public ☐			
		7 SCREEN: ☐ Not Installed Type Howard Smith Diameter 3 inch Slot/Gauze 7 Length 3 x 5 ft. Set between 100 ft. and 105 ft. FITTINGS: ☒ Packer ☐ Lead Packer ☐ Rammer Check ☐ Blank above screen 18 inch Other			
		8 STATIC WATER LEVEL: 70 ft. below land surface ☐ Flow			
		9 PUMPING LEVEL: below land surface 92 ft. after 1 hrs. pumping at 10 G.P.M. ft. after hrs. pumping at G.P.M.			
		10 WELL HEAD COMPLETION: ☒ Well adapter ☐ 12" above grade ☐ Basement offset ☐ Approved pit			
		11 WELL GROUTED? ☐ No ☐ Yes From to ft. ☐ Neat cement ☐ Bentonite ☐ Other No. of bags of cement Additives			
		12 Nearest source of possible contamination Type Septic Distance 50 ft. Direction S.W. Well disinfected upon completion? ☒ Yes ☐ No			
		13 PUMP ☐ Not installed ☐ Pump Installation Only Manufacturer's name Burke Model number HP 3/4 Volts 230 Length of Drop Pipe 184 ft. capacity G.P.M. TYPE: ☒ Submersible ☐ Jet PRESSURE TANK: Clayton Mark Manufacturer's name Model number Capacity Equal 60 Gallons			
15. Remarks. elevation, source of data, etc.		16. WATER WELL CONTRACTOR'S CERTIFICATION: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rogers and Son 1567 REGISTERED BUSINESS NAME REGISTRATION NO. Address 2031 E 34 Rd. Cadillac Signed George Rogers Date May 5, 1986 AUTHORIZED REPRESENTATIVE			