

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 9/20/2018 7:24:58 AM
To: "Popovich, Bradley (DEQ)" <PopovichB@michigan.gov>; "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: RE: Cadillac WWTP NPDES Permit Renewal

Bradley,

Yes, U.V. has completely replaced the chlorine system. The chlorine and so2 equipment was obsolete and has been removed. We do not have any newer flow diagram than the one I sent you. The diagram is the same less chlorine and so2.

I hope this helps. If you need anything else feel free to contact me.

Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841

From: Popovich, Bradley (DEQ) [mailto:PopovichB@michigan.gov]
Sent: Wednesday, September 12, 2018 2:47 PM
To: Doug Langworthy; Jeff Dietlin
Cc: Brady, Donal (DEQ)
Subject: RE: Cadillac WWTP NPDES Permit Renewal

Good Afternoon Doug,

Within the attached WWTP History document there appears to be mention of replacing chlorine disinfection with UV; however, it appears that chlorine information is still present within the attached Process Flow Diagram. Do you have any maps that are more representative of your current system? Or is Chlorine still involved in the treatment system?

Thanks!

Bradley Popovich

Environmental Quality Analyst

Water Resources Division

Municipal Permits Unit

Michigan Department of Environmental Quality

(517) 284-6656

PopovichB@Michigan.gov

Monday – Friday 8:00-4:30

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: Tuesday, July 31, 2018 7:31 AM

To: Popovich, Bradley (DEQ) <PopovichB@michigan.gov>; Jeff Dietlin <utilities@Cadillac-MI.net>
Cc: Brady, Donal (DEQ) <BradyD6@michigan.gov>
Subject: RE: Cadillac WWTP NPDES Permit Renewal

Bradley,

Attached you will find an updated flow diagram and general narrative of the treatment plant. If you need anything else please feel free to contact me.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841

From: Popovich, Bradley (DEQ) [<mailto:PopovichB@michigan.gov>]
Sent: Thursday, July 19, 2018 1:33 PM
To: Doug Langworthy; Jeff Dietlin
Cc: Brady, Donal (DEQ)
Subject: RE: Cadillac WWTP NPDES Permit Renewal

Good Afternoon Doug and Jeff,

I am currently in the process of reissuing Cadillac WWTP's NPDES Individual permit and have a few things that I'd like to follow up with you on. Please reference the email correspondence below in which Don requests upgraded flow diagrams that include use of UV. Additionally, in order to move further with the permitting process an updated narrative description that includes mention of UV's involvement within your treatment system is needed.

Please provide the updated flow diagram and narrative description to me by **August 2, 2018**. If you have any questions, comments, or concerns please let me know, I'd love to help in any way that I can!

Bradley Popovich

Environmental Quality Analyst

Water Resources Division

Municipal Permits Unit

Michigan Department of Environmental Quality

(517) 284-6656

PopovichB@Michigan.gov

Monday – Friday 8:00-4:30

From: Brady, Donal (DEQ)
Sent: Monday, July 16, 2018 2:54 PM
To: Popovich, Bradley (DEQ) <PopovichB@michigan.gov>
Subject: FW: Cadillac WWTP NPDES Permit Renewal

FYI.



Don Brady, P.E.
Michigan Department of Environmental Quality
Water Resources Division
Cadillac District Office
120 West Chapin Street
Cadillac, MI 49601
BradyD6@michigan.gov
(231) 876-4478

From: Brady, Donal (DEQ)
Sent: Friday, January 5, 2018 6:18 PM
To: Doug Langworthy <dlangworthy@Cadillac-MI.net>; lab@cadillac-mi.net
Cc: Schmitt, Glen (DEQ) <SCHMITTG1@michigan.gov>
Subject: Cadillac WWTP NPDES Permit Renewal

Hi Doug and Cindy,

The DEQ is working on the NPDES permit renewal for the Cadillac WWTP and a couple questions came up.

1. Copper analysis detection limit – As Cindy and I discussed, the current detection limit is 50 ug/L but the plant's lab may be able to achieve a lower limit. The new permit will likely include limits for copper lower than 50 ug/L. Could you please look into this and let me know what detection limit you think you could achieve? If you would like to start conducting the copper analysis with the lower limit, DEQ's permit staff will consider these results.
2. UV Disinfection - The process flow diagrams included with the renewal application showed chlorine disinfection. I know the plant uses UV. Do you have any updated diagrams you could send us?

Thanks for looking into this. Please let me know if you have any questions.



Don Brady, P.E.
Michigan Department of Environmental Quality
Water Resources Division
Cadillac District Office
120 West Chapin Street
Cadillac, MI 49601
(231) 876-4478
BradyD6@michigan.gov