

SELF MONITORING RECORDSFacility Designated Name: Cadillac WWTPPermit No.: MI0020257

YES NO N/A 1. Are all records and information resulting from the monitoring activities required by this permit maintained for at least three years? [40 CFR 122.41 (j) (2)] Examples include DMR's, MORs, lab data, chain of custody forms, calibration & maintenance records and recordings from continuous monitoring instrumentation.

YES NO N/A 2. Are analytical results/bench sheets consistent with the data reported on the DMRs? Use the table(s) below to spot check at least three sets of data points (including geometric means, loadings, averages, etc.).

Now, Fill this out

For the month of: July Year: 2014 Sampling Point: CO/A

Day	Type of Sample	Parameter	Reported Result (from DMR)	Site Record (from bench sheet or contract lab)	Accurate? Yes/No
<u>13</u>	<u>Grab</u>	<u>D.O.</u>	<u>8.1</u>	<u>8.1</u>	<u>Yes</u>

For the month of: August Year: 14 Sampling Point: CO/A

Day	Type of Sample	Parameter	Reported Result (from DMR)	Site Record (from bench sheet or contract lab)	Accurate? Yes/No
<u>1</u>	<u>24-Hr Composite</u>	<u>TSS</u>	<u>2.40</u>	<u>2.40</u>	<u>Yes</u>

For the month of: _____ Year: _____ Sampling Point: _____

Day	Type of Sample	Parameter	Reported Result (from DMR)	Site Record (from bench sheet or contract lab)	Accurate? Yes/No

YES NO N/A 3. If the data is not consistent, can permittee explain any discrepancies? _____

YES NO N/A 4. Does the facility have authorization for elimination of, or reduced monitoring? If yes, complete the table below.

Parameter				
Frequency				

5. Monitoring Records are adequate and include: [40 CFR 122.41 (j) (3) (i-v)]

- YES NO N/A a. Dates, times, frequency and location of sample collection,
YES NO N/A b. Name of individual (s) performing sampling, - *multiple people sharing sh. Sh.*
YES NO N/A c. Results of analyses,
YES NO N/A d. Dates of analyses,
YES NO N/A e. Name of person (s) performing analyses,
YES NO N/A f. Analytical technique or method used.

YES NO N/A 6. Are laboratory bench sheets and other records understandable and clearly filled out?

YES NO N/A 7. Does the inspection contact/operator have a current copy of the permit?

YES NO N/A 8. Does the file contain information on any water treatment additive(s) that have been approved? List product name(s) and approved concentration(s):

* check file ✓
Ferric Chloride
Tablet chlorine mixed liquor tank to kill
phillipsburg bacteria .1.1 Regent.

Closing Conference Notes:

Cu typically < 50 ppb email to delia
check against Harry permit.

Completed By: Jamie Wrote Date of Inspection: 10-14-14

Revised 3/13