

Report of Discharge (CSO/SSO/RTB)

version 1.15

(Submission #: HQN-7PHN-WHK7P, version 1)

Digitally signed by:
MiEnviro Portal
Date: 2026.05.01 15:28:03 -04:00
Reason: Submission Data
Location: State of Michigan

Details

Submission ID HQN-7PHN-WHK7P

Form Input

Report Details

Is this the initial or final discharge report?

Initial

Site/Facility Name:

Cadillac WWTP

Permit Number (if applicable):

MI0020257

Sewer System or Treatment Facility Owner

Organization Name

City of Cadillac

Phone Type	Number	Extension
------------	--------	-----------

Business	2317752841	
----------	------------	--

Email

utilities@cadillac-mi.net

Fax

NONE PROVIDED

Address

200 North Lake Street

Cadillac, MI 49601

United States

Facility Address

1121 PLETT RD

CADILLAC, MI 49601-1211

Sewer System or Treatment Facility Owner Location

44.2656,-85.3978

1121 PLETT RD, CADILLAC, MI

Discharge Details (1 of 1)

SSO Discharge from Leeson Lift Station`OUTFL\_ID\_TXT`

Discharge Type:

SSO Discharge

SSO Discharge

The reported discharge is from a private or municipal separate sewer collection system (not a wastewater treatment plant) during wet or dry weather, or a dry weather discharge from a municipal combined sewer collection system.

Is the outfall or discharge area located at a private residential address?

NO

Outfall or Discharge Area Name

Leeson Lift Station

Outfall or Discharge Area Description

Sanitary Sewer Lift Station

Outfall or Discharge Area Location

44.25274488672084,-85.42600625564624

Has the discharge ended?

YES

Volume Discharged	Unit	Was the volume estimated?
10000	Gallons	Yes

Quality of Discharge

Diluted Raw Sewage

Please describe the discharge, including the reason for Discharge

Lake Cadillac floded banks and lake water swamped the Lift Station. Lift station was under 3 feet of Lake/Storm water.

Was the land or surface water impacted by the discharge?

Both land and water impacted

Name of Surface Water(s) Impacted:
Storm Pond corner of Leeson and West Division

Name/description of the land impacted:

Storm Pond corner of Leeson and West Division

Discharge Event Start

Date	Time
04/19/2026	06:00 am

Discharge Event End

Date	Time
04/19/2026	08:00 pm

Initial Notification

Organization	Date	Time
Local Health Department	05/01/2026	03:00 pm
Daily Local Newspaper	05/01/2026	03:30 pm

Was EGLE notified prior to this report being received?

This report is being used as the initial notification to EGLE

Notification that discharge has concluded.

Organization	Date	Time
Local Health Department	05/01/2026	03:00 pm
Daily Local Newspaper	05/01/2026	03:30 pm

Precipitation Type(s) (Select none if there was no precipitation)

Rain

Has the precipitation ended?

YES

Precipitation

Start Date	Start Time
04/01/2026	08:00 am

Precipitation Amount (Inches)	Precipitation End Date	Precipitation End Time
11.75	04/17/2026	08:00 am

Precipitation comments

Lake Cadillac is at the highest levels ever recorded. When the Lake breached the banks water flowed to low point by lift Station. We are still trying to get certian areas un flooded.

Was this discharge disinfected to meet fecal coliform limitations?

NO

Additional Details**Report Submitter****Prefix**

Mr.

First Name

Jeffrey

Last Name

Dietlin

Title

Utilities Director

Organization Name

Cadillac Utilities Department

Phone Type**Number****Extension**

Business

2317750181

Email

utilities@cadillac-mi.net

Fax

NONE PROVIDED

Address

200 N Lake St Ste 1

Cadillac, Michigan 49601-1864

[NO COUNTRY SPECIFIED]

Do you have any additional comments or uploads you would like to provide?

NO