

Cadillac WWTP : 15637

NPDES - Reconnaissance Inspection

Inspector: Matthew Anderson

Start Date: 04/10/2024

NPDES - Reconnaissance Inspection

1. Date of Inspection:	04/10/2024
2. Approximate Start Time:	1:00 PM
3. Permit No.:	MI0020257 v7.0
4. Facility Designated Name:	Cadillac WWTP
5. Inspection Purpose/Description	Scheduled

6. Inspection Participant Information

Participant Name	Title	Affiliation	Phone Number	Email Address
Matt Anderson	Environmental Quality Analyst	EGLE	231-429-1278	andersonm70@michigan.gov
Tom Asmus	Environmental Quality Specialist	EGLE	906-202-1439	asmust@michigan.gov
Patrick Miller	Water Resource Supervisor	City of Cadillac	231-306-8084	pmiller@cadillac-mi.net

7. Opening Conference Notes:

Introductions with EGLE, Patrick Miller, and other Cadillac WWTP staff. Matt Anderson has taken over as EGLE NPDES compliance contact.

8. Observation and Discussion Notes:

Site walkthrough of Cadillac WWTP with Patrick Miller. Plant appeared to be well operated/maintained.

Discussed plans to update the plant's grit removal screening system to prevent/reduce downstream flow of grit.

Discussed plans to update the plant's UV disinfection system as the automatic wipers are no longer working and are required to be manually cleaned.

The plant was in the process of replacing a pump to transport primary waste to the anaerobic digester to help aid in sludge thickening.

The plant was also exploring potential gas capture systems to collect and utilize the gas generated by the anaerobic digesters.

The plant discussed plans to obtain filter sets for their AquaDisk tertiary filter to more efficiently maintain the operating capability of the filter.

The plans discussed are likely to better aid maintenance around the facility and hopefully reduce number of work orders.

Plant was having difficulty with co-settling and is now wasting secondary sludge to an unused primary clarifier.

9. Closing Conference Notes:

EGLE will be following up in regard to the HACH Ammonia HQ440D testing methods.

10. Were photographs taken? ☐ Yes ☒ No

11. Completed By: Matt Anderson