



Testing • Research • Consulting

Multiple Analysis Report

Sample: 406309

April 6, 2021

Ms. Cindy Tomaszewski
City of Cadillac
200 N. Lake St.
Cadillac, MI 49601

RE: PWS ID#: Unavailable
City of Cadillac
Digester #4
1121 Plett Rd.
Cadillac, MI 49601

Dear Ms. Tomaszewski:

The following are the result(s) of the test(s) performed on the sample(s) received at HML, Inc. at 10:31 AM, 3/4/2021, and collected at 1:45 PM, 3/3/2021:

<u>TEST - METHOD</u>	<u>RESULT</u>	<u>MDL*</u>	<u>Date Complete</u>
Fecal Coliform-EPA 1680	337 MPN/g dry	1 MPN/g dry	3/6/2021
Enteric Virus-EPA 625/R-92/013	<1 pfu/4g dry	1 pfu/4g dry	4/6/2021
Solids, total-SM 2540G	3.26%	0.005%	3/5/2021
Salmonella-EPA 1682	<3 MPN/4 g dry	3 MPN/4 g dry	3/9/2021
Helminth Ova-EPA/625/R-92/013	<1 ovum/4g dry	1 ovum/4 g dry	4/6/2021

*Minimum Detection Level

This testing was completed by T.K. Please feel free to contact us if we can be of further service to you.

Sincerely,

Donald A. Hendrickson, Ph.D.
President - Microbiologist
Chemistry Lab #C-18-01
Microbiological Lab #M-18-03

DAH/skp