



Testing Research Consulting

MULTIPLE ANALYSIS REPORT

Sample: 230414134A (445424)

May 15, 2023

City of Cadillac
200 N. Lake St.
Cadillac, MI 49601

RE: City of Cadillac, 1121 Plett Rd., Cadillac, MI 49601, Digester 3
Collected: 04/13/23 at 02:30 PM

Dear Sir or Madam:

The following are the results of the tests performed on the sample received at HML on 04/14/23

TEST	METHOD	Result	UNITS	Date Completed	Analyst
Enteric Virus	EPA 625/R-92/0	< 1	pfu/4g dry	5/11/2023	TK
Fecal Coliform, 503 Pathogen	EPA 1680	593	MPN/g dry	4/18/2023	MW
Helminth Ova	EPA 625/R-92/0	< 1	ovum/4gdry	5/12/2023	TK
Salmonella	EPA 1682	< 3	MPN/4g dry	4/22/2023	MW
Total Solids	SM2540G	2.90	%	4/20/2023	TK

This report shall not be reproduced except in full, without written approval of the laboratory.
Please feel free to contact us if we can be of further service to you.

Sincerely,

Donald A. Hendrickson

Donald A. Hendrickson, Ph.D.
President-Microbiologist
Chemistry Lab #C-18-01
Microbiological Lab #M-18-03

912 W. McGalliard Rd., Muncie, IN 47303

[illegible]

Relinquished by: <i>W. A. Thomas</i>	Date: <i>4-13-23</i>	Time: <i>1500</i>
Relinquished by:	Date:	Time:
Relinquished by:	Date:	Time:
Field Notes:		

Received By: UPS Overnight	Date:	Time:
Received By:	Date:	Time:
Received By: Michael Christ	Date: 4-14-23	Time: 3:30 PM
		Temp Received: 76