



Testing • Research • Consulting

Multiple Analysis Report

Sample: 417132

October 1, 2021

Ms. Cindy Tomaszewski
City of Cadillac
200 N. Lake St.
Cadillac, MI 49601

RE: PWS ID#: Unavailable
City of Cadillac
Digester #4
1121 Plett Rd.
Cadillac, MI 49601

Dear Ms. Tomaszewski:

The following are the result(s) of the test(s) performed on the sample(s) received at HML, Inc. at 10:04 AM, 9/3/2021, and collected at 2:00 PM, 9/2/2021:

<u>TEST - METHOD</u>	<u>RESULT</u>	<u>MDL*</u>	<u>Date Complete</u>
Fecal Coliform-EPA 1680	76 MPN/g dry	1 MPN/g dry	9/7/2021
Enteric Virus-EPA 625/R-92/013	<1 pfu/4g dry	1 pfu/4g dry	9/24/2021
Solids, total-SM 2540G	3.14%	0.005%	9/8/2021
Salmonella-EPA 1682	<3 MPN/4 g dry	3 MPN/4 g dry	9/7/2021
Helminth Ova-EPA/625/R-92/013	<1 ovum/4g dry	1 ovum/4 g dry	10/1/2021

*Minimum Detection Level

This testing was completed by T.K. Please feel free to contact us if we can be of further service to you.

Sincerely,

Donald A. Hendrickson

Donald A. Hendrickson, Ph.D.
President - Microbiologist
Chemistry Lab #C-18-01
Microbiological Lab #M-18-03

DAH/skp