

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 10/25/2017 9:51:55 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: BOD Violation (Permit# MI0020257)

Don,

Today we had a BOD violation of 11.3 mg/L for the day of Friday 10-20-2017. The violation comes after a spike of filamentous bacteria in our activated sludge process. I believe we have the filamentous under control now. If you have any questions feel free to contact me.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841