

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 5/24/2017 9:49:27 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>; "Jankowski, Brian (DEQ)" <JANKOWSKIB@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: BOD Violation (Permit No MI0020257)

Mr. Brady,

Per our conversation, I'm giving you written notice of our BOD exceedances of 5/15 10.2 mg/L, 5/17 11.7 mg/L, 5/18 >17.1 mg/L (pump issue) and 5/19 11.7 mg/L. I still believe weather is playing a factor in our ability to remove BOD. We are working hard and hopeful for more seasonal temps to resolve these issues.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841