

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 7/12/2017 10:54:35 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: BOD Violation

Mr. Brady

On 7/3 we had a BOD exceedance of 14.0 mg/L and on 7/6 we also had a 13.9 mg/L over our 10.0 mg/L daily.

On both days we had high depletions in our blank. I believe our nutrient water is to blame for the exceedances.

We are currently sourcing our water from a different location and hope this will help.

Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841