

From: Schmitt, Glen (DEQ)
To: [Bitondo, Mike \(DEQ\)](#)
Subject: Cadillac WWTP (MI0020257) Available Cyanide Recommendation
Date: Wednesday, September 04, 2013 9:00:00 AM

Hi Mike,

Per the request in the conference call we had with representatives from the Cadillac WWTP on 9/4/2013, we have evaluated the monitoring frequency for available cyanide in the draft permit. The current permit requires weekly monitoring for available cyanide to determine compliance with the monthly average final effluent limitations (5.9 ug/l (0.16 lbs/day)). Because this is a monthly average final effluent limitation and the current available data indicate only 2 of 21 results would have exceeded the limit, we recommend the monitoring frequency in the draft permit be reduced to monthly. In addition, the language in Part I.A.1.f, Monitoring Frequency Reduction for Available Cyanide and Total Copper, can be changed from monthly to quarterly for available cyanide.

Please let me know if you should have any questions. Thanks!

Glen P. Schmitt
Senior Aquatic Biologist
Lakes Michigan and Superior Permits Unit
Permits Section, Water Resources Division
Michigan Department of Environmental Quality
Telephone: 517-241-0910
Fax: 517-241-8133
E-mail: SchmittG1@michigan.gov