

From: Bush, Jennifer (EGLE)
Sent: 10/29/2021 1:38:38 PM
To: "utilities@cadillac-mi.net" <utilities@cadillac-mi.net>
Cc: "Sneller, Cindy (EGLE)" <SNELLERC@michigan.gov>; "Tavalire, Anne (EGLE)" <TavalireA@michigan.gov>
Subject: 2021 Biosolids PFAS Monitoring Report Review - Cadillac WWTP

Hello Jeffrey Dietlin,

On October 14, 2021, the Cadillac Wastewater Treatment Plant (WWTP) notified the Department of Environment, Great Lakes, and Energy (EGLE), Water Resources Division (WRD), that a biosolids sample collected from the Cadillac WWTP was analyzed for Per- and Polyfluoroalkyl substances (PFAS). This is in accordance with the requirements set forth in the WRD's *Interim Strategy for Land Application of Biosolids Containing (Interim Strategy) PFAS* and the Residuals Management Program (RMP) Modification letter dated April 5, 2021, which became part of the WWTP's approved RMP.

The laboratory results indicate that the PFAS analyte, Perfluorooctanoic Sulfonate (PFOS), concentrations in biosolids were 5.3 microgram per kilogram (ug/kg) (parts per billion [ppb]) on July 20, 2021. Because the current analytical results for PFOS in biosolids are 20 ug/kg or below, no additional source identification efforts are required at this time to comply with the conditions of the Interim Strategy.

Please note the following PFAS requirements for all WWTPs land applying bulk biosolids in Michigan:

- Provide the most current PFOS analytical results and additional information specific to PFAS and biosolids in Michigan to landowners and farmers prior to the land application of biosolids. Information on notification requirements and sample templates can be obtained from [Michigan Biosolids PFAS-related information and links](#).
- Beginning in calendar year 2022, collect a minimum of one (1) annual biosolids PFAS sample prior to initial land application each year, unless otherwise notified by the WRD's Biosolids Program staff.

Additional information on sampling and investigating potential PFAS sources can be obtained by visiting the IPP PFAS Initiative Web page at: [EGLE - IPP PFAS Initiative](#). This link contains numerous documents, including Frequently Asked Questions, Wastewater PFAS Sampling Guidance, and Recommended PFAS Screening and Evaluation Guidance.

Please be advised that if new PFAS information becomes available or new standards or requirements are implemented, the WRD may require additional actions in accordance with the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended, and its administrative rules.

Thank you for protecting Michigan's public health and environment from these emerging pollutants. Should you need further information, please feel free to contact me.

Jennifer Bush

Environmental Quality Analyst
Michigan Department of Environment, Great Lakes, and Energy (EGLE)
Water Resources Division | Emerging Pollutants Section
Phone Number: 517-667-1296