

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 4/1/2019 - 4/30/2019
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	45 mg/L	1200 lbs/day	(report) mg/L	(report) lbs/day	25 mg/L	670 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
4/1/2019	1.49	6.00	74.65	5.04	74.81	6.00	74.7
4/2/2019	1.90	4.80	76.01	4.96	75.01	4.20	66.5
4/3/2019	1.85	5.60	86.22	5.04	77.00	4.60	70.8
4/4/2019	1.88	4.00	62.67	4.64	71.41	4.80	75.2
4/5/2019	1.86	4.80	74.48	4.56	69.54	4.40	68.3
4/6/2019	1.66			4.16	63.23		
4/7/2019	1.46			4.16	63.23		
4/8/2019	1.62	5.60	75.65	4.16	63.23	5.25	70.9
4/9/2019	1.98	5.20	86.00	3.60	55.62	3.50	57.9
4/10/2019	1.94	3.60	58.25	3.36	51.77	4.20	68.0
4/11/2019	1.78	3.60	53.33	3.36	52.02	6.10	90.4
4/12/2019	1.84	2.80	42.95	3.04	48.50	6.50	99.7
4/13/2019	1.90			2.64	42.59		
4/14/2019	1.48			2.64	42.59		
4/15/2019	1.61	2.80	37.59	2.64	42.59	7.00	94.0
4/16/2019	2.00	4.00	66.72	2.72	43.78	5.10	85.1
4/17/2019	1.98	3.60	59.54	2.40	38.66	5.70	94.3
4/18/2019	2.14	2.00	35.69	2.24	35.57	6.40	114.2
4/19/2019	2.01	0.80	13.43	2.56	39.94	7.60	127.6
4/20/2019	2.27			2.88	44.50		
4/21/2019	1.99			2.88	44.50		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 <table style="width: 100%;"> <tr> <th style="width: 15%;">AREA CODE</th> <th style="width: 15%;">NUMBER</th> </tr> </table>	AREA CODE	NUMBER	<table style="width: 100%;"> <tr> <th colspan="3">DATE</th> </tr> <tr> <td style="width: 33%;">2019</td> <td style="width: 33%;">05</td> <td style="width: 33%;">17</td> </tr> <tr> <th>YEAR</th> <th>MO</th> <th>DAY</th> </tr> </table>	DATE			2019	05	17	YEAR	MO	DAY
AREA CODE	NUMBER														
DATE															
2019	05	17													
YEAR	MO	DAY													

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 4/1/2019 - 4/30/2019
DMR Version: 1

4/22/2019	1.63	3.20	43.54	2.88	44.50	10.10	137.4
4/23/2019	2.05	2.40	41.11	3.68	53.78	5.85	100.2
4/24/2019	1.89	2.80	44.07	4.16	60.73	6.00	94.4
4/25/2019	1.92	3.60	57.57	4.50	64.90	4.80	76.8
4/26/2019	1.81	2.40	36.24	4.80	67.34	4.65	70.2
4/27/2019	1.63			6.00	82.89		
4/28/2019	1.47			6.00	82.89		
4/29/2019	1.50	7.20	89.90	6.00	82.89	6.10	76.2
4/30/2019	1.90	4.80	75.89	4.80	75.89	9.00	142.3

Set: 2 of 4

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) ug/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
4/1/2019	71.1	0.30	3.73	0.20	2.49		
4/2/2019	70.3	0.30	4.75	0.28	4.43		<50.000
4/3/2019	68.6	0.30	4.62	0.23	3.54		
4/4/2019	68.0	0.30	4.70	0.23	3.60		
4/5/2019	71.1	0.30	4.66	0.20	3.10		
4/6/2019	77.4						
4/7/2019	77.4						
4/8/2019	77.4	0.30	4.05	0.22	2.97		
4/9/2019	82.0	0.30	4.96	0.18	2.98		
4/10/2019	87.4	0.30	4.85	0.18	2.91		
4/11/2019	92.7	0.30	4.44	0.16	2.37		<50.000
4/12/2019	97.4	0.30	4.60	0.15	2.30		
4/13/2019	103.0						<50.000

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2019 05 17 YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 4/1/2019 - 4/30/2019
DMR Version: 1

4/14/2019	103.0						
4/15/2019	103.0	0.30	4.03	0.14	1.88		
4/16/2019	111.7	0.30	5.00	0.12	2.00		
4/17/2019	114.7	0.40	6.62	0.12	1.99		<50.000
4/18/2019	114.8	1.27	22.67	0.12	2.14		
4/19/2019	107.3	1.02	17.13	0.15	2.52		
4/20/2019	95.8						
4/21/2019	95.8						
4/22/2019	95.8	0.30	4.08	0.15	2.04	<1.10	
4/23/2019	83.6	1.96	33.57	0.17	2.91		
4/24/2019	92.0	3.28	51.62	0.13	2.05		
4/25/2019	91.4	1.01	16.15	0.15	2.40		
4/26/2019	96.2	0.77	11.63	0.17	2.57		
4/27/2019	102.4						
4/28/2019	112.4						
4/29/2019	112.4	0.30	3.75	0.24	3.00		
4/30/2019	124.5	0.30	4.74	0.24	3.80		

Set: 3 of 4

Parameter	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)	Fecal Coliform
Mon. Loc.	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC	400 #/100mL
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Max 7-Day Geometric Mean
4/1/2019	*G	*G	*G	*G	*G	*G	1.0
4/2/2019							1.0
4/3/2019							1.0
4/4/2019							1.0
4/5/2019							1.0

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2019 05 17 YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 4/1/2019 - 4/30/2019
DMR Version: 1

4/6/2019							1.0
4/7/2019							1.0
4/8/2019							1.0
4/9/2019							1.0
4/10/2019							1.0
4/11/2019							1.0
4/12/2019							1.0
4/13/2019							1.0
4/14/2019							1.0
4/15/2019							1.0
4/16/2019							1.0
4/17/2019							1.0
4/18/2019							1.0
4/19/2019							1.0
4/20/2019							1.0
4/21/2019							1.0
4/22/2019							1.0
4/23/2019							1.0
4/24/2019							1.0
4/25/2019							1.0
4/26/2019							
4/27/2019							
4/28/2019							
4/29/2019							
4/30/2019							

Set: 4 of 4

Parameter	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen		
Mon. Loc.	Fecal Daily	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2019 05 17 YEAR MO DAY
--	---	--	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 4/1/2019 - 4/30/2019
DMR Version: 1

Limit	(report) #/100mL	(report) %	6.5 SU	9.0 SU	5.0 mg/L		
Stat. Base	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily		
4/1/2019	1	96.809	6.82	6.8	10.2		
4/2/2019	1	97.966	6.68	6.7	9.6		
4/3/2019	1	97.407	6.81	6.8	9.5		
4/4/2019	1	97.727	6.76	6.8	9.4		
4/5/2019	1	97.818	6.76	6.8	9.3		
4/6/2019							
4/7/2019							
4/8/2019	1	97.91	6.79	6.8	9.5		
4/9/2019	1	97.593	6.83	6.8	9.2		
4/10/2019	1	97	7.25	7.3	9.2		
4/11/2019	1	98.421	6.82	6.8	9.3		
4/12/2019	1	99.157	6.69	6.7	9.3		
4/13/2019							
4/14/2019							
4/15/2019	1	98.6	6.94	6.9	10.0		
4/16/2019	1	98.387	7.66	7.7	9.4		
4/17/2019	1	97.955	7.13	7.1	8.9		
4/18/2019	1	99.219	6.96	7.0	8.4		
4/19/2019	1	99.623	6.82	6.8	8.6		
4/20/2019							
4/21/2019							
4/22/2019	1	98.4	6.92	6.9	9.1		
4/23/2019	1	98.333	6.71	6.7	7.7		
4/24/2019	1	98.654	6.83	6.8	7.8		
4/25/2019	1	98.636	6.69	6.7	8.4		
4/26/2019	1	99.326	6.74	6.7	7.8		
4/27/2019							
4/28/2019							
4/29/2019	1	97.75	6.86	6.9	9.7		
4/30/2019	1	98.182	6.99	7.0	9.2		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2019 05 17
--	---	---	---	---------------------------------	------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 4/1/2019 - 4/30/2019
DMR Version: 1

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2019	05	17
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY