

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 6/1/2019 - 6/30/2019
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	30 mg/L	800 lbs/day	(report) mg/L	(report) lbs/day	10 mg/L	270 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
6/1/2019	1.89			8.94	140.79		
6/2/2019	1.60			8.94	140.79		
6/3/2019	1.53	8.67	110.79	8.94	140.79	5.90	75.4
6/4/2019	1.92	6.70	107.17	9.61	153.79	7.00	112.0
6/5/2019	1.94	8.00	129.68	10.93	179.21	8.00	129.7
6/6/2019	2.01	9.33	156.29	11.47	188.58	8.20	137.4
6/7/2019	2.00	12.00	200.03	11.73	205.69	7.80	130.0
6/8/2019	1.89			15.07	254.57		
6/9/2019	1.65			15.07	254.57		
6/10/2019	1.76	12.00	175.76	15.07	254.57	8.10	118.6
6/11/2019	2.11	13.33	234.30	15.60	259.59	7.65	134.5
6/12/2019	1.98	10.67	176.52	15.20	250.13	7.20	119.1
6/13/2019	2.72	10.67	241.84	14.80	244.72	7.90	179.1
6/14/2019	1.86	28.67	444.40	14.00	218.74	15.30	237.2
6/15/2019	1.97			9.33	148.89		
6/16/2019	1.68			9.33	148.89		
6/17/2019	1.64	14.67	200.90	9.33	148.89	8.05	110.2
6/18/2019	1.98	11.33	186.98	7.73	128.12	7.42	122.5
6/19/2019	2.07	8.67	149.49	6.13	102.61	6.30	108.6
6/20/2019	2.01	6.67	111.95	5.74	96.10	6.30	105.7
6/21/2019	2.14	5.33	95.14	5.47	90.31	6.10	108.9

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">AREA CODE</td> <td style="width: 50%;">NUMBER</td> </tr> </table>	AREA CODE	NUMBER	DATE 2019 07 18 <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">YEAR</td> <td style="width: 33%;">MO</td> <td style="width: 33%;">DAY</td> </tr> </table>	YEAR	MO	DAY
AREA CODE	NUMBER								
YEAR	MO	DAY							

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 6/1/2019 - 6/30/2019
DMR Version: 1

6/22/2019	1.91			6.00	94.53		
6/23/2019	1.80			6.00	94.53		
6/24/2019	1.75	6.67	97.05	6.00	94.53	6.58	95.7
6/25/2019	2.14	3.33	59.42	5.83	93.90	5.23	93.3
6/26/2019	2.09	6.70	116.92	6.67	105.39	6.53	113.9
6/27/2019	1.88	5.30	83.04	6.65	99.63	7.43	116.4
6/28/2019	1.74	8.00	116.21	8.00	116.21	5.30	77.0
6/29/2019	1.73						
6/30/2019	1.54						

Set: 2 of 4

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	2 mg/L	53 lbs/day	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
6/1/2019	116.9		4.94				
6/2/2019	116.9		4.94				
6/3/2019	116.9	0.30	4.94	3.83	0.23	2.94	
6/4/2019	125.5	0.30	5.05	4.80	0.26	4.16	
6/5/2019	130.0	0.30	5.14	4.86	0.25	4.05	
6/6/2019	127.9	0.30	5.16	5.03	0.27	4.52	
6/7/2019	136.3	0.37	6.47	6.17	0.28	4.67	
6/8/2019	157.7		15.93				
6/9/2019	157.7		15.93				
6/10/2019	157.7	0.30	15.93	4.39	0.40	5.86	
6/11/2019	156.0	0.30	15.88	5.27	0.42	7.38	
6/12/2019	153.6	0.30	15.81	4.96	0.35	5.79	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2019 07 18 YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 6/1/2019 - 6/30/2019
DMR Version: 1

6/13/2019	151.5	0.51	16.06	11.56	0.30	6.80	
6/14/2019	136.8	3.45	14.76	53.48	0.54	8.37	
6/15/2019	111.2		5.35				
6/16/2019	111.2		5.35				
6/17/2019	111.2	0.30	5.35	4.11	0.36	4.93	
6/18/2019	108.3	0.30	5.40	4.95	0.31	5.12	
6/19/2019	102.5	0.36	5.48	6.21	0.31	5.35	
6/20/2019	103.5	0.30	5.74	5.04	0.28	4.70	
6/21/2019	105.7	0.36	5.67	6.43	0.29	5.18	
6/22/2019	99.3		5.26				
6/23/2019	99.3		5.26				
6/24/2019	99.3	0.30	5.26	4.37	0.24	3.49	<1.30
6/25/2019	100.2	0.30	5.48	5.35	0.28	5.00	
6/26/2019	102.5	0.43	5.52	7.50	0.27	4.71	
6/27/2019	104.9	0.30	4.53	4.70	0.31	4.86	
6/28/2019	145.1	0.30	4.36	4.36	0.34	4.94	
6/29/2019	179.2						
6/30/2019	179.2						

Set: 3 of 4

Parameter	Total Copper	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)
Mon. Loc.	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)	Final Effluent (1)
Limit	(report) ug/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
6/1/2019		*G	*G	*G	*G	*G	*G
6/2/2019							
6/3/2019							
6/4/2019	<50.000						
6/5/2019							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2019 07 18 YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 6/1/2019 - 6/30/2019
DMR Version: 1

6/6/2019							
6/7/2019							
6/8/2019	<50.000						
6/9/2019							
6/10/2019							
6/11/2019							
6/12/2019							
6/13/2019	<50.000						
6/14/2019							
6/15/2019							
6/16/2019							
6/17/2019							
6/18/2019							
6/19/2019	<50.000						
6/20/2019							
6/21/2019							
6/22/2019							
6/23/2019							
6/24/2019							
6/25/2019							
6/26/2019							
6/27/2019							
6/28/2019							
6/29/2019							
6/30/2019							

Set: 4 of 4

Parameter	Fecal Coliform	Fecal Coliform	pH	pH	Dissolved Oxygen		
Mon. Loc.	Final Effluent (1)	Fecal Daily (report) #/100mL	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)		
Limit	400 #/100mL		6.5 SU	9.0 SU	6.0 mg/L		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2019 07 18 YEAR MO DAY
--	---	--	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 6/1/2019 - 6/30/2019
DMR Version: 1

Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily	Maximum Daily	Minimum Daily		
6/1/2019	2.6						
6/2/2019	2.6						
6/3/2019	2.6	1	7.2	7.2	8.6		
6/4/2019	2.6	1	7.3	7.3	8.3		
6/5/2019	3.0	5.2	7.25	7.3	7.8		
6/6/2019	3.2	7.5	7.34	7.3	7.7		
6/7/2019	5.4	3.1	7.35	7.4	7.7		
6/8/2019	12.5						
6/9/2019	12.5						
6/10/2019	12.5	1	7.23	7.2	8.2		
6/11/2019	18.6	2	7.12	7.1	8.2		
6/12/2019	24.0	7.4	7.3	7.3	8.0		
6/13/2019	27.5	98.5	7.35	7.4	7.8		
6/14/2019	18.9	211	7.52	7.5	6.9		
6/15/2019	9.0						
6/16/2019	9.0						
6/17/2019	9.0	7.3	7.37	7.4	8.3		
6/18/2019	6.1	7.1	7.52	7.5	7.8		
6/19/2019	5.1	14.6	7.21	7.2	7.7		
6/20/2019	4.9	15.1	7.44	7.4	7.6		
6/21/2019	5.0	5.2	7.3	7.3	7.8		
6/22/2019	3.6						
6/23/2019	3.6						
6/24/2019	3.6	1	7.28	7.3	8.1		
6/25/2019	4.9	3.1	7.42	7.4	8.1		
6/26/2019		12	7.33	7.3	7.9		
6/27/2019		15.45	7.52	7.5	8.0		
6/28/2019		1	6.91	6.9	8.0		
6/29/2019							
6/30/2019							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2019	07	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 6/1/2019 - 6/30/2019
DMR Version: 1

DMR Instructions:

DMR Comments: (none)

- **Set 1 DMR Value Comments:** **Set 2 DMR Value Comments:**
- Date: 6/14/2019 12:00:00 AM, Column 2 Comment: Seasonal tank cleaning
- Date: 6/14/2019 12:00:00 AM, Column 6 Comment: Seasonal Tank Cleaning

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC	TELEPHONE		DATE		
			2317750181 124		2019	07	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY