

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2016 - 8/31/2016
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	30 mg/L	800 lbs/day	(report) mg/L	(report) lbs/day	10 mg/L	270 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
8/1/2016	1.88	5.20	81.51	4.32	77.58	6.50	101.9
8/2/2016	2.21	2.80	51.66	4.16	74.51	4.25	78.4
8/3/2016	2.19	6.00	109.77	4.56	81.44	3.70	67.7
8/4/2016	2.21	3.20	58.86	4.40	78.59	7.20	132.4
8/5/2016	2.35	4.40	86.11	4.80	86.35	5.30	103.7
8/6/2016	2.11			4.40	78.66		
8/7/2016	1.77			4.40	78.66		
8/8/2016	1.80	4.40	66.15	4.40	78.66	5.75	86.4
8/9/2016	2.16	4.80	86.30	4.48	80.61	4.30	77.3
8/10/2016	2.20	5.20	95.52	4.24	76.81	5.50	101.0
8/11/2016	2.25	5.20	97.69	3.68	67.51	5.90	110.8
8/12/2016	2.38	2.40	47.63	3.60	66.74	5.80	115.1
8/13/2016	2.73			3.76	67.52		
8/14/2016	1.97			3.76	67.52		
8/15/2016	1.90	4.80	75.92	3.76	67.52	3.80	60.1
8/16/2016	2.24	3.60	67.29	4.08	71.83	3.90	72.9
8/17/2016	2.45	2.40	49.01	4.16	72.78	4.30	87.8
8/18/2016	2.35	4.80	93.87	4.56	78.64	4.70	91.9
8/19/2016	1.93	3.20	51.50	3.92	65.63	4.10	66.0
8/20/2016	2.11			3.84	65.40		
8/21/2016	2.00			3.84	65.40		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC	TELEPHONE	DATE		
			2317750181 124	2016	09	16
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2016 - 8/31/2016
DMR Version: 1

8/22/2016	1.83	6.40	97.50	3.84	65.40	5.00	76.2
8/23/2016	2.16	4.00	72.01	3.20	56.00	3.35	60.3
8/24/2016	2.13	4.40	78.30	3.04	52.86	2.50	44.5
8/25/2016	2.16	1.60	28.84	2.64	46.26	2.80	50.5
8/26/2016	2.16	2.80	50.36	2.90	50.61	3.20	57.6
8/27/2016	2.00			3.20	53.41		
8/28/2016	1.84			3.20	53.41		
8/29/2016	1.89	3.20	50.48	3.20	53.41	2.80	44.2
8/30/2016	2.11	3.20	56.34	2.80	50.81	2.20	38.7
8/31/2016	2.26	2.40	45.28			3.00	56.60

Set: 2 of 4

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	2 mg/L	53 lbs/day	(report) mg/L	(report) lbs/day	(report) ug/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
8/1/2016	96.8	0.03	0.47	0.22	3.45	<2.00	
8/2/2016	93.7	0.05	0.92	0.24	4.43		
8/3/2016	93.5	0.17	3.11	0.23	4.21		<50.000
8/4/2016	100.2	0.47	8.65	0.29	5.33		
8/5/2016	95.9	0.35	6.85	0.19	3.72		
8/6/2016	98.1						
8/7/2016	98.1						
8/8/2016	98.1	0.03	0.45	0.22	3.31		
8/9/2016	92.9	0.05	0.90	0.22	3.96		
8/10/2016	92.0	0.07	1.29	0.25	4.59		<50.000
8/11/2016	89.3	0.05	0.94	0.24	4.51		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 	DATE 2016 09 16 YEAR MO DAY
--	---	--	--	----------------------------	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2016 - 8/31/2016
DMR Version: 1

8/12/2016	85.6	0.23	4.56	0.21	4.17		
8/13/2016	75.7						<50.000
8/14/2016	75.7						
8/15/2016	75.7	0.04	0.63	0.18	2.85		
8/16/2016	79.0	0.09	1.68	0.20	3.74		
8/17/2016	76.4	1.32	26.95	0.25	5.11		
8/18/2016	67.8	0.55	10.76	0.21	4.11		<50.000
8/19/2016	59.5	0.08	1.29	0.22	3.54		
8/20/2016	57.8						
8/21/2016	57.8						
8/22/2016	57.8	0.03	0.46	0.25	3.81		
8/23/2016	51.4	0.06	1.08	0.20	3.60		
8/24/2016	47.1	0.05	0.89	0.21	3.74		
8/25/2016	49.5	0.03	0.54	0.20	3.61		
8/26/2016	49.3	0.04	0.72	0.18	3.24		
8/27/2016	54.2						
8/28/2016	69.9						
8/29/2016	69.9	0.03	0.47	0.25	3.94		
8/30/2016	76.3	0.03	0.53	0.24	4.23		
8/31/2016		0.06	1.13	0.24	4.53		

Set: 3 of 4

Parameter	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)
Mon. Loc.	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)	Final Effluent (1)
Limit	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
8/1/2016							
8/2/2016	<0.500	<0.2	<0.5	<0.2	<0.2		
8/3/2016							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2016 09 16 YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2016 - 8/31/2016
DMR Version: 1

8/4/2016						0	0
8/5/2016							
8/6/2016							
8/7/2016							
8/8/2016							
8/9/2016							
8/10/2016							
8/11/2016							
8/12/2016							
8/13/2016							
8/14/2016							
8/15/2016							
8/16/2016							
8/17/2016							
8/18/2016							
8/19/2016							
8/20/2016							
8/21/2016							
8/22/2016							
8/23/2016							
8/24/2016							
8/25/2016							
8/26/2016							
8/27/2016							
8/28/2016							
8/29/2016							
8/30/2016							
8/31/2016							

Set: 4 of 4

Parameter	Fecal Coliform	Fecal Coliform	pH	pH	Dissolved Oxygen		
-----------	----------------	----------------	----	----	------------------	--	--

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER NUMBER	DATE 2016 09 16 YEAR MO DAY
--	---	--	--	------------------------------	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2016 - 8/31/2016
DMR Version: 1

Mon. Loc.	Final Effluent (1)	Fecal Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)		
Limit	400 #/100mL	(report) #/100mL	6.5 SU	9.0 SU	6.0 mg/L		
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily	Maximum Daily	Minimum Daily		
8/1/2016	0.0	68	7.22	7.2	8.0		
8/2/2016	6.6	13	7.36	7.4	7.8		
8/3/2016	8.7	8	7.49	7.5	7.6		
8/4/2016	12.8	6	7.32	7.3	7.3		
8/5/2016	17.8	5	7.29	7.3	7.3		
8/6/2016	27.3						
8/7/2016	27.3						
8/8/2016	27.3	4	7.24	7.2	8.1		
8/9/2016	51.1	51	7.23	7.2	7.9		
8/10/2016	64.0	57	7.41	7.4	7.7		
8/11/2016	108.8	31	7.46	7.5	7.6		
8/12/2016	97.6	42	7.46	7.5	7.6		
8/13/2016	94.6						
8/14/2016	94.6						
8/15/2016	94.6	92	7.4	7.4	8.0		
8/16/2016	61.9	157	7.39	7.4	7.9		
8/17/2016	55.4	810	6.95	7.0	6.9		
8/18/2016	71.9	18	7.4	7.4	7.9		
8/19/2016	61.2	36	7.49	7.5	7.9		
8/20/2016	42.7						
8/21/2016	42.7						
8/22/2016	42.7	11	7.38	7.4	8.1		
8/23/2016	33.0	90	7.42	7.4	8.1		
8/24/2016	15.4	3000	7.45	7.5	7.9		
8/25/2016	4.6	8	7.35	7.4	7.9		
8/26/2016		6	7.52	7.5	7.9		
8/27/2016							
8/28/2016							
8/29/2016		3	7.32	7.3	8.2		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2016 09 16
--	---	---	---	---------------------------------	------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2016 - 8/31/2016
DMR Version: 1

8/30/2016		2	7.27	7.3	8.1		
8/31/2016		7	7.5	7.5	8.0		

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124		2016	09	16
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY