

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2019 - 11/30/2019
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	45 mg/L	1200 lbs/day	(report) mg/L	(report) lbs/day	17 mg/L	480 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
11/1/2019	1.97	8.50	139.68	7.86	125.57	23.10	379.6
11/2/2019	1.81			7.68	121.91		
11/3/2019	1.62			7.68	121.91		
11/4/2019	1.74	12.00	174.18	7.68	121.91	23.70	344.0
11/5/2019	2.12	7.00	123.76	7.08	111.64	8.80	155.6
11/6/2019	1.94	6.00	96.85	7.20	111.08	7.10	114.6
11/7/2019	1.93	5.80	93.41	7.92	121.80	8.67	139.6
11/8/2019	1.92	7.60	121.36	9.00	138.59	13.30	212.4
11/9/2019	1.79			9.00	137.40		
11/10/2019	1.51			9.00	137.40		
11/11/2019	1.64	9.00	122.82	9.00	137.40	6.40	87.3
11/12/2019	1.91	7.60	120.98	9.46	141.14	4.60	73.2
11/13/2019	1.88	9.60	150.43	9.30	136.75	7.80	122.2
11/14/2019	1.90	11.20	177.36	8.42	122.11	6.20	98.2
11/15/2019	1.82	7.60	115.42	7.66	108.40	3.63	55.1
11/16/2019	1.57			7.50	106.99		
11/17/2019	1.35			7.50	106.99		
11/18/2019	1.50	11.30	141.53	7.50	106.99	8.25	103.3
11/19/2019	1.75	6.80	98.99	6.84	99.12	3.75	54.6
11/20/2019	1.78	5.20	77.24	6.44	93.24	4.40	65.4
11/21/2019	1.76	7.40	108.84	6.20	90.35	5.40	79.4

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2019	12	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2019 - 11/30/2019
DMR Version: 1

11/22/2019	1.91	6.80	108.34	5.60	81.40	6.95	110.7
11/23/2019	1.63			5.04	69.03		
11/24/2019	1.40			5.04	69.03		
11/25/2019	1.53	8.00	102.18	5.04	69.03	7.83	100.0
11/26/2019	1.74	4.80	69.60	4.30	60.74	6.00	87.0
11/27/2019	1.88	4.00	62.80	4.13	57.79	6.30	98.9
11/28/2019	1.75	4.40	64.05	4.20	55.28	6.50	94.6
11/29/2019	1.39	4.00	46.50	4.00	46.50	5.20	60.5
11/30/2019	1.39						

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	2.8 mg/L	(report) lbs/day	(report) mg/L	(report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2019	226.7	0.30	4.93	0.20	3.29		
11/2/2019	193.2						
11/3/2019	193.2						
11/4/2019	193.2	0.30	4.36	0.18	2.61		
11/5/2019	141.9	0.55	9.72	0.17	3.01		
11/6/2019	125.4	0.30	4.84	0.14	2.26	10.2	0.165
11/7/2019	127.0	0.30	4.83	0.13	2.09		
11/8/2019	118.7	2.31	36.89	0.14	2.24		
11/9/2019	87.2					<10.000	<0.149
11/10/2019	87.2						
11/11/2019	87.2	0.30	4.09	0.22	3.00		
11/12/2019	90.4	0.53	8.44	0.19	3.03		
11/13/2019	86.7	0.30	4.70	0.20	3.13		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2019 12 18 YEAR MO DAY
--	---	--	--	---

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 3/24/2021 2:04 AM

Page 2 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2019 - 11/30/2019
DMR Version: 1

11/14/2019	75.3	0.30	4.75	0.21	3.33	<10.000	<0.158
11/15/2019	71.6	0.30	4.56	0.21	3.19		
11/16/2019	82.7						
11/17/2019	82.7						
11/18/2019	82.7	0.30	3.76	0.24	3.01		
11/19/2019	82.0	0.30	4.37	0.14	2.04		
11/20/2019	88.5	0.30	4.46	0.21	3.12		
11/21/2019	95.2	0.30	4.41	0.20	2.94		
11/22/2019	98.3	0.30	4.78	0.21	3.35	<10.000	<0.159
11/23/2019	88.2						
11/24/2019	88.2						
11/25/2019	88.2	0.30	3.83	0.25	3.19		
11/26/2019	85.2	0.30	4.35	0.20	2.90	<10.000	<0.145
11/27/2019	94.9	0.30	4.71	0.16	2.51		
11/28/2019	165.1	0.30	4.37	0.13	1.89		
11/29/2019	188.5	0.30	3.49	0.13	1.51		
11/30/2019	252.6						

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)
Limit	(report) ng/L	(report) lbs/day	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2019	*G	*G	*G	*G	*G	*G	
11/2/2019							
11/3/2019							
11/4/2019							
11/5/2019							
11/6/2019							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 124 NUMBER	DATE 2019 12 18 YEAR MO DAY
--	---	---	---	---------------------------------	---

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 3/24/2021 2:04 AM

Page 3 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2019 - 11/30/2019
DMR Version: 1

11/7/2019							
11/8/2019							
11/9/2019							<5.000
11/10/2019							
11/11/2019							
11/12/2019							
11/13/2019							
11/14/2019							<5.000
11/15/2019							
11/16/2019							
11/17/2019							
11/18/2019							
11/19/2019							
11/20/2019							
11/21/2019							
11/22/2019							
11/23/2019							
11/24/2019							
11/25/2019							
11/26/2019							
11/27/2019							
11/28/2019							
11/29/2019							
11/30/2019							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) ug/L	(report) lbs/day	(report) ng/L	(report) lbs/day	(report) ng/L	(report) lbs/day

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2019	12	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2019 - 11/30/2019
DMR Version: 1

Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2019				*G	*G	*G	*G
11/2/2019							
11/3/2019							
11/4/2019							
11/5/2019							
11/6/2019		<2.000	<0.032				
11/7/2019							
11/8/2019							
11/9/2019	<0.074	<2.000	<0.029				
11/10/2019							
11/11/2019							
11/12/2019							
11/13/2019							
11/14/2019	<0.079	<2.000	<0.031				
11/15/2019							
11/16/2019							
11/17/2019							
11/18/2019							
11/19/2019							
11/20/2019							
11/21/2019							
11/22/2019							
11/23/2019							
11/24/2019							
11/25/2019							
11/26/2019							
11/27/2019							
11/28/2019							
11/29/2019							
11/30/2019							

Set: 5 of 6

--	--	--	--	--	--	--	--

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
TYPED OR PRINTED			2317750181 124	2019	12	18
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2019 - 11/30/2019
DMR Version: 1

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis(2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily (report) #/100mL	Percent Removal (K) (report) %	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL			6.5 SU	9.0 SU	6.0 mg/L	(report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
11/1/2019	1.1	1	96.458	7.17	7.2	8.2	*C
11/2/2019	1.1						
11/3/2019	1.1						
11/4/2019	1.1	1	86.667	6.99	7.0	8.9	
11/5/2019	1.1	2	92.708	6.94	6.9	8.7	
11/6/2019	1.0	1	92.105	7	7.0	8.8	
11/7/2019	1.0	1	94.2	7.13	7.1	8.6	
11/8/2019	1.1	1	87.333	7.36	7.4	8.1	
11/9/2019	1.2						
11/10/2019	1.2						
11/11/2019	1.2	1	95.909	6.93	6.9	9.1	
11/12/2019	1.7	1	94.865	7.02	7.0	9.0	
11/13/2019	1.7	1	91.111	6.94	6.9	9.0	
11/14/2019	1.7	1.5	90.968	7.03	7.0	9.0	
11/15/2019	1.7	2	94.412	6.83	6.8	8.8	
11/16/2019	1.7						
11/17/2019	1.7						
11/18/2019	1.7	5	95.212	6.88	6.9	9.2	
11/19/2019	1.4	1	96.136	6.96	7.0	9.1	
11/20/2019	1.4	1	97.174	7.05	7.1	8.9	
11/21/2019	1.4	1.5	94.032	7.47	7.5	8.9	
11/22/2019	1.3	2	96.222	7.14	7.1	8.9	
11/23/2019	1.1						
11/24/2019	1.1						
11/25/2019	1.1	2	95	7.04	7.0	9.2	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2019 12 18 YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2019 - 11/30/2019
DMR Version: 1

11/26/2019		1	97.551	7.09	7.1	9.1	
11/27/2019		1	96.97	7.06	7.1	8.9	
11/28/2019		1	96.563	7.16	7.2	9.1	
11/29/2019		1	97.143	7.16	7.2	9.5	
11/30/2019							

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl)Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(report) lbs/day						
Stat. Base	Maximum Daily						
11/1/2019	*C						
11/2/2019							
11/3/2019							
11/4/2019							
11/5/2019							
11/6/2019							
11/7/2019							
11/8/2019							
11/9/2019							
11/10/2019							
11/11/2019							
11/12/2019							
11/13/2019							
11/14/2019							
11/15/2019							
11/16/2019							
11/17/2019							
11/18/2019							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER 	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE 2317750181 124	DATE 2019 12 18		
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2019 - 11/30/2019
DMR Version: 1

11/19/2019							
11/20/2019							
11/21/2019							
11/22/2019							
11/23/2019							
11/24/2019							
11/25/2019							
11/26/2019							
11/27/2019							
11/28/2019							
11/29/2019							
11/30/2019							

DMR Instructions:

DMR Comments: (none)

Set 1 DMR Value Comments: Set 5 DMR Value Comments: Set 6 DMR Value Comments:

- Date: 11/1/2019 12:00:00 AM,Column 1 Comment: Missed sample additional sample taken in December
- Date: 11/1/2019 12:00:00 AM,Column 6 Comment: Lab Error
- Date: 11/4/2019 12:00:00 AM,Column 6 Comment: Lab Error
- Date: 11/1/2019 12:00:00 AM,Column 7 Comment: Missed sample additional sample taken in December

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124	2019	12	18	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY