

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2020 - 11/30/2020
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	45 mg/L	1200 lbs/day	(report) mg/L	(report) lbs/day	17 mg/L	480 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
11/1/2020	1.45			7.60	107.80		
11/2/2020	1.49	8.50	105.88	7.60	107.80	4.08	50.8
11/3/2020	1.81	6.00	90.57	7.90	115.00	4.05	61.1
11/4/2020	1.73	6.50	93.87	8.80	129.46	5.55	80.1
11/5/2020	1.78	8.00	118.77	8.60	127.48	7.40	109.9
11/6/2020	1.73	9.00	129.89	9.25	134.80	11.40	164.5
11/7/2020	1.71			9.55	139.12		
11/8/2020	1.61			9.55	139.12		
11/9/2020	1.70	10.00	141.91	9.55	139.12	8.60	122.0
11/10/2020	1.86	10.50	162.89	8.95	128.88	6.10	94.6
11/11/2020	1.83	5.50	83.95	8.25	116.44	8.30	126.7
11/12/2020	1.66	11.25	155.37	8.15	113.91	9.75	134.7
11/13/2020	1.73	10.50	151.48	7.60	106.65	9.70	139.9
11/14/2020	1.61			7.50	104.66		
11/15/2020	1.47			7.50	104.66		
11/16/2020	1.55	7.00	90.72	7.50	104.66	5.10	66.1
11/17/2020	1.73	7.00	100.70	7.62	105.04	5.40	77.7
11/18/2020	1.71	5.00	71.30	7.72	104.79	6.50	92.7
11/19/2020	1.68	8.50	119.05	7.82	105.09	7.70	107.8
11/20/2020	1.70	10.00	141.55	7.02	93.22	10.90	154.3
11/21/2020	1.54			6.32	78.83		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC	TELEPHONE	DATE		
			2317750181 124	2020	12	09
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2020 - 11/30/2020
DMR Version: 1

11/22/2020	1.40			6.32	78.83		
11/23/2020	1.46	7.60	92.59	6.32	78.83	9.30	113.3
11/24/2020	1.59	7.50	99.44	6.40	79.69	6.90	91.5
11/25/2020	1.59	5.50	72.84	6.13	74.76	9.30	123.2
11/26/2020	1.59	4.50	59.66	6.33	75.40	10.40	137.9
11/27/2020	1.28	6.50	69.60	7.25	83.26	8.90	95.3
11/28/2020	1.29			8.00	96.92		
11/29/2020	1.31			8.00	96.92		
11/30/2020	1.45	8.00	96.92	8.00	96.92	5.80	70.3

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	2.8 mg/L	(report) lbs/day	(report) mg/L	(report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2020	93.3						
11/2/2020	93.3	0.30	3.74	0.35	4.36		
11/3/2020	107.5	0.30	4.53	0.31	4.68		
11/4/2020	114.2	0.30	4.33	0.29	4.19	<5.000	<0.072
11/5/2020	123.5	0.30	4.45	0.29	4.31		
11/6/2020	128.5	0.30	4.33	0.27	3.90		
11/7/2020	123.6						
11/8/2020	123.6						
11/9/2020	123.6	0.30	4.26	3.51	4.26		
11/10/2020	112.4	0.33	5.12	0.33	5.12		
11/11/2020	109.0	0.16	2.44	0.33	5.04		
11/12/2020	102.2	0.42	5.80	0.30	4.14		
11/13/2020	96.8	0.33	4.76	0.33	4.76	<5.000	<0.072

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2020 12 09 YEAR MO DAY
--	---	---	--	---

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 3/23/2021 6:58 AM

Page 2 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2020 - 11/30/2020
DMR Version: 1

11/14/2020	99.7						
11/15/2020	99.7						
11/16/2020	99.7	0.30	3.89	0.33	4.28		
11/17/2020	109.2	0.51	7.34	0.26	3.74		
11/18/2020	111.9	0.30	4.28	0.19	2.71		
11/19/2020	118.0	0.30	4.20	0.20	2.80	<5.000	<0.070
11/20/2020	124.0	0.30	4.25	0.19	2.69		
11/21/2020	112.2					<5.000	<0.064
11/22/2020	112.2						
11/23/2020	112.2	0.30	3.66	0.20	2.44	5.3	0.065
11/24/2020	103.6	0.30	3.98	0.18	2.39		
11/25/2020	106.7	0.30	3.97	0.17	2.25		
11/26/2020	101.2	0.30	3.98	0.16	2.12		
11/27/2020	90.3	0.30	3.21	0.15	1.61		
11/28/2020	113.4						
11/29/2020	113.4						
11/30/2020	113.4	0.30	3.63	0.26	3.15		

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)
Limit	(report) ng/L	(report) lbs/day	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2020							
11/2/2020							
11/3/2020							
11/4/2020							<5.000
11/5/2020							
11/6/2020							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2020 12 09
--	---	---	---	---------------------------------	------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2020 - 11/30/2020
DMR Version: 1

11/7/2020							
11/8/2020							
11/9/2020	0.59	0.00000837	0.59	0.71	<0.20	<0.20	
11/10/2020							
11/11/2020							
11/12/2020							
11/13/2020							<5.000
11/14/2020							
11/15/2020							
11/16/2020							
11/17/2020							
11/18/2020							
11/19/2020							<5.000
11/20/2020							
11/21/2020							<5.000
11/22/2020							
11/23/2020							<5.000
11/24/2020							
11/25/2020							
11/26/2020							
11/27/2020							
11/28/2020							
11/29/2020							
11/30/2020							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) ug/L	(report) lbs/day	(report) ng/L	(report) lbs/day	(report) ng/L	(report) lbs/day

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 124 NUMBER	DATE 2020 12 09 YEAR MO DAY
--	---	--	--	---------------------------------	---

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 3/23/2021 6:58 AM

Page 4 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2020 - 11/30/2020
DMR Version: 1

Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2020				*G	*G	*G	*G
11/2/2020							
11/3/2020							
11/4/2020	<0.072	<2.000	<0.029				
11/5/2020							
11/6/2020							
11/7/2020							
11/8/2020							
11/9/2020							
11/10/2020							
11/11/2020							
11/12/2020							
11/13/2020	<0.072	<2.000	<0.029				
11/14/2020							
11/15/2020							
11/16/2020							
11/17/2020							
11/18/2020							
11/19/2020	<0.070	<2.000	<0.028				
11/20/2020							
11/21/2020	<0.064	<2.000	<0.026				
11/22/2020							
11/23/2020	<0.061	<2.000	<0.024				
11/24/2020							
11/25/2020							
11/26/2020							
11/27/2020							
11/28/2020							
11/29/2020							
11/30/2020							

Set: 5 of 6

--	--	--	--	--	--	--	--

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2020	12	09
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2020 - 11/30/2020
DMR Version: 1

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis(2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily (report) #/100mL	Percent Removal (K) (report) %	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL			6.5 SU	9.0 SU	6.0 mg/L	(report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
11/1/2020	1.1						
11/2/2020	1.1	1	95.75	7.1	7.1	9.4	
11/3/2020	1.3	2	97.619	7.15	7.2	9.2	
11/4/2020	1.1	1	96.875	7.43	7.4	8.9	
11/5/2020	1.1	1	97.183	7.39	7.4	8.8	
11/6/2020	1.1	1	96.591	7.3	7.3	8.6	
11/7/2020	1.3						
11/8/2020	1.3						
11/9/2020	1.3	2	95.69	7.43	7.4	8.8	<4.400
11/10/2020	1.1	1	95.047	7.43	7.4	8.5	
11/11/2020	1.8	1	95.259	6.92	6.9	8.3	
11/12/2020	1.8	1	94.016	7.28	7.3	8.7	
11/13/2020	1.8	2	94.034	7.12	7.1	8.6	
11/14/2020	1.5						
11/15/2020	1.5						
11/16/2020	1.5	1	97.426	6.85	6.9	9.2	
11/17/2020	1.5	8.6	92.391	7.11	7.1	9.3	
11/18/2020	1.0	1	96.795	7.15	7.2	9.4	
11/19/2020	1.0	1	88.816	7.11	7.1	9.1	
11/20/2020	1.0	1	94.048	7.33	7.3	9.0	
11/21/2020	1.0						
11/22/2020	1.0						
11/23/2020	1.0	1	96.607	7.17	7.2	9.1	
11/24/2020	1.0	1	95.833	7.28	7.3	9.1	
11/25/2020	1.0	1	97.194	7.18	7.2	9.0	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2020	12	09
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2020 - 11/30/2020
DMR Version: 1

11/26/2020		1	97.554	7.1	7.1	8.7	
11/27/2020		1	97.045	7.03	7.0	8.9	
11/28/2020							
11/29/2020							
11/30/2020		1	95.745	6.91	6.9	9.6	

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl)Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(report) lbs/day						
Stat. Base	Maximum Daily						
11/1/2020							
11/2/2020							
11/3/2020							
11/4/2020							
11/5/2020							
11/6/2020							
11/7/2020							
11/8/2020							
11/9/2020	<0.0624390						
11/10/2020							
11/11/2020							
11/12/2020							
11/13/2020							
11/14/2020							
11/15/2020							
11/16/2020							
11/17/2020							
11/18/2020							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2020 12 09
--	---	---	---	---------------------------------	------------------------

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 3/23/2021 6:58 AM

Page 7 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2020 - 11/30/2020
DMR Version: 1

11/19/2020							
11/20/2020							
11/21/2020							
11/22/2020							
11/23/2020							
11/24/2020							
11/25/2020							
11/26/2020							
11/27/2020							
11/28/2020							
11/29/2020							
11/30/2020							

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2020	12	09
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY