

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(Report) MGD	30 mg/L	800 lbs/day	(Report) mg/L	(Report) lbs/day	10 mg/L	270 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
8/1/2021	1.84			7.44	123.06		
8/2/2021	1.77	4.80	70.96	7.44	123.06	3.00	44.4
8/3/2021	2.21	2.80	51.61	7.60	125.75	4.20	77.4
8/4/2021	2.22	8.40	155.53	9.04	161.28	6.10	112.9
8/5/2021	1.73	10.40	150.32	9.26	175.33	6.30	91.1
8/6/2021	2.08	10.80	186.88	8.98	180.63	4.90	84.8
8/7/2021	1.88			8.52	175.80		
8/8/2021	1.70			8.52	175.80		
8/9/2021	1.81	5.60	84.39	8.52	175.80	3.00	45.2
8/10/2021	2.75	10.00	229.26	8.50	176.61	3.60	82.5
8/11/2021	2.85	9.50	225.79	8.02	158.59	5.40	128.3
8/12/2021	2.36	9.00	176.86	7.80	142.84	9.30	182.8
8/13/2021	2.30	8.50	162.73	7.76	137.05	8.10	155.1
8/14/2021	2.09			7.34	125.73		
8/15/2021	1.82			7.34	125.73		
8/16/2021	1.93	5.50	88.41	7.34	125.73	3.15	50.6
8/17/2021	2.20	7.60	139.17	7.12	120.77	6.05	110.8
8/18/2021	2.10	8.40	147.02	6.80	113.42	6.20	108.5
8/19/2021	2.02	8.80	147.93	6.80	113.04	9.00	151.3
8/20/2021	1.99	6.40	106.11	6.08	100.81	6.30	104.4
8/21/2021	1.90			6.08	101.56		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

8/22/2021	1.80			6.08	101.56		
8/23/2021	1.73	4.40	63.60	6.08	101.56	4.25	61.4
8/24/2021	2.05	6.00	102.44	5.84	99.55	4.55	77.7
8/25/2021	2.07	8.40	145.10	5.20	89.72	4.70	81.2
8/26/2021	2.00	5.20	86.79	4.40	75.87	8.30	138.5
8/27/2021	2.06	6.40	109.90	4.80	81.71	10.50	180.3
8/28/2021	2.16			3.20	53.53		
8/29/2021	2.04			3.20	53.53		
8/30/2021	2.01	3.20	53.53	3.00	53.41	3.00	50.2
8/31/2021	2.28	2.80	53.28			3.75	71.36

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	2.0 mg/L	53 lbs/day	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	31 ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
8/1/2021	82.1		5.01				
8/2/2021	82.1	0.30	5.01	4.44	0.20	2.96	
8/3/2021	82.3	0.30	5.03	5.53	0.18	3.32	21.2
8/4/2021	83.3	0.30	5.30	5.56	0.21	3.89	
8/5/2021	86.4	0.30	5.61	4.34	0.24	3.47	
8/6/2021	104.7	0.30	5.92	5.19	0.28	4.85	
8/7/2021	118.8		6.03				
8/8/2021	118.8		6.03				
8/9/2021	118.8	0.30	6.03	4.52	0.52	7.84	
8/10/2021	119.9	0.30	6.09	6.88	0.61	13.99	
8/11/2021	125.5	0.30	5.82	7.13	0.50	11.88	20.4

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE
--	---	---	---	---------------------------------	----------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

8/12/2021	121.6	0.30	5.44	5.90	0.41	8.06	
8/13/2021	115.3	0.30	5.27	5.74	0.33	6.32	
8/14/2021	105.1		5.12				
8/15/2021	105.1		5.12				
8/16/2021	105.1	0.30	5.12	4.82	0.41	6.59	
8/17/2021	107.3	0.30	5.02	5.49	0.41	7.51	
8/18/2021	100.7	0.30	4.95	5.25	0.38	6.65	
8/19/2021	95.2	0.30	4.93	5.04	0.34	5.72	20.5
8/20/2021	92.7	0.30	4.92	4.97	0.37	6.13	
8/21/2021	107.8		4.96				
8/22/2021	107.8		4.96				
8/23/2021	107.8	0.30	4.96	4.34	0.27	3.90	19.6
8/24/2021	105.6	0.30	5.10	5.12	0.31	5.29	
8/25/2021	104.3	0.30	5.21	5.18	0.23	3.97	
8/26/2021	110.1	0.30	5.22	5.01	0.22	3.67	
8/27/2021	100.4	0.30	5.29	5.15	0.20	3.43	
8/28/2021	101.0		5.36				
8/29/2021	101.0		5.36				18.2
8/30/2021	101.0	0.30		5.02	0.24	4.02	
8/31/2021		0.30		5.71	0.20	3.81	

Set: 3 of 6

Parameter	Total Copper	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent
Limit	0.82 lbs/day	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
8/1/2021		*G	*G	*G	*G	*G	*G
8/2/2021							
8/3/2021	0.391						

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY
--	---	---	---	---------------------------------

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 9/16/2021 2:22 PM

Page 3 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

8/4/2021							
8/5/2021							
8/6/2021							
8/7/2021							
8/8/2021							
8/9/2021							
8/10/2021							
8/11/2021	0.485						
8/12/2021							
8/13/2021							
8/14/2021							
8/15/2021							
8/16/2021							
8/17/2021							
8/18/2021							
8/19/2021	0.345						
8/20/2021							
8/21/2021							
8/22/2021							
8/23/2021	0.283						
8/24/2021							
8/25/2021							
8/26/2021							
8/27/2021							
8/28/2021							
8/29/2021	0.309						
8/30/2021							
8/31/2021							

Set: 4 of 6

Parameter	Total Nickel	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)
-----------	--------------	--------------	----------------	----------------	----------------------------------	----------------------------------	-------------------------------

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) ug/L	(Report) lbs/day	(Report) ug/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day	(Report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
8/1/2021					*G	*G	*G
8/2/2021							
8/3/2021	<5.000	<0.092	<2.000	<0.037			
8/4/2021							
8/5/2021							
8/6/2021							
8/7/2021							
8/8/2021							
8/9/2021							
8/10/2021							
8/11/2021	<5.000	<0.119	<2.000	<0.048			
8/12/2021							
8/13/2021							
8/14/2021							
8/15/2021							
8/16/2021							
8/17/2021							
8/18/2021							
8/19/2021	<5.000	<0.084	<2.000	<0.034			
8/20/2021							
8/21/2021							
8/22/2021							
8/23/2021	<5.000	<0.072	<2.000	<0.029			
8/24/2021							
8/25/2021							
8/26/2021							
8/27/2021							
8/28/2021							
8/29/2021	<5.000	<0.085	<2.000	<0.034			

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE
--	---	---	---	---------------------------------	--------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

8/30/2021							
8/31/2021							

Set: 5 of 6

Parameter	Perfluorooctanoic Acid (PFOA)	Fecal Coliform	Fecal Coliform	pH	pH	Dissolved Oxygen	Bis(2-Ethylhexyl)Phtalate
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Fecal Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	400 #/100mL	(Report) #/100mL	6.5 SU	9.0 SU	6.0 mg/L	(Report) ug/L
Stat. Base	Maximum Daily	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
8/1/2021	*G	3.7					
8/2/2021		3.7	3.1	7.3	7.3	8.1	
8/3/2021		3.4	5.2	7.42	7.4	8.3	
8/4/2021		3.9	5.2	7.46	7.5	7.4	
8/5/2021		4.4	8.4	7.37	7.4	7.7	
8/6/2021		4.6	1	7.4	7.4	7.5	
8/7/2021		6.7					
8/8/2021		6.7					
8/9/2021		6.7	2	7.25	7.3	7.8	
8/10/2021		9.9	9.8	7.06	7.1	7.8	<4.400
8/11/2021		8.7	9.8	7.2	7.2	7.9	
8/12/2021		9.5	10.8	7.23	7.2	7.6	
8/13/2021		9.3	6.3	7.35	7.4	7.7	
8/14/2021		11.4					
8/15/2021		11.4					
8/16/2021		11.4	14.6	6.64	6.6	8.4	
8/17/2021		6.7	5.2	7.42	7.4	8.0	
8/18/2021		6.0	14.6	7.28	7.3	7.6	
8/19/2021		4.1	9.8	7.29	7.3	7.5	
8/20/2021		3.2	18	7.36	7.4	7.5	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

8/21/2021		1.8					
8/22/2021		1.8					
8/23/2021		1.8	1	7.26	7.3	7.7	
8/24/2021		1.8	3.1	7.28	7.3	7.7	
8/25/2021		1.4	2	7.38	7.4	7.4	
8/26/2021			3.1	7.16	7.2	7.4	
8/27/2021			1	7.17	7.2	7.3	
8/28/2021							
8/29/2021							
8/30/2021			1	7.04	7.0	7.9	
8/31/2021			1	7.26	7.3	8.1	

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl) Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(Report) lbs/day						
Stat. Base	Maximum Daily						
8/1/2021							
8/2/2021							
8/3/2021							
8/4/2021							
8/5/2021							
8/6/2021							
8/7/2021							
8/8/2021							
8/9/2021							
8/10/2021	<0.1008720						
8/11/2021							
8/12/2021							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY
--	---	---	---	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

8/13/2021							
8/14/2021							
8/15/2021							
8/16/2021							
8/17/2021							
8/18/2021							
8/19/2021							
8/20/2021							
8/21/2021							
8/22/2021							
8/23/2021							
8/24/2021							
8/25/2021							
8/26/2021							
8/27/2021							
8/28/2021							
8/29/2021							
8/30/2021							
8/31/2021							

DMR Instructions:

DMR Comments: (none)

- **Set 1 DMR Value Comments:**
- Date: 8/27/2021 12:00:00 AM, Column 6 Comment: Primary clarifier settling issue

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	2.06	2.85	MGD	*****	*****	*****	*****		Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	124.44	180.63	lbs/day	*****	6.95	9.26	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	530 Maximum Monthly Average	800 Maximum 7-Day Average		*****	20 Maximum Monthly Average	30 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	99.58	125.51	lbs/day	*****	5.62	10.5	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	190 Maximum Monthly Average	270 Maximum 7-Day Average		*****	7 Maximum Monthly Average	10 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	5.28	6.09	lbs/day	*****	0.3	0.3	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	24 Maximum Monthly Average	53 Maximum 7-Day Average		*****	0.9 Maximum Monthly Average	2.0 Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED							

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	5.78	13.95	lbs/day	*****	0.32	0.61	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	***** Maximum Daily		*****	0.5 Maximum Monthly Average	***** Maximum Daily			5X Weekly	24-Hr Composite
Total Copper (01042) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.36	0.485	lbs/day	*****	19.98	21.20	ug/L		Weekly	24-Hr Composite
	PERMIT REQUIREMENT	0.3 Maximum Monthly Average	0.82 Maximum Daily		*****	11 Maximum Monthly Average	31 Maximum Daily			Weekly	24-Hr Composite
Total Mercury (71900) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*G	*G	lbs/day	*****	*G	*G	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X) Lab ID:	SAMPLE MEASUREMENT	*G	*****	lbs/day	*****	*G	*****	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculation
Total Nickel (01067) Final Effluent (1)	SAMPLE MEASUREMENT	<0.090	<0.119	lbs/day	*****	<5.0	<5.0	ug/L		Quarterly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	TELEPHONE NUMBER	DATE YEAR MO DAY		
TYPED OR PRINTED							

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			Quarterly	24-Hr Composite
Total Selenium (01147) Final Effluent (1)	SAMPLE MEASUREMENT	<0.036	<0.048	lbs/day	*****	<2.0	<2.0	ug/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	0.15 Maximum Monthly Average	***** Maximum Daily		*****	5.7 Maximum Monthly Average	***** Maximum Daily			Monthly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS) (51526) Final Effluent (1)	SAMPLE MEASUREMENT	*G	*G	lbs/day	*****	*G	*G	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			2X Annually	Grab
Perfluorooctanoic Acid (PFOA) (51521) Final Effluent (1)	SAMPLE MEASUREMENT	*G	*G	lbs/day	*****	*G	*G	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			2X Annually	Grab
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	*****	5.75	11.4	#/100mL		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
pH (00400) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	6.64	*****	7.46	SU		5X Weekly	Grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED							

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 8/1/2021 - 8/31/2021
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	*****	*****		7.29	*****	*****			5X Weekly	Grab
Final Effluent (1)											
Lab ID:	PERMIT REQUIREMENT	*****	*****	*****	6.0 Minimum Daily	*****	*****	mg/L		5X Weekly	Grab
Bis(2-Ethylhexyl)Phthalate (39100)	SAMPLE MEASUREMENT	<0.1008720	<0.1008720		*****	<4.4	<4.4			Monthly	24-Hr Composite
Final Effluent (1)				lbs/day							
Lab ID:	PERMIT REQUIREMENT	0.82 Maximum Monthly Average	***** Maximum Daily		*****	31 Maximum Monthly Average	***** Maximum Daily	ug/L		Monthly	24-Hr Composite

DMR Instructions:

DMR Comments: (none)

DMR Value Comments:

- Total Copper, Final Effluent (1), Limit: 0.3 Maximum Monthly Average, Reported Value: 0.36, Comment: Primary clarifier settling issue
- Total Copper, Final Effluent (1), Limit: 11 Maximum Monthly Average, Reported Value: 19.98, Comment: Primary clarifier settling issue
- Carbonaceous Biochemical Oxygen Demand (CBOD5), Final Effluent (1), Limit: 10 Maximum Daily, Reported Value: 10.5, Comment: Primary clarifier settling issue

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY