

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(Report) MGD	45 mg/L	1200 lbs/day	(Report) mg/L	(Report) lbs/day	25 mg/L	670 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
4/1/2022	2.120			9.00	159.162	10.10	
4/2/2022	1.956						
4/3/2022	1.787						
4/4/2022	1.763			11.00	161.750	6.86	
4/5/2022	1.964			10.00	163.784	6.53	
4/6/2022	2.031			10.00	169.395	8.60	
4/7/2022	2.160	9.600	159.638	8.00	144.097	7.30	132.722
4/8/2022	2.002	9.600	157.860	9.00	150.273	7.60	122.378
4/9/2022	1.963	9.600	157.860				122.378
4/10/2022	1.863	9.600	157.860				122.378
4/11/2022	1.933	9.000	151.298	8.00	128.939	6.00	121.544
4/12/2022	1.992	8.400	141.801	7.00	116.303	5.80	119.427
4/13/2022	1.966	7.800	130.883	7.00	114.801	5.70	108.987
4/14/2022	1.967	8.400	138.147	11.00	180.418	6.70	104.668
4/15/2022	1.851	7.800	126.621	6.00	92.642	6.60	99.670
4/16/2022	1.594	7.800	126.621				99.670
4/17/2022	1.532	7.800	126.621				99.670
4/18/2022	1.622	7.800	122.477	8.00	108.221	5.65	95.615
4/19/2022	1.880	8.400	130.578	10.00	156.810	7.10	98.609
4/20/2022	1.892	9.000	139.182	10.00	157.821	10.10	111.792
4/21/2022	1.953	8.400	129.158	8.00	130.296	9.40	120.434

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC	TELEPHONE	DATE		
			2317750181 124			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

4/22/2022	1.963	10.200	159.740	15.00	245.555	10.90	135.740
4/23/2022	2.077	10.200	159.740				135.740
4/24/2022	2.101	10.200	159.740				135.740
4/25/2022	2.136	11.000	180.857	12.00	213.805	6.45	143.438
4/26/2022	2.139	11.400	192.314	12.00	214.096	10.22	157.638
4/27/2022	2.196	11.000	190.057	8.00	146.532	21.00	202.688
4/28/2022	2.103	11.800	206.088	12.00	210.455	22.50	250.989
4/29/2022	1.939	11.000	196.222			15.40	265.119
4/30/2022	1.962	11.200	196.241	12.00	196.317		265.119

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
4/1/2022	178.615	1.46	25.820	0.158	2.794		
4/2/2022							
4/3/2022						5	0.0745
4/4/2022	100.873	0.47	6.941	0.206	3.029		
4/5/2022	106.951	1.18	19.327	0.227	3.718		
4/6/2022	145.680	0.64	10.892	0.171	2.897		
4/7/2022	131.489	0.30	5.404	0.144	2.594		
4/8/2022	126.897	0.30	5.009	0.141	2.354	5	0.0835
4/9/2022							
4/10/2022							
4/11/2022	96.704	0.30	4.835	0.174	2.804	5.3	0.0854
4/12/2022	96.365	0.34	5.566	0.167	2.775		
4/13/2022	93.481	0.30	4.920	0.153	2.509		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

4/14/2022	109.891	0.30	4.920	0.183	3.002		
4/15/2022	101.906	0.30	4.632	0.142	2.193		
4/16/2022							
4/17/2022							
4/18/2022	76.431	0.30	4.058	0.185	2.503		
4/19/2022	111.335	0.30	4.704	0.207	3.246	5.1	0.0800
4/20/2022	159.399	0.32	4.987	0.170	2.683		
4/21/2022	153.098	0.30	4.886	0.183	2.981		
4/22/2022	178.437	0.38	6.204	0.202	3.307		
4/23/2022							
4/24/2022							
4/25/2022	114.920	1.79	31.893	0.202	3.599		
4/26/2022	182.338	2.25	40.143	0.183	3.265		
4/27/2022	384.647	2.43	44.509	0.158	2.894	5.4	0.0989
4/28/2022	394.603	1.60	28.061	0.144	2.525		
4/29/2022	249.089	1.29	20.865	0.137	2.216		
4/30/2022							

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)
Limit	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
4/1/2022							
4/2/2022							
4/3/2022							5
4/4/2022							
4/5/2022							
4/6/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE
--	---	---	---	---------------------------------	--------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

4/7/2022							
4/8/2022							5
4/9/2022							
4/10/2022							
4/11/2022							5
4/12/2022							
4/13/2022							
4/14/2022							
4/15/2022							
4/16/2022							
4/17/2022							
4/18/2022							
4/19/2022							5
4/20/2022							
4/21/2022							
4/22/2022							
4/23/2022							
4/24/2022							
4/25/2022							
4/26/2022							
4/27/2022							5
4/28/2022							
4/29/2022							
4/30/2022							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	(Report) ug/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR	MO DAY	DATE
--	---	--	--	----------------------------	---------------	----------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
4/1/2022							
4/2/2022							
4/3/2022	0.7452	2	0.0298				
4/4/2022							
4/5/2022							
4/6/2022							
4/7/2022							
4/8/2022	0.8349	2	0.0334				
4/9/2022							
4/10/2022							
4/11/2022	0.8059	2	0.0322				
4/12/2022							
4/13/2022							
4/14/2022							
4/15/2022							
4/16/2022							
4/17/2022							
4/18/2022							
4/19/2022	0.7840	2	0.0314				
4/20/2022							
4/21/2022				3.1	0.0000505	2	0.0000326
4/22/2022							
4/23/2022							
4/24/2022							
4/25/2022							
4/26/2022							
4/27/2022	0.9158	2	0.0366				
4/28/2022							
4/29/2022							
4/30/2022							

Set: 5 of 6

--	--	--	--	--	--	--	--

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE			
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis(2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily (Report) #/100mL	Percent Removal (K) (Report) % (2)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL			6.5 SU	9.0 SU	5.0 mg/L	(Report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
4/1/2022		37.90	91.35	7.96	8.0	8.35	
4/2/2022							
4/3/2022							
4/4/2022		1.00	96.84	8.15	8.2	8.59	
4/5/2022		100.00	94.05	7.85	7.9	8.33	<4.2
4/6/2022	20.864	50.00	95.61	7.67	7.7	8.50	
4/7/2022	8.409	1.00	96.15	8.03	8.0	8.76	
4/8/2022	5.493	1.00	95.75	7.72	7.7	8.87	
4/9/2022	5.493						
4/10/2022	8.409						
4/11/2022	5.530	18.70	98.15	7.71	7.7	9.09	
4/12/2022	3.430	7.40	98.01	7.69	7.7	8.75	
4/13/2022	4.079	2.00	97.50	7.83	7.8	8.81	
4/14/2022	5.412	3.10	94.39	7.98	8.0	8.70	
4/15/2022	4.810	3.00	97.32	7.86	7.9	8.93	
4/16/2022	4.810						
4/17/2022	3.425						
4/18/2022	2.955	4.10	96.23	7.96	8.0	9.39	
4/19/2022	4.556	11.30	97.93	7.95	8.0	9.00	
4/20/2022	3.434	1.00	95.90	8.21	8.2	9.05	
4/21/2022	4.303	7.40	96.72	7.93	7.9	8.52	
4/22/2022	4.030	3.10	92.92	7.93	7.9	8.35	
4/23/2022	4.030						
4/24/2022	4.013						
4/25/2022	2.189	1.00	93.18	7.75	7.8	7.45	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124	DATE <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%; border: 1px solid black; height: 30px;"></td> <td style="width: 33%; border: 1px solid black; height: 30px;"></td> <td style="width: 33%; border: 1px solid black; height: 30px;"></td> </tr> <tr> <td style="text-align: center; font-size: small;">YEAR</td> <td style="text-align: center; font-size: small;">MO</td> <td style="text-align: center; font-size: small;">DAY</td> </tr> </table>				YEAR	MO	DAY
YEAR	MO	DAY								
			<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%; border: 1px solid black; font-size: small;">AREA CODE</td> <td style="width: 33%; border: 1px solid black; font-size: small;">NUMBER</td> <td style="width: 33%; border: 1px solid black; font-size: small;">YEAR</td> </tr> </table>	AREA CODE	NUMBER	YEAR				
AREA CODE	NUMBER	YEAR								

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

4/26/2022	2.189	1.00	95.16	7.79	7.8	7.77	
4/27/2022	1.327	1.00	94.59	7.94	7.9	7.88	
4/28/2022	1.000	1.00	93.48	7.87	7.9	7.81	
4/29/2022	1.000	1.00	95.71	7.92	7.9	7.51	
4/30/2022	1.000						

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl)Phtalate						
Mon. Loc.	Final Effluent (1)						
Limit	(Report) lbs/day						
Stat. Base	Maximum Daily						
4/1/2022							
4/2/2022							
4/3/2022							
4/4/2022							
4/5/2022	<0.0688						
4/6/2022							
4/7/2022							
4/8/2022							
4/9/2022							
4/10/2022							
4/11/2022							
4/12/2022							
4/13/2022							
4/14/2022							
4/15/2022							
4/16/2022							
4/17/2022							
4/18/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

4/19/2022							
4/20/2022							
4/21/2022							
4/22/2022							
4/23/2022							
4/24/2022							
4/25/2022							
4/26/2022							
4/27/2022							
4/28/2022							
4/29/2022							
4/30/2022							

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	2.07	2.34	MGD	*****	*****	*****	*****		Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	160.6	245.55	lbs/day	*****	9.79	12	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	800 Maximum Monthly Average	1200 Maximum 7-Day Average		*****	30 Maximum Monthly Average	45 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	156.96	394.60	lbs/day	*****	9.36	22.5	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	450 Maximum Monthly Average	670 Maximum 7-Day Average		*****	17 Maximum Monthly Average	25 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	20.44	44.51	lbs/day	*****	1.179	2.43	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	130 Maximum Monthly Average	REPORT Maximum Daily		*****	4.8 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	2.87	3.767	lbs/day	*****	0.17286	3.767	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	17 Maximum Monthly Average	REPORT Maximum Daily		*****	0.65 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite
Total Copper (01042) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.00149	0.001932	lbs/day	*****	0.088667	0.099	ug/L		Weekly	24-Hr Composite
	PERMIT REQUIREMENT	0.3 Maximum Monthly Average	0.82 Maximum Daily		*****	11 Maximum Monthly Average	31 Maximum Daily			Weekly	24-Hr Composite
Total Mercury (71900) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.000006	0.000006	lbs/day	*****	0.28	0.32	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X) Lab ID:	SAMPLE MEASUREMENT	0.000006	*****	lbs/day	*****	0.30	*****	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculation
Total Nickel (01067) Final Effluent (1)	SAMPLE MEASUREMENT	0.092	0.092	lbs/day	*****	0.1015	0.11	ug/L		Quarterly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	24-Hr Composite
Total Selenium (01147) Final Effluent (1)	SAMPLE MEASUREMENT	*g	*g		*****	*g	*g			Monthly	24-Hr Composite
Lab ID:				lbs/day				ug/L			
	PERMIT REQUIREMENT	0.15 Maximum Monthly Average	REPORT Maximum Daily		*****	5.7 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS) (51526) Final Effluent (1)	SAMPLE MEASUREMENT	0.0000505	0.0000505		*****	3.1	3.1			2X Annually	Grab
Lab ID:				lbs/day				ng/L			
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Perfluorooctanoic Acid (PFOA) (51521) Final Effluent (1)	SAMPLE MEASUREMENT	0.0000326	0.0000326		*****	2	2			2X Annually	Grab
Lab ID:				lbs/day				ng/L			
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****		*****	16	70.7			5X Weekly	Grab
Lab ID:				*****				#/100mL			
	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
Total Suspended Solids Minimum % Removal	SAMPLE MEASUREMENT	*****	*****	*****	95.6	*****	91.3	% (2)		Monthly	Calculation

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 4/1/2022 - 4/30/2022
DMR Version: 2

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
(81011) Percent Removal (K) Lab ID:	PERMIT REQUIREMENT	*****	*****		85 Minimum Monthly % Removal	*****	REPORT Minimum Daily % Removal			Monthly	Calculation
pH (00400) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.2	SU		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	7.45	*****	*****	mg/L		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		5.0 Minimum Daily	*****	*****			5X Weekly	Grab
Bis(2-Ethylhexyl) Phthalate (39100) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.074	0.074	lbs/day	*****	4.2	4.2	ug/L		Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.82 Maximum Monthly Average	REPORT Maximum Daily		*****	31 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

Submission Identifier: DMR-MI0020257-20220430-1-v2

Submission Signature Hash: P+gkaCc74CBwejlsgV/7ljlO6lom21mGJ0SV0rVGK0A=

Submitter Name: Jeffrey Dietlin Cadillac Financing Auth. GWCU

Submitter Email: utilities@cadillac-mi.net

Submitted Date/Time: 11/8/2022 11:52:29 AM