

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(Report) MGD	45 mg/L	1200 lbs/day	(Report) mg/L	(Report) lbs/day	17 mg/L	480 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
11/1/2022	1.783			4.80	71.389	4.15	
11/2/2022	1.833			4.00	61.162	5.20	
11/3/2022	1.836			5.60	85.772	6.95	
11/4/2022	1.834			7.20	110.147	9.60	
11/5/2022	1.856						
11/6/2022	1.675						
11/7/2022	1.674	5.760	85.794	7.20	100.502	4.60	91.751
11/8/2022	1.926	5.760	86.935	4.80	77.092	5.60	97.395
11/9/2022	1.883	6.080	92.291	5.60	87.941	6.65	102.378
11/10/2022	1.892	6.160	94.076	6.00	94.699	9.30	110.445
11/11/2022	1.878	6.400	98.355	8.40	131.542	10.10	112.706
11/12/2022	1.667	6.400	98.355				112.706
11/13/2022	1.501	6.400	98.355				112.706
11/14/2022	1.568	6.320	96.042	6.80	88.936	12.70	133.084
11/15/2022	1.750	7.760	115.661	12.00	175.187	11.25	147.943
11/16/2022	1.813	9.240	137.388	13.00	196.577	14.95	172.270
11/17/2022	1.768	11.840	174.489	19.00	280.203	14.05	184.354
11/18/2022	1.786	12.960	189.892	14.00	208.556	15.90	200.093
11/19/2022	1.717	12.960	189.892				200.093
11/20/2022	1.538	12.960	189.892				200.093
11/21/2022	1.514	15.000	215.024	17.00	214.594	13.45	200.829

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

11/22/2022	1.666	15.400	218.897	14.00	194.555	11.90	201.056
11/23/2022	1.855	17.200	247.639	22.00	340.287	17.40	209.671
11/24/2022	1.730	16.600	237.781	16.00	230.911	13.60	207.485
11/25/2022	1.453	16.400	227.579	13.00	157.547	11.07	186.944
11/26/2022	1.408	16.400	227.579				186.944
11/27/2022	1.440	16.400	227.579				186.944
11/28/2022	1.551	17.000	236.399	20.00	258.694	9.30	177.047
11/29/2022	1.799	16.600	233.493	12.00	180.023	13.55	184.627
11/30/2022	1.859	15.000	208.857	14.00	217.108	16.50	181.976

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	2.8 mg/L	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2022	61.722	0.30	4.462	0.223	3.317		
11/2/2022	79.511	0.30	4.587	0.192	2.936		
11/3/2022	106.449	0.30	4.595	0.174	2.665		
11/4/2022	146.863	0.30	4.589	0.192	2.937	<5	<0.0765
11/5/2022							
11/6/2022							
11/7/2022	64.209	0.30	4.188	0.189	2.638	<5	<0.0698
11/8/2022	89.940	0.30	4.818	0.164	2.634		
11/9/2022	104.430	0.30	4.711	0.126	1.979		
11/10/2022	146.784	0.30	4.735	0.137	2.162		
11/11/2022	158.164	0.30	4.698	0.147	2.302		
11/12/2022							
11/13/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE YEAR MO DAY
--	---	--	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

11/14/2022	166.102	0.30	3.924	0.178	2.328		
11/15/2022	164.238	0.30	4.380	0.180	2.628	<5	<0.0730
11/16/2022	226.064	0.30	4.536	0.179	2.707		
11/17/2022	207.203	0.30	4.424	0.159	2.345		
11/18/2022	236.860	0.46	6.867	0.185	2.756		
11/19/2022						<5	<0.0716
11/20/2022							
11/21/2022	169.782	0.30	3.787	0.209	2.638		
11/22/2022	165.372	0.30	4.169	0.222	3.085		
11/23/2022	269.136	0.80	12.436	0.228	3.527	5.3	0.0820
11/24/2022	196.275	0.71	10.189	0.210	3.031		
11/25/2022	134.158	0.18	2.157	0.218	2.642		
11/26/2022							
11/27/2022							
11/28/2022	120.293	0.30	3.880	0.321	4.152		
11/29/2022	203.276	0.30	4.501	0.358	5.371	9.6	0.1440
11/30/2022	255.878	0.30	4.652	0.226	3.505		

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA-Effluent	Mercury QA-Effluent	Mercury QA-Effluent	Mercury QA-Effluent	Final Effluent (1)
Limit	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2022	*g	*g	*g	*g	*g	*g	
11/2/2022							
11/3/2022							
11/4/2022							<5
11/5/2022							
11/6/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE YEAR MO DAY
--	---	--	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

11/7/2022							<5
11/8/2022							
11/9/2022							
11/10/2022							
11/11/2022							
11/12/2022							
11/13/2022							
11/14/2022							
11/15/2022							<5
11/16/2022							
11/17/2022							
11/18/2022							
11/19/2022							<5
11/20/2022							
11/21/2022							
11/22/2022							
11/23/2022							<5
11/24/2022							
11/25/2022							
11/26/2022							
11/27/2022							
11/28/2022							
11/29/2022							<5
11/30/2022							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	(Report) ug/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2022				*g	*g	*g	*g
11/2/2022							
11/3/2022							
11/4/2022	<0.0765	<2	<0.0306				
11/5/2022							
11/6/2022							
11/7/2022	<0.0698	<2	<0.0279				
11/8/2022							
11/9/2022							
11/10/2022							
11/11/2022							
11/12/2022							
11/13/2022							
11/14/2022							
11/15/2022	<0.0730	<2	<0.0292				
11/16/2022							
11/17/2022							
11/18/2022							
11/19/2022	<0.0716	<2	<0.0286				
11/20/2022							
11/21/2022							
11/22/2022							
11/23/2022	<0.0773	<2	<0.0309				
11/24/2022							
11/25/2022							
11/26/2022							
11/27/2022							
11/28/2022							
11/29/2022	<0.0750	<2	<0.0300				
11/30/2022							

Set: 5 of 6

--	--	--	--	--	--	--	--

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER 	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE 2317750181 124	DATE 		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis(2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily (Report) #/100mL	Percent Removal (K) (Report) % (2)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL			6.5 SU	9.0 SU	6.0 mg/L	(Report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
11/1/2022		1.00	97.00	7.59	7.59	8.45	
11/2/2022		2.00	96.00	7.63	7.63	8.58	
11/3/2022		2.00	95.33	7.57	7.57	8.49	
11/4/2022		2.00	95.50	7.85	7.85	8.36	
11/5/2022							
11/6/2022	1.682						
11/7/2022	2.000	2.00	96.54	7.52	7.52	8.82	
11/8/2022	1.682	1.00	98.67	7.46	7.46	8.92	4.1
11/9/2022	1.682	2.00	97.54	7.61	7.61	8.91	
11/10/2022	1.414	1.00	94.44	7.61	7.61	8.43	
11/11/2022	1.320	1.00	96.82	7.79	7.79	8.29	
11/12/2022	1.320						
11/13/2022	1.189						
11/14/2022	1.189	1.00	97.57	8.05	8.05	9.04	
11/15/2022	1.189	2.00	92.86	7.92	7.92	8.92	
11/16/2022	1.189	1.00	97.34	7.66	7.66	8.60	
11/17/2022	1.189	1.00	94.21	7.57	7.57	8.66	
11/18/2022	1.440	3.10	94.93	7.53	7.53	8.15	
11/19/2022	1.440						
11/20/2022	1.578						
11/21/2022	1.327	1.00	91.50	7.62	7.62	9.24	
11/22/2022	1.327	1.00	94.53	7.56	7.56	8.86	
11/23/2022	1.327	1.00	90.18	7.66	7.66	8.47	
11/24/2022	1.000	1.00	92.16	7.61	7.61	8.41	
11/25/2022	1.000	1.00	94.84	7.64	7.64	8.58	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

11/26/2022	1.000						
11/27/2022	1.000						
11/28/2022	1.000	1.00	93.75	7.60	7.60	9.10	
11/29/2022	1.000	1.00	92.86	7.58	7.58	8.99	
11/30/2022	1.189	2.00	93.02	7.60	7.60	8.77	

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl)Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(Report) lbs/day						
Stat. Base	Maximum Daily						
11/1/2022							
11/2/2022							
11/3/2022							
11/4/2022							
11/5/2022							
11/6/2022							
11/7/2022							
11/8/2022	0.0658						
11/9/2022							
11/10/2022							
11/11/2022							
11/12/2022							
11/13/2022							
11/14/2022							
11/15/2022							
11/16/2022							
11/17/2022							
11/18/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

11/19/2022							
11/20/2022							
11/21/2022							
11/22/2022							
11/23/2022							
11/24/2022							
11/25/2022							
11/26/2022							
11/27/2022							
11/28/2022							
11/29/2022							
11/30/2022							

DMR Instructions:

DMR Comments: (none)

- **Set 1 DMR Value Comments:**
- Date: 11/23/2022 12:00:00 AM, Column 6 Comment: I believe this was due to us aggressively decanting to make room for more sludge storage. I contacted Don on the 28th to inform him of the violation.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	1.715	1.926	MGD	*****	*****	*****	*****		Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	161.974	247.639	lbs/day	*****	11.2	17.2	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	800 Maximum Monthly Average	1200 Maximum 7-Day Average		*****	30 Maximum Monthly Average	45 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	157.85	209.671	lbs/day	*****	10.81	17.4	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	290 Maximum Monthly Average	480 Maximum 7-Day Average		*****	11 Maximum Monthly Average	17 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	5.058	12.436	lbs/day	*****	0.34	0.8	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	88 Maximum Monthly Average	REPORT Maximum Daily		*****	1.6 Maximum Monthly Average	2.8 Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	2.922	5.371	lbs/day	*****	0.201	0.358	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	REPORT Maximum Daily		*****	0.5 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite
Total Copper (01042) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	<0.0861	0.1440	lbs/day	*****	<5.817	9.6	ug/L		Weekly	24-Hr Composite
	PERMIT REQUIREMENT	0.3 Maximum Monthly Average	0.82 Maximum Daily		*****	11 Maximum Monthly Average	31 Maximum Daily			Weekly	24-Hr Composite
Total Mercury (71900) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X) Lab ID:	SAMPLE MEASUREMENT	*g	*****	lbs/day	*****	*g	*****	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculation
Total Nickel (01067) Final Effluent (1)	SAMPLE MEASUREMENT	<0.0739	<0.0773	lbs/day	*****	<5	<5	ug/L		Quarterly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	24-Hr Composite
Total Selenium (01147) Final Effluent (1)	SAMPLE MEASUREMENT	<0.0295	<0.0309	lbs/day	*****	<2	<2	ug/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	0.15 Maximum Monthly Average	REPORT Maximum Daily		*****	5.7 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS) (51526) Final Effluent (1)	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Perfluorooctanoic Acid (PFOA) (51521) Final Effluent (1)	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.41	3.1	#/100mL		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
Total Suspended Solids Minimum % Removal	SAMPLE MEASUREMENT	*****	*****	*****	94.89	*****	90.18	% (2)		Monthly	Calculation

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 11/1/2022 - 11/30/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
(81011) Percent Removal (K) Lab ID:	PERMIT REQUIREMENT	*****	*****		85 Minimum Monthly % Removal	*****	REPORT Minimum Daily % Removal			Monthly	Calculation
pH (00400) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	7.46	*****	8.05	SU		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	8.15	*****	*****	mg/L		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 Minimum Daily	*****	*****			5X Weekly	Grab
Bis(2-Ethylhexyl) Phthalate (39100) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.0658	0.0658	lbs/day	*****	4.1	4.1	ug/L		Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.82 Maximum Monthly Average	REPORT Maximum Daily		*****	31 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

Submission Identifier: DMR-MI0020257-20221130-1

Submission Signature Hash: saZo3/vzHeinTB9ObXIDh+7NaE4bWqANazHLxBus/Zs=

Submitter Name: Jeffrey Dietlin Cadillac Financing Auth. GWCU

Submitter Email: utilities@cadillac-mi.net

Submitted Date/Time: 12/14/2022 1:55:30 PM