

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 7/1/2015 - 7/31/2015
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	30 mg/L	800 lbs/day	10 mg/L	270 lbs/day	2 mg/L	53 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum 7-Day Average
7/1/2015	2.14	3.60	64.40	3.63	64.9	0.24	4.29
7/2/2015	2.14	4.00	71.31	3.10	55.3	0.36	6.42
7/3/2015	2.14	2.00	35.73	3.65	65.2	0.40	7.15
7/4/2015	1.90						
7/5/2015	1.95						
7/6/2015	2.41	4.40	88.48	4.13	83.1	0.11	2.21
7/7/2015	2.20	2.40	44.05	3.28	60.2	0.66	12.11
7/8/2015	2.16	2.40	43.21	4.08	73.5	0.38	6.84
7/9/2015	2.13	2.80	49.71	4.00	71.0	0.28	4.97
7/10/2015	2.07	2.80	48.42	8.60	148.7	0.31	5.36
7/11/2015	1.84						
7/12/2015	1.84						
7/13/2015	2.39	3.20	63.66	7.67	152.6	0.04	0.80
7/14/2015	2.31	2.40	46.24	4.35	83.8	0.31	5.97
7/15/2015	2.34	4.00	78.03	4.30	83.9	0.13	2.54
7/16/2015	2.29	5.20	99.48	4.20	80.3	0.06	1.15
7/17/2015	2.23	3.20	59.58	4.10	76.3	0.07	1.30
7/18/2015	2.13						
7/19/2015	2.00						
7/20/2015	2.34	4.80	93.72	6.52	127.3	0.04	0.78
7/21/2015	2.23	4.40	81.70	3.93	73.0	1.49	27.67
7/22/2015	2.12	4.20	74.40	4.40	77.9	0.16	2.83

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2015	08	28
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 7/1/2015 - 7/31/2015
DMR Version: 1

7/23/2015	2.16	4.40	79.35	4.30	77.5	0.23	4.15
7/24/2015	2.11	10.00	176.19	5.18	91.3	0.43	7.58
7/25/2015	1.81						
7/26/2015	1.80						
7/27/2015	2.22	10.50	194.39	5.80	107.4	0.08	1.48
7/28/2015	2.33	5.50	106.85	3.70	71.9	0.18	3.50
7/29/2015	2.39	5.00	99.65	3.20	63.8	0.20	3.99
7/30/2015	1.93	7.50	120.45	3.90	62.6	0.48	7.71
7/31/2015	2.01	4.00	67.05	3.80	63.69	0.24	4.02

Set: 2 of 4

Parameter	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide	Total Copper	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (Daily Form Only) (1D)	Final Effluent (Daily Form Only) (1D)
Limit	(report) mg/L	(report) lbs/day	(report) ug/L	(report) ug/L	(report) ng/L	(report) ng/L	(report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
7/1/2015	0.16	2.86	<2	<50	*E	*E	*E
7/2/2015	0.16	2.85					
7/3/2015	0.08	1.43					
7/4/2015							
7/5/2015							
7/6/2015	0.11	2.21					
7/7/2015	0.08	1.47		<50			
7/8/2015	0.11	1.98					
7/9/2015	0.11	1.95					
7/10/2015	0.11	1.90					
7/11/2015							
7/12/2015							
7/13/2015	0.14	2.79					

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2015 08 28 YEAR MO DAY
--	---	--	--	---

Permit Number: MI0020257 v5.0

DMR Version: 1

Generated: 3/29/2021 7:35 PM

Page 2 of 5

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 7/1/2015 - 7/31/2015
DMR Version: 1

7/14/2015	0.13	2.50					
7/15/2015	0.16	3.12		<50			
7/16/2015	0.13	2.49					
7/17/2015	0.14	2.61					
7/18/2015							
7/19/2015							
7/20/2015	0.16	3.12					
7/21/2015	0.20	3.71					
7/22/2015	0.19	3.37					
7/23/2015	0.20	3.61		<50			
7/24/2015	0.23	4.05					
7/25/2015							
7/26/2015							
7/27/2015	0.21	3.89					
7/28/2015	0.24	4.66		<50			
7/29/2015	0.23	4.58					
7/30/2015	0.22	3.53					
7/31/2015	0.20	3.35					

Set: 3 of 4

Parameter	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)	Fecal Coliform	pH	pH
Mon. Loc.	Final Effluent (Daily Form Only) (1D)	Final Effluent (Daily Form Only) (1D)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC	400 #/100mL	6.5 SU	6.5 SU
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Max 7-Day Geometric Mean	Minimum Daily	Minimum Daily
7/1/2015	*E	*E	*E	*E	13	7.42	7.4
7/2/2015					15	7.18	7.2
7/3/2015					5	7.46	7.5

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124	DATE 2015 08 28	AREA CODE	NUMBER	YEAR	MO	DAY
--	---	---	---------------------------------	------------------------	--------------	--------	------	----	-----

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 7/1/2015 - 7/31/2015
DMR Version: 1

7/4/2015					29		
7/5/2015							
7/6/2015						7.36	7.4
7/7/2015					10	7.16	7.2
7/8/2015					15	7.11	7.1
7/9/2015					7	6.97	7.0
7/10/2015					18	7.18	7.2
7/11/2015							
7/12/2015							
7/13/2015					16	7.27	7.3
7/14/2015					11	7.25	7.3
7/15/2015					18	7.54	7.5
7/16/2015					14	7.49	7.5
7/17/2015					12	7.37	7.4
7/18/2015							
7/19/2015							
7/20/2015					13	7.31	7.3
7/21/2015					32	7.25	7.3
7/22/2015					30	7.06	7.1
7/23/2015					66	7.26	7.3
7/24/2015					86	7.28	7.3
7/25/2015							
7/26/2015							
7/27/2015					42	7.2	7.2
7/28/2015					11	7.35	7.4
7/29/2015					8	7.34	7.3
7/30/2015					5	7.54	7.5
7/31/2015					30	7.56	7.6

Set: 4 of 4

Parameter	Dissolved Oxygen						

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124	2015	08	28
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 7/1/2015 - 7/31/2015
DMR Version: 1

Mon. Loc.	Final Effluent (1)						
Limit	6.0 mg/L						
Stat. Base	Minimum Daily						
7/1/2015	7.7						
7/2/2015	7.6						
7/3/2015	7.3						
7/4/2015							
7/5/2015							
7/6/2015	7.5						
7/7/2015	7.4						
7/8/2015	7.5						
7/9/2015	7.1						
7/10/2015	7.0						
7/11/2015							
7/12/2015							
7/13/2015	7.5						
7/14/2015	7.3						
7/15/2015	7.7						
7/16/2015	7.8						
7/17/2015	7.7						
7/18/2015							
7/19/2015							
7/20/2015	7.8						
7/21/2015	7.2						
7/22/2015	7.7						
7/23/2015	7.5						
7/24/2015	7.3						
7/25/2015							
7/26/2015							
7/27/2015	8.2						
7/28/2015	7.9						
7/29/2015	8.1						
7/30/2015	7.8						

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE 2317750181 124	DATE 2015 08 28			
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 7/1/2015 - 7/31/2015
DMR Version: 1

7/31/2015	8.0						
-----------	-----	--	--	--	--	--	--

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124	2015	08	28	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY