

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 7/1/2017 - 7/31/2017
DMR Version: 2

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	30 mg/L	800 lbs/day	(report) mg/L	(report) lbs/day	10 mg/L	270 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
7/1/2017	2.08			3.12	56.45		
7/2/2017	1.91			3.12	56.45		
7/3/2017	1.90	2.00	31.74	3.12	56.45	14.00	222.2
7/4/2017	1.90	1.20	19.01	3.52	64.61	<3.00	47.5
7/5/2017	1.74	3.20	46.49	4.96	99.67	<3.00	43.6
7/6/2017	2.39	5.20	103.50	5.12	106.23	13.90	178.61
7/7/2017	2.44	4.00	81.54	4.72	100.32	8.20	167.1
7/8/2017	2.33			4.56	98.61		
7/9/2017	2.16			4.56	98.61		
7/10/2017	2.17	4.00	72.50	4.56	98.61	5.90	106.9
7/11/2017	2.77	8.40	194.32	4.72	101.28	7.60	175.8
7/12/2017	2.38	4.00	79.28	4.24	88.32	8.40	166.5
7/13/2017	2.77	3.20	73.97	5.14	105.66	9.10	210.4
7/14/2017	2.74	3.20	72.98	6.10	123.35	8.00	182.5
7/15/2017	2.51			6.46	129.81		
7/16/2017	2.21			6.46	129.81		
7/17/2017	2.15	4.80	85.86	6.46	129.81	3.75	67.1
7/18/2017	2.59	6.00	129.48	5.98	120.83	4.73	102.1
7/19/2017	2.34	8.50	166.00	5.26	104.66	8.40	164.1
7/20/2017	2.43	8.00	162.41	4.12	82.67	9.20	186.8
7/21/2017	2.53	5.00	105.31	2.92	58.44	7.20	151.6

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2019	06	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 7/1/2017 - 7/31/2017
DMR Version: 2

7/22/2017	2.49			2.48	48.84		
7/23/2017	2.09			2.48	48.84		
7/24/2017	2.05	2.40	40.93	2.48	48.84	<3.00	51.2
7/25/2017	2.43	2.40	48.67	2.40	47.26	3.00	60.8
7/26/2017	2.40	2.80	56.06	2.40	46.91	3.00	60.1
7/27/2017	2.47	2.00	41.24	2.40	49.28	3.30	68.0
7/28/2017	2.46	2.80	57.32	2.80	57.32	4.40	90.1
7/29/2017	2.22			2.00	33.01		
7/30/2017	1.86			2.00	33.01		
7/31/2017	1.98	2.00	33.01			<3.00	49.51

Set: 2 of 4

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	2 mg/L	53 lbs/day	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
7/1/2017	151.4		2.45				
7/2/2017	151.4		2.45				
7/3/2017	151.4	0.05	2.45	0.79	0.20	3.17	
7/4/2017	128.4	0.09	2.47	1.43	0.19	3.01	<2.00
7/5/2017	154.0	0.05	9.31	0.73	0.22	3.20	
7/6/2017	178.6	0.19	9.44	3.78	0.22	4.38	
7/7/2017	165.3	0.27	9.93	5.50	0.18	3.67	
7/8/2017	168.4		11.75				
7/9/2017	168.4		11.75				
7/10/2017	168.4	0.05	11.75	0.91	0.16	2.90	
7/11/2017	160.4	1.54	11.78	35.63	0.20	4.63	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124		2019	06	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 7/1/2017 - 7/31/2017
DMR Version: 2

7/12/2017	145.7	0.07	5.87	1.39	0.15	2.97	
7/13/2017	145.2	0.27	7.74	6.24	0.15	3.47	
7/14/2017	140.5	0.64	7.18	14.60	0.19	4.33	
7/15/2017	134.3		6.07				
7/16/2017	134.3		6.07				
7/17/2017	134.3	0.06	6.07	1.07	0.16	2.86	
7/18/2017	131.1	0.28	6.03	6.04	0.16	3.45	
7/19/2017	122.9	0.55	5.31	10.74	0.15	2.93	
7/20/2017	102.1	0.17	4.04	3.45	0.17	3.45	
7/21/2017	78.3	0.43	4.09	9.06	0.15	3.16	
7/22/2017	66.0		3.26				
7/23/2017	66.0		3.26				
7/24/2017	66.0	0.05	3.26	0.85	0.22	3.75	
7/25/2017	65.7	0.12	3.19	2.43	0.18	3.65	
7/26/2017	66.9	0.22	3.38	4.41	0.16	3.20	
7/27/2017	83.5	0.18	3.04	3.71	0.14	2.89	
7/28/2017	135.6	0.24	2.70	4.91	0.16	3.28	
7/29/2017	150.8		0.50				
7/30/2017	150.8						
7/31/2017		0.03		0.50	0.14	2.31	

Set: 3 of 4

Parameter	Total Copper	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)
Mon. Loc.	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)	Final Effluent (1)
Limit	(report) ug/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
7/1/2017		*G	*G	*G	*G	*G	*G
7/2/2017							
7/3/2017							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2019 06 18 YEAR MO DAY
--	---	---	---	---	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 7/1/2017 - 7/31/2017
DMR Version: 2

7/4/2017							
7/5/2017	<50.000						
7/6/2017							
7/7/2017							
7/8/2017							
7/9/2017							
7/10/2017							
7/11/2017							
7/12/2017							
7/13/2017	<50.000						
7/14/2017							
7/15/2017	<50.000						
7/16/2017							
7/17/2017							
7/18/2017							
7/19/2017							
7/20/2017							
7/21/2017	<50.000						
7/22/2017							
7/23/2017							
7/24/2017							
7/25/2017							
7/26/2017							
7/27/2017							
7/28/2017							
7/29/2017							
7/30/2017							
7/31/2017							

Set: 4 of 4

Parameter	Fecal Coliform	Fecal Coliform	pH	pH	Dissolved Oxygen		
-----------	----------------	----------------	----	----	------------------	--	--

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2019	06	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 7/1/2017 - 7/31/2017
DMR Version: 2

Mon. Loc.	Final Effluent (1)	Fecal Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)		
Limit	400 #/100mL	(report) #/100mL	6.5 SU	9.0 SU	6.0 mg/L		
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily	Maximum Daily	Minimum Daily		
7/1/2017	0.0						
7/2/2017	14.8						
7/3/2017	14.8	10	7.54	7.5	8.4		
7/4/2017	16.3	5	7.04	7.0	8.3		
7/5/2017	21.7	39	7.02	7.0	8.3		
7/6/2017	19.0	16	7.23	7.2	8.3		
7/7/2017	20.1	23	7.35	7.4	8.0		
7/8/2017	21.6						
7/9/2017	21.6						
7/10/2017	21.6	16	7.2	7.2	8.3		
7/11/2017	21.0	21	7.18	7.2	7.9		
7/12/2017	21.6	20	7.57	7.6	7.8		
7/13/2017	20.6	21	7.11	7.1	7.8		
7/14/2017	19.3	33	7.14	7.1	7.7		
7/15/2017	17.4						
7/16/2017	17.4						
7/17/2017	17.4	14	7.29	7.3	8.2		
7/18/2017	14.7	24	7.27	7.3	8.0		
7/19/2017	12.6	16	7.38	7.4	7.6		
7/20/2017	11.2	15	7.47	7.5	7.6		
7/21/2017	10.7	20	7.33	7.3	7.6		
7/22/2017	10.1						
7/23/2017	10.1						
7/24/2017	10.1	6	7.3	7.3	7.9		
7/25/2017	12.0	11	7.35	7.4	8.1		
7/26/2017		9	7.39	7.4	7.8		
7/27/2017		12	7.53	7.5	7.7		
7/28/2017		15	7.48	7.5	7.6		
7/29/2017							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2019 06 18
--	---	---	---	---------------------------------	------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 7/1/2017 - 7/31/2017
DMR Version: 2

7/30/2017							
7/31/2017		14	7.21	7.2	8.1		

DMR Instructions:

DMR Comments: (none)

- **Set 1 DMR Value Comments:**
- Date: 7/3/2017 12:00:00 AM, Column 6 Comment: High blank depletion due to bad nutrient water.
- Date: 7/6/2017 12:00:00 AM, Column 6 Comment: High blank depletion due to bad nutrient water.
- Date: 7/6/2017 12:00:00 AM, Column 7 Comment: High blank depletion due to bad nutrient water.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2019	06	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY