

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	45 mg/L	1200 lbs/day	(report) mg/L	(report) lbs/day	34 mg/L	910 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
3/1/2021	1.46	8.00	97.69	8.08	105.94	7.60	92.8
3/2/2021	1.65	6.80	93.62	8.08	105.96	7.56	104.1
3/3/2021	1.65	8.00	110.21	8.08	106.30	8.40	115.7
3/4/2021	1.62	8.00	108.03	8.08	106.40	9.90	133.7
3/5/2021	1.50	9.60	120.18	7.78	103.40	11.10	139.0
3/6/2021	1.45			7.06	95.94		
3/7/2021	1.41			7.06	95.94		
3/8/2021	1.47	8.00	97.75	7.06	95.94	9.00	110.0
3/9/2021	1.68	6.80	95.34	7.06	94.95	7.21	101.1
3/10/2021	1.66	8.00	110.72	7.44	99.11	6.50	90.0
3/11/2021	1.72	6.50	93.01	7.58	100.52	6.30	90.1
3/12/2021	1.66	6.00	82.88	7.34	95.72	5.60	77.4
3/13/2021	1.48			7.88	102.88		
3/14/2021	1.35			7.88	102.88		
3/15/2021	1.39	8.00	92.80	7.88	102.88	9.50	110.2
3/16/2021	1.60	8.70	116.15	8.14	111.20	9.00	120.2
3/17/2021	1.62	8.70	117.74	8.10	112.17	9.23	124.9
3/18/2021	1.56	5.30	69.05	7.36	102.90	8.10	105.5
3/19/2021	1.64	8.70	118.65	7.55	105.62	7.80	106.4
3/20/2021	1.47			6.81	95.27		
3/21/2021	1.33			6.81	95.27		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

3/22/2021	1.73	9.30	134.41	6.81	95.27	9.90	143.1
3/23/2021	1.71	8.50	121.02	5.85	77.86	8.60	122.4
3/24/2021	1.71	5.00	71.38	5.15	67.03	12.15	173.5
3/25/2021	1.59	6.25	82.67	5.05	64.54	11.80	156.1
3/26/2021	1.60	5.00	66.89	4.75	60.01	15.00	200.7
3/27/2021	1.36			4.75	57.10		
3/28/2021	1.24			4.75	57.10		
3/29/2021	1.26	4.50	47.33	4.75	57.10	9.80	103.1
3/30/2021	1.60	5.00	66.87	4.75	62.90	11.20	149.8
3/31/2021	1.57	4.50	58.94			13.00	170.27

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) mg/L	(report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
3/1/2021	117.0	0.30	3.66	0.27	3.30		
3/2/2021	120.5	0.30	4.13	0.21	2.89		
3/3/2021	119.9	0.30	4.13	0.25	3.44		
3/4/2021	114.7	0.30	4.05	0.23	3.11	5.5	0.074
3/5/2021	106.0	0.30	3.76	0.25	3.13		
3/6/2021	93.7						
3/7/2021	93.7						
3/8/2021	93.7	0.30	3.67	0.34	4.16		
3/9/2021	93.8	0.30	4.21	0.32	4.49		
3/10/2021	97.6	0.30	4.15	0.27	3.74		
3/11/2021	104.6	0.30	4.29	0.23	3.29		
3/12/2021	107.6	0.30	4.14	0.24	3.32	6.7	0.093

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 	DATE YEAR MO DAY
--	---	--	--	----------------------------	---------------------------------

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 4/13/2021 4:32 PM

Page 2 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

3/13/2021	113.4						
3/14/2021	113.4						
3/15/2021	113.4	0.30	3.48	0.29	3.36	7	0.081
3/16/2021	120.0	0.30	4.01	0.24	3.20		
3/17/2021	120.5	0.30	4.06	0.27	3.65		
3/18/2021	130.2	0.30	3.91	0.24	3.13		
3/19/2021	140.3	0.30	4.09	0.25	3.41		
3/20/2021	159.1					7.6	0.093
3/21/2021	159.1						
3/22/2021	159.1	2.70	39.02	0.25	3.61		
3/23/2021	151.1	9.95	141.67	0.24	3.42		
3/24/2021	156.6	3.54	50.54	0.18	2.57	8.6	0.123
3/25/2021	156.0	0.66	8.73	0.17	2.25		
3/26/2021	156.0	2.56	34.25	0.18	2.41		
3/27/2021	136.6						
3/28/2021	149.5						
3/29/2021	149.5	5.13	53.96	0.23	2.42		
3/30/2021	161.1	9.30	124.38	0.23	3.08		
3/31/2021		2.58	33.79	0.15	2.02		

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)
Limit	(report) ng/L	(report) lbs/day	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
3/1/2021	*G	*G	*G	*G	*G	*G	
3/2/2021							
3/3/2021							
3/4/2021							<5.000

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE
--	---	---	---	---------------------------------	--------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

3/5/2021							
3/6/2021							
3/7/2021							
3/8/2021							
3/9/2021							
3/10/2021							
3/11/2021							
3/12/2021							<5.000
3/13/2021							
3/14/2021							
3/15/2021							<5.000
3/16/2021							
3/17/2021							
3/18/2021							
3/19/2021							
3/20/2021							<5.000
3/21/2021							
3/22/2021							
3/23/2021							
3/24/2021							5.2
3/25/2021							
3/26/2021							
3/27/2021							
3/28/2021							
3/29/2021							
3/30/2021							
3/31/2021							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
-----------	--------------	----------------	----------------	----------------------------------	----------------------------------	-------------------------------	-------------------------------

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) ug/L	(report) lbs/day	(report) ng/L	(report) lbs/day	(report) ng/L	(report) lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
3/1/2021				*G	*G	*G	*G
3/2/2021							
3/3/2021							
3/4/2021	<0.068	<2.000	<0.027				
3/5/2021							
3/6/2021							
3/7/2021							
3/8/2021							
3/9/2021							
3/10/2021							
3/11/2021							
3/12/2021	<0.069	<2.000	<0.028				
3/13/2021							
3/14/2021							
3/15/2021	<0.058	<2.000	<0.023				
3/16/2021							
3/17/2021							
3/18/2021							
3/19/2021							
3/20/2021	<0.061	<2.000	<0.025				
3/21/2021							
3/22/2021							
3/23/2021							
3/24/2021	0.074	<2.000	<0.029				
3/25/2021							
3/26/2021							
3/27/2021							
3/28/2021							
3/29/2021							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE
--	---	---	---	---	----------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

3/30/2021							
3/31/2021							

Set: 5 of 6

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis (2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL	(report) #/100mL	(report) %	6.5 SU	9.0 SU	5.0 mg/L	(report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
3/1/2021	1.5	1	96.226	7.08	7.1	9.5	<4.600
3/2/2021	1.5	1	98.152	7.35	7.4	9.8	
3/3/2021	1.5	1	96.774	7.29	7.3	9.5	
3/4/2021	1.5	1	96.97	7.21	7.2	9.5	
3/5/2021	1.5	7.5	96	7.23	7.2	9.5	
3/6/2021	1.1						
3/7/2021	1.1						
3/8/2021	1.1	1	97.143	6.89	6.9	9.9	
3/9/2021	1.1	1	96.667	6.92	6.9	9.6	
3/10/2021	1.1	1	96.154	7.23	7.2	9.5	
3/11/2021	1.3	1	96.684	7.06	7.1	9.1	
3/12/2021	1.3	2	97.414	7.04	7.0	9.2	
3/13/2021	1.1						
3/14/2021	1.1						
3/15/2021	1.1	1	97.333	7.03	7.0	9.8	
3/16/2021	1.1	1	96.801	7.1	7.1	9.6	
3/17/2021	1.1	2	95.817	7.21	7.2	9.4	
3/18/2021	1.0	1	97.634	7.09	7.1	9.2	
3/19/2021	1.0	1	96.979	7.14	7.1	9.4	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE YEAR MO DAY
--	---	--	--	---

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 4/13/2021 4:32 PM

Page 6 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

3/20/2021	1.0						
3/21/2021	1.0						
3/22/2021	1.0	1	89.891	7.09	7.1	9.5	
3/23/2021	1.0	1	96.627	7.03	7.0	8.9	
3/24/2021	1.0	1	97.222	6.95	7.0	8.7	
3/25/2021	1.0	1	91.319	7.06	7.1	8.8	
3/26/2021		1	95.37	7.19	7.2	8.7	
3/27/2021							
3/28/2021							
3/29/2021		1	99.055	7.06	7.1	9.1	
3/30/2021		1	96.875	6.92	6.9	8.9	
3/31/2021		1	96.959	6.88	6.9	8.9	

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl) Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(report) lbs/day						
Stat. Base	Maximum Daily						
3/1/2021	<0.0561697						
3/2/2021							
3/3/2021							
3/4/2021							
3/5/2021							
3/6/2021							
3/7/2021							
3/8/2021							
3/9/2021							
3/10/2021							
3/11/2021							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

3/12/2021							
3/13/2021							
3/14/2021							
3/15/2021							
3/16/2021							
3/17/2021							
3/18/2021							
3/19/2021							
3/20/2021							
3/21/2021							
3/22/2021							
3/23/2021							
3/24/2021							
3/25/2021							
3/26/2021							
3/27/2021							
3/28/2021							
3/29/2021							
3/30/2021							
3/31/2021							

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	1.54	1.73	MGD	*****	*****	*****			Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	94.49	112.17	lbs/day	*****	7.09	8.14	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	800 Maximum Monthly Average	1200 Maximum 7-Day Average		*****	30 Maximum Monthly Average	45 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	123.46	161.05	lbs/day	*****	9.31	15	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	670 Maximum Monthly Average	910 Maximum 7-Day Average		*****	25 Maximum Monthly Average	34 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	23.74	141.66	lbs/day	*****	1.77	9.95	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	99 Maximum Monthly Average	***** Maximum Daily		*****	3.7 Maximum Monthly Average	***** Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED							

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	3.19	4.48	lbs/day	*****	0.24	0.34	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	***** Maximum Daily		*****	0.5 Maximum Monthly Average	***** Maximum Daily			5X Weekly	24-Hr Composite
Total Copper (01042) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.09	0.123	lbs/day	*****	7.08	8.6	ug/L		Weekly	24-Hr Composite
	PERMIT REQUIREMENT	0.3 Maximum Monthly Average	0.82 Maximum Daily		*****	11 Maximum Monthly Average	31 Maximum Daily			Weekly	24-Hr Composite
Total Mercury (71900) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*G	*G	lbs/day	*****	*G	*G	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X) Lab ID:	SAMPLE MEASUREMENT	*G	*****	lbs/day	*****	*G	*****	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculation
Total Nickel (01067) Final Effluent (1)	SAMPLE MEASUREMENT	<0.066	0.074	lbs/day	*****	<5.04	5.2	ug/L		Quarterly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED							

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			Quarterly	24-Hr Composite
Total Selenium (01147) Final Effluent (1)	SAMPLE MEASUREMENT	<0.026	<0.029	lbs/day	*****	<2.0	<2.0	ug/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	0.15 Maximum Monthly Average	***** Maximum Daily		*****	5.7 Maximum Monthly Average	***** Maximum Daily			Monthly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS) (51526) Final Effluent (1)	SAMPLE MEASUREMENT	*G	*G	lbs/day	*****	*G	*G	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			2X Annually	Grab
Perfluorooctanoic Acid (PFOA) (51521) Final Effluent (1)	SAMPLE MEASUREMENT	*G	*G	lbs/day	*****	*G	*G	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			2X Annually	Grab
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****		*****	1.18	1.5	#/100mL		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
Total Suspended Solids Minimum % Removal	SAMPLE MEASUREMENT	*****	*****		96.35	*****	89.89	%		Monthly	Calculation

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED							

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 3/1/2021 - 3/31/2021
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
(81011) Percent Removal (K) Lab ID:	PERMIT REQUIREMENT	*****	*****		85 Minimum Monthly % Removal	*****	***** Minimum Daily % Removal			Monthly	Calculation
pH (00400) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		6.88	*****	7.35	SU		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		8.67	*****	*****	mg/L		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		5.0 Minimum Daily	*****	*****			5X Weekly	Grab
Bis(2-Ethylhexyl) Phthalate (39100) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	<0.05616	<0.05616	lbs/day	*****	<4.60	<4.60	ug/L		Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.82 Maximum Monthly Average	***** Maximum Daily		*****	31 Maximum Monthly Average	***** Maximum Daily			Monthly	24-Hr Composite

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.			TELEPHONE		DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	