

Trace Analytical Laboratories, Inc.
2241 Black Creek Road
Muskegon, MI 49444-2673



231-773-5998 Phone
888-979-4469 Fax
www.trace-labs.com

May 01, 2026

Patrick Miller
Cadillac, City of
1121 Plett Rd.
Cadillac, MI 49601

RE: Trace Project 26E0032
Client Project NPDES Monthly Requirements- April 2026

Enclosed are your analytical results. The results of this report relate only to the samples listed in the body of this report.

All reports were examined through Trace's validation process to ensure that requirements for quality and completeness were satisfied. All reported analytical results were obtained in accordance with the methods referenced on the reports. Every practical effort was made to meet the reporting limit specifications for this work, however, some results may have raised reporting limits to correct for percent solids.

For clients that require NELAP Accreditation, Trace certifies that these test results meet all requirements of the NELAP Standard, except for those analytes with a "N" notation. These analytes have not been evaluated by NELAP at Trace's discretion and will not be reported unless requested by client.

If you have questions concerning this report, please contact me at 231.773.5998 or by email at tbrewer@trace-labs.com.

Sincerely,

A handwritten signature in black ink that reads "Timothy W. Brewer".

Tim Brewer
Project Manager
Enclosures



TNI EL V1:2016

This report shall not be reproduced, except in full, without the written consent of Trace Analytical Laboratories, Inc.

Trace Analytical Laboratories, Inc.
2241 Black Creek Road
Muskegon, MI 49444-2673



231-773-5998 Phone
888-979-4469 Fax
www.trace-labs.com

SAMPLE SUMMARY

Trace Project ID: 26E0032
Client Project ID: NPDES Monthly Requirements- April 2026

Trace ID	Sample ID	Matrix	Collected By	Date Collected	Date Received
26E0032-01	Effluent	Aqueous	T.Lackzo	04/30/26 12:47	05/01/26 11:32

CERTIFICATE OF ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Trace Analytical Laboratories, Inc.

Trace Analytical Laboratories, Inc.
2241 Black Creek Road
Muskegon, MI 49444-2673



231-773-5998 Phone
888-979-4469 Fax
www.trace-labs.com

ANALYTICAL RESULTS

Trace Project ID: 26E0032
Client Project ID: NPDES Monthly Requirements- April 2026

Trace ID: 26E0032-01 Matrix: Aqueous Date Collected: 04/30/26 12:47
Sample ID: Effluent Date Received: 05/01/26 11:32

PARAMETERS	RESULTS	UNITS	RDL	DILUTION	PREPARED	BY	ANALYZED	BY	NOTES	MCL
------------	---------	-------	-----	----------	----------	----	----------	----	-------	-----

WET CHEMISTRY

Analysis Method: EPA OIA 1677-09

Batch: T182477

Cyanide (Available)	*	110 ug/L	2.0	1	05/01/26	ljs	05/01/26	ljs		5.9
---------------------	---	----------	-----	---	----------	-----	----------	-----	--	-----

CERTIFICATE OF ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Trace Analytical Laboratories, Inc.

Trace Analytical Laboratories, Inc.
2241 Black Creek Road
Muskegon, MI 49444-2673



231-773-5998 Phone
888-979-4469 Fax
www.trace-labs.com

QUALITY CONTROL RESULTS

Trace Project ID: 26E0032

Client Project ID: NPDES Monthly Requirements- April 2026

QC Batch: T182477

Analysis Description: Cyanide, Available

QC Batch Method: EPA OIA 1677-09

Analysis Method: EPA OIA 1677-09

METHOD BLANK: T182477-BLK1

Parameter	Units	Blank Result	Reporting Limit	Notes
Cyanide (Available)	ug/L	<2.0	2.0	

LABORATORY CONTROL SAMPLE: T182477-BS1

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limit	Notes
Cyanide (Available)	ug/L	100.0	101	101	86-118	

CERTIFICATE OF ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Trace Analytical Laboratories, Inc.

AN EXPLANATION OF TERMS AND SYMBOLS WHICH MAY OCCUR IN THIS REPORT

DEFINITIONS

LCS	Laboratory Control Sample
LCSD	Laboratory Control Sample Duplicate
MS	Matrix Spike
MSD	Matrix Spike Duplicate
RPD	Relative Percent Difference
DUP	Matrix Duplicate
RDL	Reporting Detection Limit
MCL	Maximum Contamination Limit
TIC	Tentatively Identified Compound
<, ND or U	Indicates the compound was analyzed for but not detected
*	Indicates a result that exceeds its associated MCL or Surrogate control limits
N	Indicates that the laboratory is not accredited by NELAP for this compound
NA	Indicates that the compound is not available.

NOTE: Samples for volatiles that have been extracted with a water miscible solvent were corrected for the total volume of the solvent/water mixture.
Solid matrices Method Blanks are at 100% solids as such results are the same wet or dry.

CERTIFICATE OF ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Trace Analytical Laboratories, Inc.