

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 5/9/2018 10:29:21 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: BOD Exceedance (Permit No. MI0020257)

Don,

I'm emailing to inform you we had a BOD exceedance on Friday 5-4-2018 on 11.4 mg/L on our limit of 10.0 mg/L.

We believe this is due to seasonal turn over that is currently occurring.

If you have any question feel free to contact me.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841