

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 12/4/2017 11:13:25 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: BOD Violation Permit No MI0020257

Don,

On Monday 11/27 (read on 12/2) we had a BOD violation of 11.1 on our limit of 10 mg/L. I believe the violation is due to a pump malfunction similar to the last time. We are taking steps to bleed that pump off daily. The two sample results prior to the final process are both lower in concentration and we did have some debris in the final sample that day. If you have any questions feel free to contact me.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841