

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 6/15/2017 9:31:15 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: BOD Violation (permit no MI0020257)

Mr. Brady,

Wednesday 6/14 we had a BOD violation of 13 mg/L sampled on 6/9/2017. The refrigerated sampler fan froze up and didn't keep temp. The BOD blank also depleted out .3 mg/L that day.

If you have any questions feel free to contact me.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841