

From: Jeff Dietlin <utilities@cadillac-mi.net>
Sent: 4/11/2019 11:19:47 AM
To: "Popovich, Bradley (DEQ)" <PopovichB@michigan.gov>
Cc: "Barbieri, Charles (CBarbieri@fosterswift.com)" <CBarbieri@fosterswift.com>
Subject: FW: Paragon WO 207982 Final Report Result Inquiry

Bradley,

This is what we received from the Laboratory about the DEHP hit.
From the email they state "that there isn't additional information that would point to whether or not contamination of the sample happened".

They can't confirm one way or another. I think there may be wiggle room here since it was a detection on our first sample only and not any of the subsequent samples.

Jeffrey M. Dietlin

City of Cadillac
Director of Utilities
(231) 779-7346(Direct)
(231)775-0906 (Fax)

From: Cindy Tomaszewski <ctomaszewski@Cadillac-MI.net>
Sent: Thursday, April 11, 2019 10:58 AM
To: Jeff Dietlin <utilities@cadillac-mi.net>
Subject: FW: Paragon WO 207982 Final Report Result Inquiry

Jeff –

This is the response I rec'd regarding the DEHP "hit" in the May 2016 additional monitoring sample.

Let me know if I need follow-up with anything else. Thanks,

Cindy A. Tomaszewski

Lab Supervisor

From: Kaitlin James <kaitlinj@paragonlaboratories.com>
Sent: Wednesday, April 10, 2019 2:44 PM
To: Cindy Tomaszewski <ctomaszewski@Cadillac-MI.net>
Subject: Paragon WO 207982 Final Report Result Inquiry

Hi Cindy,

The analyst looked up the original data package and found that there was no transcription error, the method blank showed no signs of contamination, that the batch QC performed passed acceptability, and that there isn't additional information that would point to whether or not contamination of the sample happened.

Please let me know if you have any further questions.

Thank you and have a great day!

--

Please Note: Paragon Laboratories has updated its pricing for 2019.
Please view our website at www.paragonlaboratories.com to familiarize yourself with the 2019 rates.

If you do not currently have a quotation for 2019 with Paragon Laboratories, you will be subject to our list pricing effective January 14th, 2019.

Sincerely,
Kaitlin James
Drinking Water Account Coordinator

Paragon Laboratories, Inc.
[12649 Richfield Ct.](http://12649 Richfield Ct. Livonia, MI 48150)
Livonia, MI 48150

Phone: 734.469.5622
Fax: 734.462.3911

www.paragonlaboratories.com

This transmission may contain information that is privileged, confidential, and exempt from disclosure. It is intended for the use only by the person to whom it is addressed. If you have received this in error, please (1) do not forward or use this information in any way, and (2) contact me immediately.