



Testing • Research • Consulting

Multiple Analysis Report

Sample: 353137

May 9, 2018

Ms. Amy Vail
City of Cadillac
200 N. Lake St.
Cadillac, MI 49601

RE: PWS ID#: Unavailable
City of Cadillac
Digester #4
1121 Plett Rd.
Cadillac, MI 49601

Dear Ms. Vail:

The following are the result(s) of the test(s) performed on the sample(s) received at HML, Inc. at 10:53 AM, 03/29/2018, and collected at 1:40 PM, 03/28/2018:

<u>TEST - METHOD</u>	<u>RESULT</u>	<u>MDL*</u>	<u>Date Complete</u>
Fecal Coliform-EPA 1680	<1 MPN/g dry	1 MPN/g dry	04/04/2018
Enteric Virus-EPA 625/R-92/013	<1 pfu/4g dry	1 pfu/4g dry	05/04/2018
Solids, total-SM 2540G	0.55%	0.005%	04/03/2018
Salmonella-EPA 1682	<3 MPN/4 g dry	3 MPN/4 g dry	03/31/2018
Helminth Ova-EPA/625/R-92/013	<1 ovum/4g dry	1 ovum/4 g dry	04/26/2018

*Minimum Detection Level

This testing was completed by M.Q. and J.B. Please feel free to contact us if we can be of further service to you.

Sincerely,

Donald A. Hendrickson, Ph.D.
President - Microbiologist
Chemistry Lab #C-18-01
Microbiological Lab #M-18-03

DAH/skp