



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
GAYLORD DISTRICT OFFICE



LIESL EICHLER CLARK  
DIRECTOR

October 16, 2019

CC No. CC-002274

Mr. Doug Langworthy, Assistant Water Resources Supervisor  
Cadillac Wastewater Treatment Plant  
200 North Lake Street  
Cadillac, Michigan 49601

Dear Mr. Langworthy:

SUBJECT: Industrial Pretreatment Program Reconnaissance Inspection  
National Pollutant Discharge Elimination System (NPDES) Permit No. MI0020257  
Designated Name: Cadillac WWTP

On September 24, 2019, staff of the Michigan Department of Environment, Great Lakes, and Energy (EGLE), Water Resources Division (WRD), conducted an Industrial Pretreatment Reconnaissance inspection of Cadillac WWTP, located at 1121 Plett Road, Cadillac, Michigan 49601 (Facility). The purpose of the inspection was to evaluate the Facility's compliance with the Michigan pretreatment requirements in NPDES Permit No. MI0020257, issued August 30, 2019, effective September 1, 2019.

Mr. Doug Langworthy of the City of Cadillac and Ms. Claire Lowe of EGLE participated in the inspection, which included an interview, and a records review of a Categorical Industrial User (CIU). Overall the City of Cadillac appears to maintain detailed pretreatment records, however the following items were identified as deficiencies:

1. Required Action: A review of the permit issued to AAR Cadillac Manufacturing, Inc. (AAR Facility) revealed that permit limits were not applied for the following parameters as required under the categorical limits of 40 CFR Part 433: Nickel, Silver, Cyanide, and Total Toxic Organics (TTO). All the applicable categorical limits listed under Part 433 must be included in the permit limits, except where local limits are more stringent. The most stringent limit must always be applied. The City of Cadillac may authorize a waiver for sampling of a pollutant regulated under the categorical pretreatment standards only if the conditions listed under 40 CFR 403.12(e) are met. Any grant of a monitoring waiver to an Industrial User (IU) must be included in the permit issued by the City of Cadillac.
2. Required Action: The permit issued to AAR Facility includes a discharge limitation for only two of the toxic organics listed Part 433.11. The permit must include the discharge limitation on TTO as required under the categorical standard. The City of Cadillac may, in lieu of monitoring for all toxic organics, allow the permittee to make the certification statement under Part 433.12(a) as part of the required semi-annual reports, if the conditions under Part 433.12 are met.

3. Required Action: The permit issued to AAR Facility does not include an appropriate sample location. Sampling must occur at a point where a representative sample can be obtained and where categorical limits apply. Categorical limits apply to a specific regulated wastestream before mixing with other flows. Therefore, sampling for categorical wastestreams must be obtained before mixing with another wastestream or adjusted categorical limits must be applied according to the combined wastestream formula.
4. Required Action: The City of Cadillac did not always issue violation notices (VN) in a timely manner. The file review and interview revealed that a VN was issued to AAR Facility on August 21, 2019, in response to exceedances of pH limits occurring from March 7, 2019 to March 26, 2019. Under the approved Enforcement Response Plan (ERP) enforcement response, including contact with the IU and a request for information on corrective or preventative action, must occur within 15 days of the City of Cadillac becoming aware of the violation. Enforcement action must be taken according to the ERP. On October 11, 2019, Mr. Langworthy confirmed that the City of Cadillac had begun issuing VNs immediately upon receiving laboratory results.
5. Recommended action: The limits stated in the AAR Facility permit do not include the maximum daily concentration limits as listed under Part 433. Maximum daily limits will apply if sampling occurs more often than once a month. It is recommended that the categorical daily limits are also included in the issued permit, except where local maximum daily concentration limits are applied as the more stringent limit. The most stringent limit must always be applied.
6. Recommended action: The interview portion of the inspection revealed that the City of Cadillac Maximum Allowable Industrial Loading (MAIL) calculations were last updated in 1994. It was also noted that the influent to the City of Cadillac Wastewater Treatment Plant has been significantly altered since this time. It is highly recommended that the MAIL for the wastewater treatment plant is updated based on current conditions.

Thank you for your cooperation in these matters. Please respond to the items listed above by December 16, 2019.

Should you require further information, please contact me at 989-330-4639; [LoweC9@michigan.gov](mailto:LoweC9@michigan.gov); or EGLE, WRD, Gaylord District Office, 2100 West M-32, Gaylord, Michigan 49735-9282

Sincerely,

Claire Lowe  
Gaylord District Office  
Water Resources Division

cc: Mr. Randy Conroy, EGLE