

From: Lowe, Claire (EGLE)
Sent: 2/24/2023 4:40:44 PM
To: "Shattuck, Terri (EGLE)" <ShattuckT@michigan.gov>
Subject: FW: Categorical determination - Cadillac casting - reply
Attachments: MX-5051_20230224_113352.pdf

Hi Terri,

I finally got a process flow diagram from Cadillac Casting. I think that completes our requirements for the categorical determination. I don't see any additional processes in there that should be considered. Let me know if you want to discuss.

Happy Friday!

Thanks,

Claire Lowe

Environmental Quality Analyst
Water Resources Division, Gaylord District Office
Michigan Department of Environment, Great Lakes, and Energy
[989-330-4639](tel:989-330-4639) | LoweC9@Michigan.gov
Michigan.gov/EGLE



From: Erik Olson <eolson@cadillaccasting.com>
Sent: Friday, February 24, 2023 11:48 AM
To: Lowe, Claire (EGLE) <LoweC9@michigan.gov>
Cc: 'utilities@Cadillac-MI.net' <utilities@Cadillac-MI.net>; Patrick Miller <pmiller@cadillac-mi.net>
Subject: RE: Categorical determination - Cadillac casting - reply

CAUTION: This is an External email. Please send suspicious emails to abuse@michigan.gov

Here are my process flow diagrams for the Melt Furnace Scrubber Operations and for our Dust Collection Scrubber Operations.

My notes from previous discussions are that we fall under Part 464.36. These are the two operations we have that are listed.

Thank you and let me know if you have more questions or information needed.

Erik Olsn

From: Lowe, Claire (EGLE) <LoweC9@michigan.gov>
Sent: Thursday, February 23, 2023 9:30 AM
To: Erik Olson <eolson@cadillaccasting.com>
Cc: 'utilities@Cadillac-MI.net' <utilities@Cadillac-MI.net>; Patrick Miller <pmiller@cadillac-mi.net>
Subject: RE: Categorical determination - Cadillac casting - reply

Good Morning Erik,

I just wanted to get in touch regarding the requested process description and diagram to complete the categorical determination for Cadillac Casting. Please submit this information as soon as possible. Our intention is to provide the City of Cadillac with an accurate determination so that the new IU permit issued to you can clearly lay out the expectations for compliance. At the moment, the IU permit does not include limits and requirements that would demonstrate compliance with Part 464. Even though the permit does not include such requirements, Cadillac Casting is still required to meet the limits as stated in Part 464. Having an accurate determination in place will only clarify to you what is already required by the federal pretreatment standards. Please let me know if you have any questions regarding the information required.

Thank you,

Claire Lowe
Environmental Quality Analyst
Water Resources Division, Gaylord District Office
Michigan Department of Environment, Great Lakes, and Energy
[989-330-4639](tel:989-330-4639) | LoweC9@Michigan.gov
Michigan.gov/EGLE



From: Lowe, Claire (EGLE)
Sent: Friday, January 27, 2023 4:12 PM
To: Erik Olson <eolson@cadillaccasting.com>
Cc: 'utilities@Cadillac-MI.net' <utilities@Cadillac-MI.net>; Patrick Miller <pmiller@cadillac-mi.net>
Subject: RE: Categorical determination - Cadillac casting - reply

Erik,

Thank you for the quick response. For item four, the purpose is simply to make sure we understand all of the processes that are producing wastewater. The wastewater flow diagram shows the discharges from the treatment processes, but the effluent limitations are based on processes that produce the wastewater. We have to fully understand both which effluent limits apply and how categorical

wastewater is combined with unregulated and dilute wastestreams to determine (along with other information) what the adjusted effluent limits would be at the sampling point.

This doesn't have to be anything more complicated than a hand drawing, as long as the information is there.

Thank you,

Claire Lowe

Environmental Quality Analyst

Water Resources Division, Gaylord District Office

Michigan Department of Environment, Great Lakes, and Energy

[989-330-4639](tel:989-330-4639) | LoweC9@Michigan.gov

Michigan.gov/EGLE



MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

From: Erik Olson <eolson@cadillaccasting.com>

Sent: Friday, January 27, 2023 3:49 PM

To: Lowe, Claire (EGLE) <LoweC9@michigan.gov>

Cc: 'utilities@Cadillac-MI.net' <utilities@Cadillac-MI.net>; Patrick Miller <pmiller@cadillac-mi.net>

Subject: RE: Categorical determination - Cadillac casting - reply

CAUTION: This is an External email. Please send suspicious emails to abuse@michigan.gov

See below in red

From: Lowe, Claire (EGLE) <LoweC9@michigan.gov>

Sent: Friday, January 27, 2023 3:05 PM

To: Erik Olson <eolson@cadillaccasting.com>

Cc: utilities@cadillac-mi.net; Patrick Miller <pmiller@cadillac-mi.net>; Shattuck, Terri (EGLE) <ShattuckT@michigan.gov>

Subject: Categorical determination - Cadillac casting

Erik,

In follow up to our meeting last year, EGLE is completing a formal categorical determination for Cadillac Casting. To assist us with this process, please could you provide some additional information and clarifications listed below?

1. A description of the products produced by CCI.

Ductile iron castings

2. Facility SIC code(s)

3321

3. A list of any process chemicals used and associated SDS sheets. Included in this, does CCI use any penetrants or dyes as part of testing processes?

We do not use any penetrants or dyes

4. A diagram and written description of the production processes. For guidance, please see the attached example of a production flow diagram.

Will need to produce. What is the purpose relative to wastewater discharge? That diagram has been provided...

5. Please clarify if the slag quench process discharges any wastewater either to the treatment system or sanitary sewer.

The wet slag is recharged with fresh water as evaporation requires. Under normal operating conditions, no water is discharged. Overflow is possible and that water would be taken to our melt wwtp and go through treatment and be co-mingled with the melt scrubber waters.

6. Please confirm if the primary quench scrubber discussed during our meeting refers to a furnace scrubber, which is a quenching type scrubber, or if this refers to a scrubber used in a quenching process.

This scrubber is scrubbing the exhaust air from our cupola iron melting furnace system. It is a quenching type scrubber stage.

7. The melting furnace scrubber includes a series of three scrubbers – does each scrubber produce a wastewater discharge?

All three wastewater discharges lines meet and enter our wwtp system at the same location. The front section of our lamella clarifier called the flash mixer. It allow the flocculant polymer to be mixed ahead of the clarifier..

Thank you for your help with this. Please let me know if any of the above is unclear.

Claire Lowe

Environmental Quality Analyst

Water Resources Division, Gaylord District Office

Michigan Department of Environment, Great Lakes, and Energy

[989-330-4639](tel:989-330-4639) | LoweC9@Michigan.gov

Michigan.gov/EGLE




MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

ATTACHMENT NAME:

MX-5051_20230224_113352.pdf

ATTACHMENT TYPE:

Adobe Portable Document Format (PDF) compound image



Cadillac Casting, Inc.

Dust Collection Scrubber Operations:

Mold making, Pouring, and Shakeout diagram
Including the North WWTP for wet scrubbers
2/23/2023

