

**From:** Lowe, Claire (EGLE)  
**Sent:** 10/20/2021 3:46:08 PM  
**To:** "'Doug Langworthy'" <dlangworthy@Cadillac-MI.net>  
**Subject:** RE: IPP Annual report

Doug,

The influent and effluent should be tested at least once annually for all the pollutants you have local limits for. Arsenic is in your local limits so you should still test influent and effluent for it. For biosolids report the pollutants that are limited by Part 24 for land application: Arsenic, Cadmium, Copper, Lead, Mercury, Nickel, Selenium, Zinc, and Molybdenum.

It may be that the industry that made Arsenic an issue when the local limits were developed is gone. If the data shows that Arsenic isn't a problem in the influent then that's helpful when you come to review the local limits and you may be able to justify removing it.

Thanks,

**Claire Lowe**  
Environmental Quality Analyst  
Water Resources Division, Gaylord District Office  
Michigan Department of Environment, Great Lakes, and Energy  
989-330-4639 | LoweC9@Michigan.gov  
Michigan.gov/EGLE



---

**From:** Doug Langworthy <dlangworthy@Cadillac-MI.net>  
**Sent:** Wednesday, October 20, 2021 11:18 AM  
**To:** Lowe, Claire (EGLE) <LoweC9@michigan.gov>  
**Subject:** RE: IPP Annual report

**CAUTION: This is an External email. Please send suspicious emails to [abuse@michigan.gov](mailto:abuse@michigan.gov)**

Claire,  
After talking with my lab manager, what frequency do we need to test our influent for the missing data? Also we don't test any industry for arsenic. Do we need to still test influent for that?  
Thanks Doug

**Douglas Langworthy**  
Assistant Water Resources Supervisor

City of Cadillac  
231-775-2841

---

**From:** Lowe, Claire (EGLE) <[LoweC9@michigan.gov](mailto:LoweC9@michigan.gov)>  
**Sent:** Thursday, October 7, 2021 3:48 PM  
**To:** Doug Langworthy <[dlangworthy@Cadillac-MI.net](mailto:dlangworthy@Cadillac-MI.net)>  
**Subject:** IPP Annual report

Hi Doug,

I looked over your IPP annual report (apparently I missed this last year) for 2020/21. It looks like you're missing some data from the data monitoring summary. I'm hoping you might have the information to add.

For both 2020 and 2021 you don't report Selenium data for biosolids. This isn't currently in your local limits but is limited by Part 24 for biosolids, so it demonstrates there's no pass through that you would need to add a limit for.

For your influent and effluent data you should report results for anything you have a local limit for. You're missing some data for Arsenic, Cyanide, BTEX, Phenols, and a handful of others that are listed in your local limits. Please add any data you might have for these years to complete the report if possible. If you don't have the data make sure to sample for everything you have a limit for this year.

I also noticed the copper in your influent looks high relative to the local limit and the MAIL. Do you know if that is exceeding the current MAHL? Given that there were some copper NPDES violations since the new permit limit was added I think copper is going to need to be looked at.

Please let me know if you have any data to add on those reports.

Thanks,

Claire Lowe  
Environmental Quality Analyst  
Water Resources Division, Gaylord District Office  
Michigan Department of Environment, Great Lakes, and Energy  
[989-330-4639](tel:989-330-4639) | [LoweC9@Michigan.gov](mailto:LoweC9@Michigan.gov)  
[Michigan.gov](http://Michigan.gov)/EGLE



MICHIGAN DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY