

**From:** Popovich, Bradley (DEQ)  
**Sent:** 9/4/2018 2:27:33 PM  
**To:** "Brady, Donal (DEQ)" <BradyD6@michigan.gov>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Don,

Thank you for your recommendations regarding Cadillac's Asset Management, I'll plan on rolling them forward. Also, I believe that is the case. I will draft up two different sets of seasons and limits for the facility during the pre-public notice period. Also, within the facility maps that you sent me on 7/25/2018. Do you think that the maps they provided are representative of their current disinfection system? I still see no mention of chlorination within the map provided.

Thanks again for all of your help with all of my questions! I appreciate it.

Bradley P.

---

**From:** Brady, Donal (DEQ)  
**Sent:** Wednesday, August 29, 2018 2:25 PM  
**To:** Popovich, Bradley (DEQ) <PopovichB@michigan.gov>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Hi Bradley,

The City of Cadillac still has not submitted sufficient information to document compliance with the NPDES permit Part I, Section A.5 (asset management), specifically, the City has not provided the information requested in 5.a.2) to 5.a.4) in any detail. I think the requirements for these items and annual reporting need to be maintained in the renewed NPDES permit.

I understand the City will have the opportunity to request different seasons (and associated limits) during the draft permit review process and we are going to provide them the revised seasons/limits in a draft permit and not in any other correspondence.

Thanks for the work and correspondence on this. Please let me know if you need anything else from me.



Don Brady, P.E.  
Michigan Department of Environmental Quality  
Water Resources Division  
Cadillac District Office  
120 West Chapin Street  
Cadillac, MI 49601  
[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)  
(231) 876-4478

---

**From:** Popovich, Bradley (DEQ)  
**Sent:** Friday, August 24, 2018 1:59 PM  
**To:** Brady, Donal (DEQ) <[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Hi Don,

Just wanted to check in, as I have drafted more of Cadillac's permit. Have you had a chance to look over my proposed questions below?

Thanks!

Bradley P.

---

**From:** Popovich, Bradley (DEQ)  
**Sent:** Thursday, August 9, 2018 2:37 PM  
**To:** Brady, Donal (DEQ) <[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Donal,

I believe I could take a look at the current Asset Management Template language and see if it would be appropriate to change the language to fit Cadillac's current Asset Management Plan. Once you have reviewed the City's AM submittal (was it an annual report or their AM plan?) please let me know if it meets the permit requirements/is sufficient and based on that we can decide what to do with reissuance permit language. Does this make sense? If not, please let me know. I'm looking forward to hearing back from you!

Regards,

**Bradley Popovich**  
Environmental Quality Analyst  
Water Resources Division  
Municipal Permits Unit  
Michigan Department of Environmental Quality  
**(517) 284-6656**  
[PopovichB@Michigan.gov](mailto:PopovichB@Michigan.gov)  
Monday – Friday 8:00-4:30

---

**From:** Brady, Donal (DEQ)  
**Sent:** Thursday, August 9, 2018 1:53 PM  
**To:** Popovich, Bradley (DEQ) <[PopovichB@michigan.gov](mailto:PopovichB@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Hi Bradley,

No worries. O.K. on the season question. The contested case was related to a dispute about the NPDES permit asset management language. The City did not want that language in the permit. We just received an asset management submittal from Cadillac, which I expect is the first asset management submittal of any substance we have received. I have not looked at what they submitted yet. Is permit staff maintaining asset management language in the new permits that will renew those permits that contained the initial NPDES asset management requirements? If permit staff are including some asset management verbiage in the permit renewals, this standard verbiage may be sufficient. Otherwise, I think we should consider asking the City of Cadillac for additional asset management annual reports to be submitted for DEQ review. When are you targeting to have the draft permit complete? I could provide more input on asset management, once I review what the City recently submitted and see how developed their program is.



Don Brady, P.E.  
Michigan Department of Environmental Quality  
Water Resources Division  
Cadillac District Office  
120 West Chapin Street  
Cadillac, MI 49601  
[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)  
(231) 876-4478

---

**From:** Popovich, Bradley (DEQ)  
**Sent:** Thursday, August 9, 2018 1:01 PM  
**To:** Brady, Donal (DEQ) <[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Don,

Additionally, It seems that during the last permit reissuance there was a contested case. Do you know anything about that? Is there anything that I should take into consideration during this reissuance?

Thank you for all of your help so far, I appreciate it!

Bradley P.

---

**From:** Popovich, Bradley (DEQ)  
**Sent:** Thursday, August 9, 2018 1:00 PM  
**To:** Brady, Donal (DEQ) <[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Good Afternoon Don,

I apologize for the delay. I am waiting to hear back internally on what to do regarding our question below. I'll let you know as soon as we figure it out! Also, are you aware if Cadillac has submitted their

Asset Management Plan? I see that they have been submitting their reports. Also, if they did submit it was the plan approved?

Thanks!

**Bradley Popovich**

Environmental Quality Analyst  
Water Resources Division  
Municipal Permits Unit  
Michigan Department of Environmental Quality  
**(517) 284-6656**  
[PopovichB@Michigan.gov](mailto:PopovichB@Michigan.gov)  
Monday – Friday 8:00-4:30

---

**From:** Brady, Donal (DEQ)  
**Sent:** Friday, July 27, 2018 12:08 PM  
**To:** Popovich, Bradley (DEQ) <[PopovichB@michigan.gov](mailto:PopovichB@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Hi Bradley, O.K. Do you think we could or should get a jump on the facility review/comments by sending them the Table 3 mentioned in your email below? If it is O.K. with you, and I can pull Table 3 off MiWaters, I can send it to the City. Thx!



Don Brady, P.E.  
Michigan Department of Environmental Quality  
Water Resources Division  
Cadillac District Office  
120 West Chapin Street  
Cadillac, MI 49601  
[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)  
(231) 876-4478

---

**From:** Popovich, Bradley (DEQ)  
**Sent:** Thursday, July 26, 2018 8:24 AM  
**To:** Brady, Donal (DEQ) <[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Hi Don!

Of course. The current seasons are: May-September, October-November, December-March, and April. It seems like Philip modeled the alternative seasons are: June-September, October-November, December-March, and April-May. I believe, according to the Conventional WQBEL Memo this was the rationale for the change:

“In the spring of 2017 the DEQ’s Cadillac District asked if it would be possible to remove the month of May from the summer season of the Cadillac WWTP permit. Given Cadillac’s northern location, it is possible that the cold weather season could extend into May. Cold temperatures have the potential to limit ammonia removal via nitrification at the treatment facility and may cause effluent limit violations. Table 3 is provided to summarize what potential effluent limit recommendations would be under the following seasonal divisions: June-September, October-November, December-March, and April-May.”

This was the only mention I was able to find about why the alternatives were proposed. Does this help answer your question?

Regards,

**Bradley Popovich**

Environmental Quality Analyst

Water Resources Division

Municipal Permits Unit

Michigan Department of Environmental Quality

**(517) 284-6656**

[PopovichB@Michigan.gov](mailto:PopovichB@Michigan.gov)

Monday – Friday 8:00-4:30

---

**From:** Brady, Donal (DEQ)

**Sent:** Wednesday, July 25, 2018 5:43 PM

**To:** Popovich, Bradley (DEQ) <[PopovichB@michigan.gov](mailto:PopovichB@michigan.gov)>

**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Hi Bradley,

Can you please tell me what alternative seasons were requested by the facility? Thanks!



Don Brady, P.E.

Michigan Department of Environmental Quality

Water Resources Division

Cadillac District Office

120 West Chapin Street

Cadillac, MI 49601

[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)

(231) 876-4478

---

**From:** Popovich, Bradley (DEQ)

**Sent:** Wednesday, July 25, 2018 9:25 AM

**To:** Brady, Donal (DEQ) <[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)>

**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Good Morning Don,

I apologize for the delay (I have been out of the office for the past few days). I have spoken with some more senior permit writers and they recommended I draft the reissued permit to include the alternative seasons (the ones that were requested by the facility) and see if the facility has any comments during PPN. Does this work with what you had in mind? If not, please let me know and we can discuss what to do further.

Bradley P.

---

**From:** Brady, Donal (DEQ)  
**Sent:** Friday, July 20, 2018 9:19 AM  
**To:** Popovich, Bradley (DEQ) <[PopovichB@michigan.gov](mailto:PopovichB@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Thanks for sending this email Bradley. Do you also plan to discuss adjusting the permit limit seasons with the plant at some point during the renewal process?



Don Brady, P.E.  
Michigan Department of Environmental Quality  
Water Resources Division  
Cadillac District Office  
120 West Chapin Street  
Cadillac, MI 49601  
[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)  
(231) 876-4478

---

**From:** Popovich, Bradley (DEQ)  
**Sent:** Thursday, July 19, 2018 1:33 PM  
**To:** [dlangworthy@Cadillac-MI.net](mailto:dlangworthy@Cadillac-MI.net); [utilities@cadillac-mi.net](mailto:utilities@cadillac-mi.net)  
**Cc:** Brady, Donal (DEQ) <[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)>  
**Subject:** RE: Cadillac WWTP NPDES Permit Renewal

Good Afternoon Doug and Jeff,

I am currently in the process of reissuing Cadillac WWTP's NPDES Individual permit and have a few things that I'd like to follow up with you on. Please reference the email correspondence below in which Don requests upgraded flow diagrams that include use of UV. Additionally, in order to move further with the permitting process an updated narrative description that includes mention of UV's involvement within your treatment system is needed.

Please provide the updated flow diagram and narrative description to me by **August 2, 2018**. If you have any questions, comments, or concerns please let me know, I'd love to help in any way that I can!

**Bradley Popovich**  
Environmental Quality Analyst

Water Resources Division  
Municipal Permits Unit  
Michigan Department of Environmental Quality  
**(517) 284-6656**  
[PopovichB@Michigan.gov](mailto:PopovichB@Michigan.gov)  
Monday – Friday 8:00-4:30

---

**From:** Brady, Donal (DEQ)  
**Sent:** Monday, July 16, 2018 2:54 PM  
**To:** Popovich, Bradley (DEQ) <[PopovichB@michigan.gov](mailto:PopovichB@michigan.gov)>  
**Subject:** FW: Cadillac WWTP NPDES Permit Renewal

FYI.



Don Brady, P.E.  
Michigan Department of Environmental Quality  
Water Resources Division  
Cadillac District Office  
120 West Chapin Street  
Cadillac, MI 49601  
[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)  
(231) 876-4478

---

**From:** Brady, Donal (DEQ)  
**Sent:** Friday, January 5, 2018 6:18 PM  
**To:** Doug Langworthy <[dlangworthy@Cadillac-MI.net](mailto:dlangworthy@Cadillac-MI.net)>; [lab@cadillac-mi.net](mailto:lab@cadillac-mi.net)  
**Cc:** Schmitt, Glen (DEQ) <[SCHMITTG1@michigan.gov](mailto:SCHMITTG1@michigan.gov)>  
**Subject:** Cadillac WWTP NPDES Permit Renewal

Hi Doug and Cindy,

The DEQ is working on the NPDES permit renewal for the Cadillac WWTP and a couple questions came up.

1. Copper analysis detection limit – As Cindy and I discussed, the current detection limit is 50 ug/L but the plant's lab may be able to achieve a lower limit. The new permit will likely include limits for copper lower than 50 ug/L. Could you please look into this and let me know what detection limit you think you could achieve? If you would like to start conducting the copper analysis with the lower limit, DEQ's permit staff will consider these results.
2. UV Disinfection - The process flow diagrams included with the renewal application showed chlorine disinfection. I know the plant uses UV. Do you have any updated diagrams you could send us?

Thanks for looking into this. Please let me know if you have any questions.



Don Brady, P.E.  
Michigan Department of Environmental Quality  
Water Resources Division  
Cadillac District Office  
120 West Chapin Street  
Cadillac, MI 49601  
(231) 876-4478  
[BradyD6@michigan.gov](mailto:BradyD6@michigan.gov)