

June 16, 2025

Council Communication

Re: Filter Pipe Replacement

A recent inspection revealed that a tertiary filter at the wastewater treatment plant was starting to leak at a pipe fitting that penetrates the tank. Upon investigation it was noted that all three filters were failing at these pipe penetrations. After consulting with the manufacturer, AquaDisc, it was determined that this was a common failing point on these filters. Replacement parts have been ordered to repair these pipe penetrations.

The installation of these parts requires a qualified company to install them. After contacting several qualified companies only Monarch Welding & Engineering submitted a quote. This installation of parts will cost \$11,137.

This repair is urgent, and it is strongly recommended by plant staff that the repair is immediately authorized so that the contractor can be scheduled as soon as possible.

Recommended Action

It is recommended that the City Council waive competitive bidding and award Monarch Welding & Engineering, Inc the sum of \$11,137 to repair the piping in three Aqua Disc tertiary filters. Funds are available in the Water and Sewer Fund.

PROPOSAL



Sent via email
pmiller@cadillac-mi.net

Patrick Miller
City of Cadillac

City of Cadillac – Filter pipe replacement Monarch Proposal: 25-2473

Dear Patrick Miller:

We thank you for this inquiry and are pleased to submit our proposal for your consideration. We propose to furnish the necessary labor, equipment, and material to install filter piping on three filters with three remobilizations.

Lump Sum..... \$11,137.00

Work Scope:

- Mobilize (three separate occasions in the summer of 2025)
- Remove three pipe spools
- Weld in three stainless steel pipe spools
- Use of life safety for going in filter
- Demobilize

Work Clarifications:

- Work to be done on a schedule, no weekends or holidays unless specifically stated.
- Full access to the work area with no interruptions.
- Lockout by GENERAL CONTRACTOR/OWNER
- Scaffolding, if required, by GENERAL CONTRACTOR/OWNER
- Electrical by OTHERS
- Insulation by OTHERS
- Paint by OTHERS
- Abatement by OTHERS

Proposal Clarifications:

- This proposal is valid for 30 days and replaces any previous revisions to the same proposal.
- Payment terms net 30, a finance charge will be added to late payments.
- Monarch Welding & Engineering, Inc takes EXCEPTION to ANY and ALL Liquidated and / or Consequential Damages.
- Safety expectations shall be reviewed and agreed upon before the start of the project.
- Proposal based on (1) one mobilization and (1) one demobilization.
- Proposal as written includes NO engineering, permits or inspection costs.
- Proposal assumes General Contractor/Owner will provide utilities (water, electricity, compressed air, etc.) necessary to perform work, as well as break room and toilet facilities.
- Additional terms and conditions of this proposal are located at www.monarchwelding.com/proposalterms and are incorporated herein by this reference.

www.monarchwelding.com



Thank you in advance for your consideration. Should there be questions and/or additional information necessary to evaluate our proposal, please contact me for further details. We look forward to your favorable response.

Sincerely,

Samantha Savich

MONARCH WELDING & ENGINEERING, INC.
519 W. Hackley Ave
Muskegon, MI 49444