

**From:** Smith, Christian (EGLE)  
**Sent:** 5/4/2026 4:14:34 PM  
**To:** "Jeff Dietlin" <utilities@cadillac-mi.net>  
**Cc:** "pmiller@cadillac-mi.net" <pmiller@cadillac-mi.net>; "Campbell, Sarah (EGLE)" <Campbells32@michigan.gov>; "Tavalire, Anne (EGLE)" <TavalireA@michigan.gov>; "Starry, Victoria (EGLE)" <StarryV@michigan.gov>  
**Subject:** 2026 Cadillac WWTP Biosolids PFAS Letter  
**Attachments:** Cadillac WWTP Class A EQ Letter\_Interim\_Strategy\_2026.pdf

Concerning your submission: Biosolids PFAS Monitoring Report:

Link to submission: <https://mienviro.michigan.gov/nform/app/#/submissionversion/5588582d-a04d-483c-b9e6-28dbeefa4e71/overview>

Hi Jeff,

Attached is your letter regarding the 2026 Biosolids PFAS Monitoring Report for the Cadillac Wastewater Treatment Plant. Feel free to reach out with any questions.

Best,

Christian Smith  
**Christian Smith, M.S.** (he/him)  
Environmental Quality Analyst  
Emerging Pollutants Section – Water Resources Division  
Michigan Department of Environment, Great Lakes, and Energy  
Telephone number: 517-257-0251 (cell); [SmithC186@michigan.gov](mailto:SmithC186@michigan.gov)  
[Follow Us](#) | [Michigan.gov/EGLE](https://Michigan.gov/EGLE)



ATTACHMENT NAME:

Cadillac WWTP Class A EQ Letter\_Interim\_Strategy\_2026.pdf

ATTACHMENT TYPE:

Adobe Portable Document Format (PDF) compound image



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
WATER RESOURCES DIVISION



PHILLIP D. ROOS  
DIRECTOR

May 4, 2026

VIA EMAIL

Jeff Dietlin, Director of Utilities  
Cadillac Wastewater Treatment Plant  
1121 Plett Rd  
Cadillac, MI 49061

Dear Jeff Dietlin:

SUBJECT: Biosolids and PFAS Monitoring Results – Exceptional Quality  
National Pollutant Discharge Elimination System (NPDES)  
Permit No. MI0020257  
Designated Name: Cadillac WWTP

On March 13, 2026, the Cadillac Wastewater Treatment Plant (WWTP) submitted results to the Department of Environment, Great Lakes, and Energy (EGLE), Water Resources Division (WRD), of a biosolids sample collected from the Cadillac WWTP on February 25, 2026, was analyzed for Per- and Polyfluoroalkyl substances (PFAS). The submittal was in accordance with the requirements set forth in the WRD's *Interim Strategy for Land Application of Biosolids Containing PFAS (Interim Strategy)* and the Residuals Management Program (RMP) Modification letter dated December 27, 2023, which became effective January 1, 2024, and part of the WWTP's approved RMP.

The laboratory results indicate that the PFAS analytes, Perfluorooctane Sulfonate (PFOS) and Perfluorooctanoic Acid (PFOA), concentrations in biosolids were less than (" $<$ ") 1.7 micrograms per kilogram ( $\mu\text{g}/\text{kg}$ ) (parts per billion [ppb]) for PFOS and  $<1.7 \mu\text{g}/\text{kg}$  for PFOA, respectively. Based on the combined analytical results for PFOS and PFOA in biosolids being less than  $20 \mu\text{g}/\text{kg}$ , no additional actions are required at this time and land application is approved to proceed as normal in accordance with the conditions of the Interim Strategy.

Please note the following PFAS requirements for Cadillac WWTP when land applying bulk biosolids in Michigan:

- Provide the most current PFOS and PFOA analytical results and additional information specific to PFAS and biosolids in Michigan to landowners and farmers prior to the land application of biosolids. Information on notification requirements and sample templates can be obtained from [Michigan Biosolids PFAS-related information and links](#).

- Continue to collect a minimum of one (1) annual biosolids PFAS sample prior to initial land application each **calendar year**, unless otherwise notified by the WRD's Biosolids Program staff. **Submit all PFAS data to EGLE WRD via MiEnviro Portal a minimum of two weeks prior to land application.**
- Please note that beginning calendar year 2024, generators who wish to obtain and/or maintain EQ designation for biosolids, must have **combined** PFOS and PFOA concentrations below 20 µg/kg. To demonstrate compliance with this standard, samples must be taken and analyzed quarterly. These requirements are in addition to, and do not supersede or replace, in any way, other requirements for EQ designation as defined in the state and federal biosolids regulations.

EGLE continues to support a source reduction approach to reducing PFAS concentrations in effluent and biosolids generated from municipal WWTPs. Information on sampling and investigating potential PFAS sources can be obtained at [Industrial Pretreatment Program \(IPP\) PFAS Initiative](#). This link contains numerous documents, including Frequently Asked Questions, Wastewater PFAS Sampling Guidance, and Recommended PFAS Screening and Evaluation Guidance.

This Biosolids PFAS Monitoring Report acknowledgment does not constitute a release or waiver of liability for compliance with your NPDES Permit; your NPDES Permit Application; or Part 31, Water Resources Protection, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (NREPA). Please be advised that if new PFAS information becomes available or new standards or requirements are implemented, the WRD may require additional actions in accordance with the NREPA and its administrative rules.

Thank you for protecting Michigan's public health and environment from these emerging pollutants. Should you need further information, please feel free to contact me at 517-257-0251 or [SmithC186@michigan.gov](mailto:SmithC186@michigan.gov).

Sincerely,



Christian Smith, M.S.  
Environmental Quality Analyst  
Emerging Pollutants Section  
Water Resources Division

cc: Sarah Campbell, EGLE  
Anne Tavalire, EGLE  
Victoria Starry, EGLE  
Patrick Miller, City of Cadillac