

DEQ-WATER BUREAU
POST INSPECTION REPORT

Cadillac WWTP
Industrial Pretreatment Prog Recon
Inspection ID: 38964

FACILITY INFORMATION

Facility Name: Cadillac WWTP

Facility Address:

1121 Plett Road

Cadillac, Michigan 49601

Facility Phone: (231) 775-2841

Facility Contact: Shawn Wheat

Facility Contact Phone: (231) 775-0181 Ext. 124

Permit Reviewed Permit No.: MI0020257

Issued: 9/5/2008

Effective: 11/1/2008

Expires: 10/1/2012

App. Due: 4/4/2012

Certified Operator:

Certified Operator Phone:

Primary Industry:

Nature of Business: municipal wastewater treatment
plant

Wastewater Treatment Processes:

Municipal Classification Code: A

Major: Yes

INSPECTION INFORMATION

Insp Start Date

11/19/09

Insp End Date

11/19/09

Transmittal Date

Sampling Start Date

N/A

Sampling End Date

N/A

DEQ Inspector(s)

Garth Aslakson

Workgroup

Cadillac

Inspection Contact(s)

Name

Working Title

Phone Number

Inspection Summary/Notes

Conducted IPP Recon inspection on November 19, 2009. Primary issue was elevated zinc in biosolids. Zinc was found during a September 2009 Point Source Survey. Plant Superintendent identified Cadillac Castings Inc. as the source of zinc. Cadillac needs to submit a compliance report by Jan. 15, 2010 per CSI inspection letter. City had determined source of zinc by manhole sampling.

AREAS EVALUATED

Comment

LEGAL AUTHORITY Not Evaluated

DEQ-WATER BUREAU POST INSPECTION REPORT

ENFORCEMENT RESPONSE PLAN Not Evaluated

PROCEDURES Not Evaluated

INTERJURISDICTIONAL AGREEMENTS Not Evaluated

INDUSTRIAL USER PERMITS Marginal

Focused on Cadillac Castings due to high zinc in biosolids. IPP Permit contained only monthly average limit. It needs daily max. limit also. IPP permit requires sampling 2X/month. Cadillac Castings should sample cooling water tank prior to discharge to adequately monitor zinc discharge to POTW.

INDUSTRIAL USER FILES Not Evaluated

LOCAL LIMITS Not Evaluated

EVALUATE SIGNIFICANT INDUSTRIAL USER LIST Not Evaluated

VIOLATIONS

Effluent Violations

Viol ID	Permit Number	Detection Date	Mon. Point	Mon. Point Description	Parameter	Permit Limit	Sample Result	Limit Type	Status
87004,	MI0020257,	12/31/08,	001A,	Effluent,	pH,	6.5 S.U.,	5.50 S.U.,	Minimum ,	Active,
22091,	MI0020257,	12/10/06,	001A,	Effluent,	Fecal Colifor,	400 cts/100 m,	433.99271,	Max 7-Da,	Active,
22090,	MI0020257,	12/09/06,	001A,	Effluent,	Fecal Colifor,	400 cts/100 m,	433.99271,	Max 7-Da,	Active,
22089,	MI0020257,	12/08/06,	001A,	Effluent,	Fecal Colifor,	400 cts/100 m,	433.99271,	Max 7-Da,	Active,
22088,	MI0020257,	12/07/06,	001A,	Effluent,	Fecal Colifor,	400 cts/100 m,	433.99271,	Max 7-Da,	Active,
9551,	MI0020257,	11/18/05,	001A,	Effluent,	Dissolved Oxy,	6.0 mg/l,	3.2 mg/l,	Minimum ,	Active,
9550,	MI0020257,	11/17/05,	001A,	Effluent,	Ammonia Nitro,	2 mg/l,	4.47 mg/l,	Maximum ,	Active,
27632,	MI0020257,	10/23/07,	001A,	Effluent,	Carbonaceous ,	10 mg/l,	11.6 mg/l,	Maximum ,	Active,
27631,	MI0020257,	10/21/07,	001A,	Effluent,	Ammonia Nitro,	2 mg/l,	3.33 mg/l,	Maximum ,	Active,
20579,	MI0020257,	10/18/06,	001A,	Effluent,	Carbonaceous ,	10 mg/l,	12.1 mg/l,	Maximum ,	Active,
20578,	MI0020257,	10/04/06,	001A,	Effluent,	Dissolved Oxy,	6.0 mg/l,	4.1 mg/l,	Minimum ,	Active,
8989,	MI0020257,	09/05/05,	001A,	Effluent,	Carbonaceous ,	10 mg/l,	20.0 mg/l,	Maximum ,	Active,
82382,	MI0020257,	08/31/08,	001A,	Effluent,	Total Phospho,	0.5 mg/l,	0.79 mg/l,	Maximum ,	Active,
94242,	MI0020257,	08/26/09,	001A,	Effluent,	Carbonaceous ,	10 mg/l,	12.870 mg,	Maximum ,	Active,
8988,	MI0020257,	08/01/05,	001A,	Effluent,	Ammonia Nitro,	2 mg/l,	2.52 mg/l,	Maximum ,	Active,
8987,	MI0020257,	07/31/05,	001A,	Effluent,	Total Mercury,	30 ng/l,	_____ ng/l,	Maximum ,	Active,
8966,	MI0020257,	07/15/04,	001A,	Effluent,	Ammonia Nitro,	2 mg/l,	2.20 mg/l,	Maximum ,	Active,
18713,	MI0020257,	07/13/06,	001A,	Effluent,	Dissolved Oxy,	6.0 mg/l,	5.6 mg/l,	Minimum ,	Active,
18712,	MI0020257,	07/10/06,	001A,	Effluent,	Dissolved Oxy,	6.0 mg/l,	5.9 mg/l,	Minimum ,	Active,
10257,	MI0020257,	05/31/04,	001A,	Effluent,	Fecal Colifor,	200 cts/100 m,	261.837 c,	Max Mont,	Active,
25034,	MI0020257,	05/30/07,	001A,	Effluent,	Carbonaceous ,	10 mg/l,	12.4 mg/l,	Maximum ,	Active,
25033,	MI0020257,	05/29/07,	001A,	Effluent,	Carbonaceous ,	10 mg/l,	13.2 mg/l,	Maximum ,	Active,
92101,	MI0020257,	05/28/09,	001A,	Effluent,	Ammonia Nitro,	2 mg/l,	2.080 mg/,	Maximum ,	Active,
8986,	MI0020257,	05/22/05,	001A,	Effluent,	Carbonaceous ,	10 mg/l, ,	13.0 mg/l, ,	Maximum ,	Active,
79954,	MI0020257,	05/01/08,	001A,	Effluent,	Carbonaceous ,	6.5 S.U.,	6.200 S.U,	Maximum ,	Active,
91050,	MI0020257,	04/30/09,	001A,	Effluent,	pH,	6.5 S.U.,	6.390 S.U,	Minimum ,	Active,
91049,	MI0020257,	04/29/09,	001A,	Effluent,	pH,	6.5 S.U.,	5.870 S.U,	Minimum ,	Active,
91048,	MI0020257,	04/24/09,	001A,	Effluent,	pH,	6.5 S.U.,	6.420 S.U,	Minimum ,	Active,
91047,	MI0020257,	04/23/09,	001A,	Effluent,	pH,	6.5 S.U.,	6.330 S.U,	Minimum ,	Active,
91046,	MI0020257,	04/22/09,	001A,	Effluent,	pH,	6.5 S.U.,	6.150 S.U,	Minimum ,	Active,
91045,	MI0020257,	04/21/09,	001A,	Effluent,	pH,	6.5 S.U.,	6.270 S.U,	Minimum ,	Active,

DEQ-WATER BUREAU POST INSPECTION REPORT

Viol ID	Permit Number	Detection Date	Mon. Point	Mon. Point Description	Parameter	Permit Limit	Sample Result	Limit Type	Status
91044,	MI0020257,	04/20/09,	001A,	Effluent,	pH,	6.5 S.U.,	6.250 S.U,	Minimum ,	Active,
91043,	MI0020257,	04/16/09,	001A,	Effluent,	pH,	6.5 S.U.,	6.200 S.U,	Minimum ,	Active,
91042,	MI0020257,	04/15/09,	001A,	Effluent,	pH,	5.0 mg/l,	1.0 mg/l,	Minimum ,	Active,
77494,	MI0020257,	03/10/08,	001A,	Effluent,	Dissolved Oxy,	0.5 mg/l,	5.838 mg/,	Minimum ,	Active,
7797,	MI0020257,	09/30/05,	001A,	Prior to,	Total Phospho,	2 mg/l,	6.91 mg/l,	Maximum ,	Active,
15413,	MI0020257,	09/03/03,	001A,	Prior to,	Ammonia Nitro,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
10252,	MI0020257,	08/31/03,	001A,	Prior to,	Lindane,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
10250,	MI0020257,	08/31/03,	001A,	Prior to,	Total Lead,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
10251,	MI0020257,	08/31/03,	001A,	Prior to,	Total Silver,	2 mg/l,	2.52 mg/l,	Maximum ,	Active,
7501,	MI0020257,	08/01/05,	001A,	Prior to,	Ammonia Nitro,	(report) TUC,	___ TUC,	Maximum ,	Active,
6959,	MI0020257,	07/31/05,	001A,	Prior to,	Chronic Toxic,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
6960,	MI0020257,	07/31/05,	001A,	Prior to,	Lindane,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
6955,	MI0020257,	07/31/05,	001A,	Prior to,	Total Cadmium,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
6956,	MI0020257,	07/31/05,	001A,	Prior to,	Total Copper,	(report) ng/l,	___ ng/l,	Maximum ,	Active,
6957,	MI0020257,	07/31/05,	001A,	Prior to,	Total Mercury,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
6958,	MI0020257,	07/31/05,	001A,	Prior to,	Total Zinc,	30 ng/l,	___ ng/l,	Maximum ,	Active,
6228,	MI0020257,	06/30/05,	001A,	Prior to,	Total Mercury,	10 mg/l,	13.0 mg/l,	Maximum ,	Active,
5613,	MI0020257,	05/22/05,	001A,	Prior to,	Carbonaceous ,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
10255,	MI0020257,	04/30/04,	001A,	Prior to,	Total Cadmium,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
10256,	MI0020257,	04/30/04,	001A,	Prior to,	Total Copper,	30 ng/l,	___ ng/l,	Maximum ,	Active,
3647,	MI0020257,	03/31/05,	001A,	Prior to,	Total Mercury,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
10253,	MI0020257,	01/31/04,	001A,	Prior to,	Total Cadmium,	(report) ug/l,	___ ug/l,	Maximum ,	Active,
10254,	MI0020257,	01/31/04,	001A,	Prior to,	Total Copper,	85 %,	6.7 %,	Maximum ,	Active,
24215,	MI0020257,	04/30/07,	001A,	Percent ,	Total Suspend,	85 %,	76.563 %,	Minimum ,	Manually Re,
79573,	MI0020257,	04/30/07,	001A,	Percent ,	Total Suspend,	85 %,	84.583 %,	Minimum ,	Active,
77491,	MI0020257,	03/31/08,	001A,	Percent ,	Total Suspend,	85 %,	84.318 %,	Minimum ,	Active,
23363,	MI0020257,	03/31/07,	001A,	Percent ,	Total Suspend,	85 %,	80.714 %,	Minimum ,	Active,
76973,	MI0020257,	02/29/08,	001A,	Percent ,	Total Suspend,			Minimum ,	Active,

SOC Violations

Viol ID	SOC ID	Program Name	Schedule Name	Due Date	Detection Date	SOC Status	Violation Status
89380,	25455,	Michigan Industrial Pretrea,	Annual Report,	04/01/09,	04/02/09,	Retired,	Retired,
88424,	25465,	Pollutant Minimization Prog,	for Total Mercury,	03/31/09,	04/01/09,	Active,	Active,
85875,	26725,	Monthly Operating Reports,	Submit a Facility Monitoring Pr,	12/01/08,	12/02/08,	Active,	Active,
83403,	25454,	Monthly Operating Reports,	Submit a Facility Monitoring Pr,	10/01/08,	10/02/08,	N/A,	N/A,
79193,	8118,	Michigan Industrial Pretrea,	IPP Annual Report,	04/01/08,	04/02/08,	Retired,	Retired,
78793,	8110,	Pollutant Minimization Prog,	for Total Mercury,	03/31/08,	04/01/08,	Superce,	Superce,
23185,	8109,	Pollutant Minimization Prog,	for Total Mercury,	03/31/07,	04/01/07,	Superce,	Superce,
25466,	8113,	Storm Water Pollution Preve,	Non-structural Controls Complet,	07/01/05,	07/02/05,	Superce,	Superce,
4107,	8119,	Residual Management Program,	RMP Certification or Proposed M,	08/01/04,	05/12/05,	Superce,	Superce,
3550,	8120,	Residual Management Program	RMP Annual Report	10/30/04,	04/22/05,	Retired,	Retired,

Report Submittal Violations

Viol ID	Report Start Date	Report End Date	Report Due Date	Type	Viol Status

Other Violations

Vio. ID	Detection Date	Violation Category	Violation Type	Violation Status
28029	11/09/07	Permit Language	Failure to Sample/Monitor as Required	Active

ENFORCEMENT

Enf. ID	Enf. No.	Enforcement Type	Action Type	Issued Date	Issued By	Enf. Status
6543	NL-003144	Notice Letter	Informal		Garth Aslakson	Pending

DEQ-WATER BUREAU POST INSPECTION REPORT

FOLLOW-UP ACTION

Item ID	Item Name	Due Date	Received Date	Approved Date	Locked	Item Type

Comments

Completed by_____

Date_____