

From: Jeff Dietlin <utilities@cadillac-mi.net>
Sent: 6/9/2022 9:12:49 AM
To: "Campbell, Sarah (EGLE)" <CampbellS32@michigan.gov>
Subject: RE: Concerning your submission #HPC-K20Z-68T3J: Annual Report Form For Reporting Biosolids

CAUTION: This is an External email. Please send suspicious emails to abuse@michigan.gov

Sarah,

pH adjustment was in error.
I will make sure that retention time is added. We historically have around a 20 day holding time.

Thank you,

Jeffrey M. Dietlin

City of Cadillac
Director of Utilities
(231) 779-7346(Direct)
(231)775-0906 (Fax)

From: Campbell, Sarah (EGLE) <CampbellS32@michigan.gov>
Sent: Thursday, June 9, 2022 8:49 AM
To: Jeff Dietlin <utilities@cadillac-mi.net>
Subject: Concerning your submission #HPC-K20Z-68T3J: Annual Report Form For Reporting Biosolids

Concerning your submission: Biosolids Annual Report:

Link to submission: <https://miwaters.deq.state.mi.us/nform/app/#/submissionversion/c00e89a5-4e76-4bc0-a5e9-afe9247b689b/overview>

Good morning,

I have been reviewing Cadillac's 2021 biosolids annual report. Under the pathogen reduction methods listed, one of the options that was selected was raising the pH. However, I did not see any documentation for this. Was this selected in error? Please either revise the report to either not include this option or include documentation that the pH was raised and the duration (I.E.,- raised to 12 for 2 hrs).

Additionally, because digester temps have a time and temperature requirement, it would be helpful in the future to include a solids retention time. Your digester sheet has a comment section

and a box for number of days- it would be really helpful for me to put an average SRT in one of those two areas.

If you have any questions, please reach out.

Sarah

Sarah Campbell [\(they/she\)](#)

West Michigan Biosolids Environmental Quality Analyst

Water Resource Division

Michigan Department of Environment, Great Lakes, and Energy

517-243-9939

Campbells32@michigan.gov