



JENNIFER M. GRANHOLM
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING



STEVEN E. CHESTER
DIRECTOR

July 26, 2004

Mr. Jeffrey M. Dietlin
Water Resources Supervisor
City of Cadillac WWTP
200 N. Lake Street
Cadillac, MI 49601

Dear Mr. Dietlin:

I have completed my review of the materials submitted to Mr. Mike Person of our Saginaw Bay District Office regarding the biosolids produced by your wastewater treatment plant. Based on the information submitted, it is my opinion that your biosolids meet the class A pathogen reduction criteria and the other necessary criteria of the Part 24 Biosolids Rules to be considered Exceptional Quality (EQ). Routine testing will still be required at the frequency specified in the Part 24 Rules to confirm that you are continuing to meet EQ criteria.

The EQ Biosolids produced are suitable for all land application uses including use on home lawns and gardens as well as other public contact areas and for retail sale, should you wish to do so.

Your biosolids will be considered EQ as long as there is no change in your current process and in the quality of the influent to your system. Any change in your process or addition of a new user that will affect your biosolids will require a new EQ determination be made.

I am very pleased to congratulate you on your efforts to meet these high standards.

If you have any questions, please feel free to contact Mr. Mike Person, Saginaw Bay District Office, Water Division, at 989-686-8025, Extension 8269, or you may contact me by telephone or e-mail at johnsoj1@michigan.gov.

Sincerely,

James E. Johnson
State Biosolids Coordinator
Water Division
517-241-8716

cc: Mr. Mike Person, DEQ