

Digester Hld Times and Temps 2025

Digester Capacity 150,000 gallons X 2 = 300,000

October	Sludge In	Temp	Detention Days	November	Sludge In	Temp	Detention Days	December	Sludge In	Temp	Detention Days	January	Sludge In
1	14070	94	21	1	12060	90	25	1	12060	85	25	1	9760
2	14070	94	21	2	12060	90	25	2	12060	84	25	2	12810
3	14070	94	21	3	12060	90	25	3	7930	84	38	3	12810
4	12060	94	25	4	12060	90	25	4	7930	84	38	4	12200
5	12060	94	25	5	12060	90	25	5	10980	84	27	5	19520
6	12060	94	25	6	12060	89	25	6	10980	83	27	6	12200
7	12060	94	25	7	12060	89	25	7	12060	82	25	7	12200
8	12060	94	25	8	12060	89	25	8	12060	82	25	8	14640
9	18090	94	17	9	12060	89	25	9	10980	84	27	9	13420
10	16080	93	19	10	12060	88	25	10	10980	83	27	10	12200
11	16080	93	19	11	12060	88	25	11	14640	83	20	11	13420
12	14070	92	21	12	12060	88	25	12	10980	83	27	12	15860
13	14070	92	21	13	12060	88	25	13	10980	83	27	13	16470
14	14070	92	21	14	12060	87	25	14	10980	83	27	14	11590
15	14070	91	21	15	12060	87	25	15	10980	83	27	15	11590
16	12060	91	25	16	12060	108	25	16	10980	83	27	16	12200
17	10050	90	30	17	12060	87	25	17	14640	83	20	17	15200
18	12060	90	25	18	12060	86	25	18	10980	83	27	18	14640
19	12060	90	25	19	12060	85	25	19	14640	84	20	19	10980
20	16080	91	19	20	12060	85	25	20	14640	84	20	20	13420
21	14070	90	21	21	12060	85	25	21	14640	83	20	21	12200
22	12060	90	25	22	12060	85	25	22	14640	83	20	22	12200
23	12060	90	25	23	12060	85	25	23	14640	82	20	23	12200
24	10050	90	30	24	12060	85	25	24	10800	82	28	24	12200
25	12060	90	25	25	12060	85	25	25	10800	82	28	25	12200
26	12060	90	25	26	12060	85	25	26	15660	82	19	26	12200
27	12060	90	25	27	12060	86	25	27	13920	82	22	27	14210
28	12060	90	25	28	12060	85	25	28	21960	82	14	28	12060
29	12060	90	25	29	12060	85	25	29	24400	82	12	29	12060
30	12060	90	25	30	12060	85	25	30	18300	81	16	30	12060
31	12060	90	25					31	12200	80	25	31	12060

Temp	Detention Days
80	31
79	23
79	23
79	25
79	15
78	25
78	25
78	20
78	22
77	25
78	22
78	19
77	18
76	26
78	26
80	25
82	20
83	20
84	27
86	22
87	25
88	25
89	25
89	25
89	25
89	25
90	21
90	25
90	25
90	25
90	25

February	Sludge In	Temp	Detention Days
1	12060	90	25
2	12060	90	25
3	12060	91	25
4	12060	91	25
5	12060	90	25
6	12060	90	25
7	12060	90	25
8	12060	92	25
9	12060	92	25
10	12060	92	25
11	16080	92	19
12	16080	92	19
13	16080	92	19
14	16080	92	19
15	16080	92	19
16	20100	91	15
17	16080	91	19
18	16080	90	19
19	16080	90	19
20	16080	91	19
21	16080	91	19
22	16080	90	19
23	16080	91	19
24	16080	90	19
25	16080	90	19
26	18090	90	17
27	18090	89	17
28	18090	89	17
29	19200	92	16

March	Sludge In	Temp	Detention Days
1	12060	87	25
2	12060	89	25
3	16080	90	19
4	18090	90	17
5	14070	91	21
6	14070	90	21
7	14070	91	21
8	16080	90	19
9	16080	90	19
10	12060	90	25
11	14070	91	21
12	16080	91	19
13	16080	91	19
14	16080	90	19
15	14070	90	21
16	14070	89	21
17	12060	89	25
18	16080	90	19
19	14070	89	21
20	16080	90	19
21	18090	90	17
22	14070	89	21
23	14070	89	21
24	14070	90	21
25	14070	90	21
26	14070	90	21
27	14070	90	21
28	14070	91	21
29	14070	90	21
30	14070	90	21
31	14070	90	21

April	Sludge In	Temp	Detention Days
1	14070	90	21
2	14070	90	21
3	14070	90	21
4	14070	90	21
5	14070	89	21
6	14070	89	21
7	14070	89	21
8	14070	89	21
9	14070	89	21
10	14070	89	21
11	14070	89	21
12	14070	88	21
13	14070	88	21
14	14070	89	21
15	14070	88	21
16	14070	89	21
17	14070	90	21
18	14070	90	21
19	14070	90	21
20	14070	90	21
21	14070	91	21
22	14070	92	21
23	14070	92	21
24	14070	91	21
25	14070	91	21
26	14070	91	21
27	14070	91	21
28	14070	92	21
29	14070	91	21
30	14070	91	16

May	Sludge In	Temp	Detention Days
1	14070	91	21
2	14070	92	21
3	14070	91	21
4	14070	92	21
5	14070	92	21
6	14070	91	21
7	14070	91	21
8	14070	91	21
9	14070	91	21
10			#DIV/0!
11			#DIV/0!
12			#DIV/0!
13			#DIV/0!
14			#DIV/0!
15			#DIV/0!
16			#DIV/0!
17			#DIV/0!
18			#DIV/0!
19			#DIV/0!
20			#DIV/0!
21	19030	89	16
22	19030	89	16
23	14070	89	21
24	14070	88	21
25	14070	88	21
26	14070	88	21
27	14070	90	21
28	18090	90	17
29	20100	89	15
30	14070	90	21
31	14070	90	21

June	Sludge In	Temp	Detention Days
1	14070	90	21
2	14070	91	21
3	14070	91	21
4	14070	91	21
5	16080	92	19
6	14070	92	21
7	18090	92	17
8	14070	92	21
9	18090	92	17
10	14070	91	21
11	14070	92	21
12	14070	92	21
13	14070	92	21
14	14070	92	21
15	14070	91	21
16	14070	93	21
17	14070	93	21
18	14070	93	21
19	14070	93	21
20	14070	93	21
21	14070	93	21
22	14070	93	21
23	16080	94	19
24	34170	94	9
25	16080	92	19
26	16080	93	19
27	16080	93	19
28	16080	93	19
29	16080	93	19
30	14070	94	21

July	Sludge In	Temp	Detention Days
1	14070	93	21
2	14070	94	21
3	14070	94	21
4	14070	94	21
5	14070	94	21
6	14070	94	21
7	14070	94	21
8	14070	94	21
9	14070	94	21
10	14070	94	21
11	14070	94	21
12	14070	94	21
13	14070	94	21
14	14070	95	21
15	16080	96	19
16	16080	96	19
17	16080	96	19
18	14070	95	21
19	16080	95	19
20	16080	95	19
21	16080	95	19
22	16080	96	19
23	16080	96	19
24	16080	95	19
25	16080	95	19
26	16080	95	19
27	20100	95	15
28	20100	95	15
29	20100	95	15
30	16080	95	19
31	16080	96	19

August	Sludge In
1	16080
2	16080
3	16080
4	16080
5	16080
6	16080
7	16080
8	16080
9	16080
10	16080
11	16080
12	16080
13	20100
14	22110
15	20100
16	20100
17	24120
18	24120
19	20100
20	16080
21	18090
22	20100
23	16080
24	20100
25	16080
26	22110
27	16080
28	20100
29	16080
30	16080
31	14070

Temp	Detention Days
96	19
95	19
96	19
96	19
96	19
95	19
95	19
95	19
95	19
95	19
96	19
96	19
96	19
96	15
96	14
96	15
96	15
95	12
95	12
94	15
94	19
94	17
94	15
94	19
94	19
94	15
94	19
94	14
94	19
95	15
95	19
95	19
96	21

September	Sludge In	Temp	Detention Days
1	12040	96	25
2	16080	95	19
3	16080	95	19
4	16080	95	19
5	16080	96	19
6	16080	97	19
7	16080	98	19
8	16080	96	19
9	14060	96	21
10	16080	96	19
11	16080	96	19
12	16080	96	19
13	16080	96	19
14	16080	96	19
15	18090	94	17
16	18090	95	17
17	20100	95	15
18	20100	96	15
19	16080	95	19
20	18090	96	17
21	16080	95	19
22	16080	95	19
23	16080	94	19
24	16080	94	19
25	20100	94	15
26	18090	95	17
27	16080	95	19
28	16080	95	19
29	16080	95	19
30	16080	95	19