

From: Sneller, Cindy (EGLE)
Sent: 4/3/2020 11:07:43 AM
To: "'Doug Langworthy'" <dlangworthy@Cadillac-MI.net>
Subject: RE: Documentation to continue the RMP Mod Review - Received

Hi Doug – Yep that looks like all the data, I will need. Thanks for putting it together like that. I will continue on with the review and hopefully have the final letter here in the next week or two.
Cindy

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: Friday, April 3, 2020 10:41 AM
To: Sneller, Cindy (EGLE) <SNELLERC@michigan.gov>
Subject: RE: Documentation needed to continue the RMP Mod Review

Cindy,
I think I have everything you requested. Let me know if there is anything else.
Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor
City of Cadillac
231-775-2841

From: Sneller, Cindy (EGLE) <SNELLERC@michigan.gov>
Sent: Friday, April 3, 2020 7:41 AM
To: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Cc: Person, Michael (EGLE) <PERSONNM@michigan.gov>
Subject: Documentation needed to continue the RMP Mod Review

Hi Doug – Mike Person and I discussed the proper documentation for review of the RMP Mod. [The following would be necessary in order to continue the RMP Mod Review.](#)

A minimum of *two years of data/documentation* regarding: Pathogen results (Rule 323.2414(2)(f) Alternative 4) [and](#) Vector Attraction Reduction (VAR) – 323.2415(4)(a) Reduction of Volatile Solids by 38%.

- [Data/documentation](#) showing how the formula is used with the pre- and post- sludge data, to achieve compliance.
- This may be:
 - Copies of the lab bench sheets (pre- and post- sludge data), along with the Excel spreadsheet calculations showing compliance with the 38% reduction. **Or,**
 - The plant's Excel spreadsheet (if all lab work is electronic), where we can see the data (pre- and post- sludge data), and access the formula used to calculate the reduction and achieve compliance. **Or,**
 - However the WWTP documents the data and the calculation, for compliance to be achieved.

Provide also a written statement of the formula used to calculate how the Volatile solids reduction is met.

- What is that formula?

Currently our office has: an excel spreadsheet of the **pre**-treated (raw) sludge data for June, 2019 and the **post**-treated sludge data during the land application of June 2019 (which you provided), and We have access to the pathogen results in the last two years via the fiscal year biosolids annual reports; According to the Biosolids Annual Reports, pathogen samples were collected twice each year.

- 2018 Pathogens were collected: March and September;
- 2019 Pathogens were collected: April and Fall (month?);

There is minimal data/documentation for VAR in these biosolids annual reports.

- The post-treated sludge data (during the hauling week);
- no pre-treated sludge data;

At this point, our office would like the following **VAR data (pre and post Volatile Sludge results)** for these time periods:

1. **Year 2018** – hauling occurred: May and October, 2018;
 - Please provide VAR data/documentation for **May and October, 2018;**
2. **Year 2019** – hauling occurred: June and Fall 2019;
 - Our office has the June 2019 data/documentation;
 - Please provide VAR data/documentation for the **Fall (month?) haul of 2019;**

Once we have that data, I will be able to continue with the review and hopefully have it completed soon after that.

If you have any questions regarding the above, feel free to contact me. I'm available today until approx.. 2:30 pm, then back on Monday.

Cindy

Cindy A. Sneller, Senior EQA
EGLE/WRD/Biosolids - Covering the west side of the Lower Peninsula
snellerc@michigan.gov
616-401-2471

Grand Rapids District Office
State Office Building
350 Ottawa Ave., NW
Grand Rapids, MI 49503
www.michigan.gov/egle