

Results for 1140 Plett Rd

Analyte	Original Cyclopure Test Kit Results (collected 3/7/2025)	EGLE Lab Resampling Results (collected 6/24/2025)	Comparability Study Results (collected 9/10/2025)									
			Indoor*				Indoor, Flushed for 3 Minutes			Outdoor**		
			EGLE	EGLE Duplicate	Merit	Cyclopure	EGLE	Merit	Cyclopure	EGLE	Merit	Cyclopure
11CI-PF3OUdS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
4:2 FTS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
6:2 FTS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
8:2 FTS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
9CI-PF3ONS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ADONA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HFPO-DA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
NFDHA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFBA	1.8	5	5	5	4	1.6	5	4	1.7	5	4	1.2
PFBS	22.9	28	28	29	24	22.5	29	27	24.6	28	26	24.2
PFDA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFDaA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFEESA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFHpA	3.1	4	4	4	3	3.6	4	4	3.7	4	4	3.4
PFHpS	1.3	ND	ND	ND	ND	1.9	ND	ND	1.6	ND	ND	1.9
PFHxA	4.5	6	5	5	5	4.5	5	6	3.9	5	5	3.4
PFHxS	24.3	35	36	39	29	31.7	35	29	32.6	37	28	31
PFMBA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFMPA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFNA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFOA	19.3	34	34	35	22	21.4	35	30	21.4	35	24	20.3
PFOS	9.3	15	19	18	14	12.9	18	15	12.4	18	14	12.1
PFPeA	2.3	4	4	4	3	1.5	4	3	1.7	4	3	1.6
PFPeS	1.3	ND	2	2	ND	1.8	3	ND	1.8	2	ND	1.7
PFUnA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Results are in parts per trillion (ppt)

Samples were collected by AECOM staff under the guidance of Cyclopure and EGLE/MPART staff

*Indoor samples were collected without flushing the tap

**Outdoor samples were collected after flushing the tap for three minutes

All exceedances of Michigan Drinking Water Criteria are highlighted in yellow