



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
CADILLAC DISTRICT OFFICE

Classification File
DEQ

DAN WYANT
DIRECTOR

October 22, 2014

Cadillac WWTP

Mr. Jeffrey Dietlin, Water Resources Supervisor
Cadillac WWTP
200 N. Lake Street
Cadillac, Michigan 49601

Dear Mr. Dietlin:

SUBJECT: Notice of Classification
Wastewater Treatment Facility that Services the Public
NPDES Permit No. MI0020257
Cadillac WWTP, CLASS A

The Michigan Department of Environmental Quality (DEQ), Water Resources Division (WRD), has responsibility for the classification of government owned wastewater treatment facilities or other facilities that serve the public in accordance with Part 41, Sewerage Systems, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (NREPA). Facilities that have already been classified are periodically reviewed to ensure that the existing facility classification(s) is still appropriate. This classification letter is a result of that review.

The plans for your existing wastewater treatment facility located at 1121 Plett Road, Cadillac, Michigan 49601, have been reviewed by the WRD for classification and are based primarily on the population served; the size, location and type of treatment facility; the character and volume of wastes treated; and the use and nature of the waters of the state receiving the effluent. However, treatment facilities in any size group may be placed in a higher classification when any of the following special conditions exist.

- Special features of design or characteristics more difficult to operate than usual.
- A particularly difficult type of sewage (wastewater characteristics).
- Stream conditions (receiving waters).

After review of these factors, the WRD has determined that the appropriate classification of your wastewater treatment facility is Class "A." The unique conditions which justify this classification are: the in-place IPP program, activated sludge, RBC treatment, cloth media filtration, UV disinfection, and discharge to a trout stream.

If you disagree with this classification, you may request a hearing before the Director of the DEQ or his designated representative, to present evidence to support your position. After the hearing, the DEQ will determine the proper waste treatment or control facility classification.

You are required by law to designate a superintendent, who shall be a properly certified operator to be in responsible charge of the day-to-day operation of your facility. Please notify the Cadillac District Office, Water Resources Division, in writing within 60 days, with the name, address and telephone number of the designated superintendent. A designation form is enclosed for your convenience. You may replace the superintendent with another properly

Mr. Jeffrey Dietlin
Cadillac WWTP

2

October 22, 2014

certified operator at any time and shall notify the WRD in writing within ten (10) days after the replacement.

Should you require further information, please contact Mr. Jeremy (Jamie) Wade, P.E., Environmental Engineer, at 231-876-4478, wadej@michigan.gov, or DEQ-WRD, Cadillac District Office, Department of Environmental Quality, 120 West Chapin Street, Cadillac, Michigan 49601-2158; or you may contact me.

Sincerely,



Brian W. Jankowski
Cadillac District Supervisor
Water Resources Division
231-876-4475
jankowskib@michigan.gov

Enclosure

cc: Mr. Hamid Rahbarnoohi, Superintendent
Operator Training and Certification Unit, WRD (via email)