

MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
SURFACE WATER QUALITY DIVISION
NPDES Permit Application Transmittal Memo

July 30, 2002

TO: Dan Dell, Lake Michigan Unit, Permits Section, SWQD

FROM: [Garth Aslakson, Cadillac, Cadillac](#) District Office, SWQD

SUBJECT: Facility's Designated Name: [Cadillac WWTP](#)
Permit No.: [MI0020257](#)
Permit ID.v: [21871.1](#)

1. *Provide a brief description of the compliance status of the permittee (effluent limit compliance, IPP compliance, etc.)*

No enforcement actions taken against this facility. Good compliance history.

2. *List any Certificates of Coverage (COC's), including storm water, that the facility currently possesses or that are pending that should be incorporated into this individual permit. Include the COC number(s) and attach a copy of the COC(s). For storm water COCs, attach documentation showing compliance schedules and the dates of any item(s) that have been completed.*

No other NPDES permits.

3. *Do the requested authorized discharge flow rates make sense for this facility? (If this is a municipal facility, is the requested authorized flow rate at or near the design capacity for the facility?) If the flow rate in the application is a decrease from what is authorized in the current permit, contact the permittee to verify that they really want the authorized flow rate in their permit decreased, and document that here.*

Requested flow is reasonable.

4. *List any other discharges in the area that should be considered during the review of this application.*

There are three dischargers up stream. AAR Brooks and Perkins, MI0002640
Cadillac Financing Authority, MI0054925
Rexaire Inc., MI0047104

5. *List any other pollutants you are aware of that may be in this discharge that have not been identified in the permit application and include the available effluent data. Attach daily data for toxic chemicals if not already provided in Section II Item 6 or Section III Item 9 of the application. (GLEAS would like 2 years worth of daily tox data if it is representative of the current discharge; more data may be beneficial to the applicant because it reduces the safety factor in the WQBEL calculation).*

No other pollutants known.

6. *Provide any recommendations for Special Conditions, Schedules of Compliance or other permit language, including operational problems, that should be included in the new permit specific to this*

NPDES Permit Application Transmittal Memo, Page 2

Designated Name:

NPDES Permit/Certificate of Coverage No.

DATE

*facility (check most recent CEI, PCI, IPP audit for comments made during the last inspection). For WWSL facilities indicate whether leak testing should be required by the permit. **Also** include approval dates for plans/etc. which have previously been approved if the plan/etc. will be continued in the new permit.*

No recommendations for special conditions.

7. *Provide any recommendations on Special Conditions, Schedules of Compliance, permit limitations, monitoring requirements (including sample types and sampling frequencies), IPP (e.g., change to MIPP language for POTWs with design flow of 5.0 MGD or less), or other permit language in the existing permit, which should be modified or do not need to be included in the new permit. Explain.*

This facility should have MIPP language.