

PUBLIC NOTICE

Date: August 1, 2008
Permit No. MI0020257
Cadillac WWTP

The Michigan Department of Environmental Quality proposes to reissue a discharge permit to: the City of Cadillac for the Cadillac Wastewater Treatment Plant located at 1121 Plett Road, Cadillac, Michigan 49601. The applicant collects and treats municipal wastewater from the City of Cadillac, Haring Township, Cherry Grove Township, and Clam Lake Township. The applicant discharges treated municipal wastewater to the Clam River, in the NE1/4, NE1/4, Section 33, Town 22N, Range 9W, Wexford County.

The draft permit includes the following modifications to the previously-issued permit: The effluent monitoring requirements for Lindane, Total Copper, and Total Cadmium have been eliminated because these parameters are not present in concentrations of concern. Total Selenium and Available Cyanide were detected at concentrations of concern; therefore, new monitoring requirements have been added for these parameters to better characterize the effluent. A new effluent limitation for Chronic Toxicity has also been included in the permit. The final effluent limitation for Total Mercury has been changed to 10 ng/l, which is the Level Currently Achievable based on a multiple discharger variance from the water quality-based effluent limit of 1.3 ng/l, pursuant to Rule 323.1103(9) of the Michigan Water Quality Standards.

Comments or objections to the draft permit received by September 1, 2008 will be considered in the final decision to issue the permit. Persons desiring information regarding the draft permit, procedures for commenting, or requesting a hearing should contact Jeff Fischer, Permits Section, Water Bureau, Department of Environmental Quality, P.O. Box 30273, Lansing, Michigan 48909, telephone: 517-335-4188, e-mail: fischerj1@michigan.gov.

Copies of the permit application, Public Notice, Fact Sheet, and draft permit may be obtained via the Internet (<http://www.deq.state.mi.us/owis> - click on 'Permits on Public Notice') or at the Water Bureau Cadillac District Office located at 120 West Chapin Street, Cadillac, Michigan 49601, telephone: 231-775-3960.

The multiple discharger variance for Total Mercury is from the Mercury Permitting Strategy for Fiscal Years 2005-2009 which may be obtained via the Internet at http://www.deq.state.mi.us/documents/deq-water-npdes-rules-Mercury_2004.pdf or it can be obtained at the District Office.