

Cadillac WWT
IPP

LETTER OF TRANSMITTAL

City of Cadillac Utilities Department

200 Lake Street
Cadillac, Michigan 49601
(231)-775-0181

3/28/2012	Job#:
Attention: Ms. Sy Pauilk	
Re: I.P.P. Report	

To: Ms. Sy Pauilk
120 W. Chapin St.
Cadillac, MI 49601

GENTLEMEN:

we are sending you:

- | | |
|--|---|
| ☒ Attached | ☐ Under Seperate Cover Sheet |
| ☐ Shop Drawings | ☐ Prints |
| ☐ Copy of Letter | ☐ Samples |
| ☐ Specifications | ☐ Plans |
| | ☐ Change Order |
| | ☐ _____ |

Copies	Date	No.	Description
1			Annual I.P.P. Report

These Are Transmitted As Checked Below:

- | | | |
|--|---|---|
| ☐ For approval | ☐ Approved as Submitted | ☐ Resubmit Copies for Approval |
| ☐ As Requested | ☐ Approved as noted | ☐ Submit Copies for Approval |
| ☐ For Review | ☐ Returned for Corrections | ☐ Return Corrected Print(s) |
| ☒ For Your Use | ☐ _____ | |
| ☐ For bids due | _____ | |

Remarks _____

MAR 29 2012

CADILLAC UTILITIES DEPARTMENT

Copy to: Annual I.P.P. Report

Signed: _____

[Signature]

RECEIVED MAR 29 2012

Michigan Industrial Pretreatment Program (MIPP)

Annual Report Form

Section I : General Information			
1. Name of Facility: City of Cadillac			
NPDES Number: MI0020257			
2. Contact Person: Hamid Rahbarnoohi		Phone: 231-775-2841	
3. Reporting Period: January 1, 2011 to December 31, 2011		E-mail: hrahbarnoohi@cadillac-mi.net	
4. Attach a summary of any sampling results for the influent, effluent, and sludge monitoring conducted during the reporting period.			
5. Total Number of Industrial Users: 17 SIUs: 17 CIUs: 6			
Have there been any additions, deletions, or any other modifications to the previous year's Significant Industrial User (SIU) list or industrial user inventory? If <i>NO</i> , check here. ☒ If yes provide the following information: (Attach additional sheets if necessary.)			
Facility Name	Change Add/Delete	Explanation	CIU or SIU
			☐ ☐
			☐ ☐
			☐ ☐
			☐ ☐

For all new or changed SIUs, provide:

- ☐ Process description,
- ☐ Flow information; and
- ☐ Reason it is classified as an SIU.

See attached report


MAR 29 2012


I certify under penalty of law that all the information supplied in this report, including attachments, is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Signature Hamid P. Rahbarnoohi

Title Water Resources Supervisor

Date 3/28/2012

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-01- FAC	SIU #590-17																		
a. SIU Name	AAR manufacturing	AAR Manufacturing (6 th Avenue)																		
b. Categorical Classification (if applicable)	Metal finisher	Metal finisher																		
c. Date(s) Inspected	March 2011	March 2011																		
d. Permit Issued Date	1/1/2011	1/1/2011																		
e. Permit Expiration	12/31/2012	12/31/2012																		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No																		
g. If yes, list dates.																				
h. How often has the <u>POTW</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.																		
i. How often has the <u>SIU</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never																		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☐ Yes ☒ No	☐ Yes ☒ No																		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No																		
l. List: - o violations, - o corresponding enforcement actions, and - o whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr> <td>See attachment</td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?	See attachment						<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr> <td>See attachment</td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?	See attachment					
Violations	Enforcement Actions	In Compliance?																		
See attachment																				
Violations	Enforcement Actions	In Compliance?																		
See attachment																				
m. Additional Information																				

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-11	SIU #590-09				
a. SIU Name	Cadillac Castings Inc.	Rec Boat Holding Inc. Trailer Plant				
b. Categorical Classification (if applicable)	Cast Iron Foundry	Metal Finisher				
c. Date(s) Inspected	January 2011	January 2011				
d. Permit Issued Date	1/1/2011	1/1/2011				
e. Permit Expiration	12/31/2012	12/31/2012				
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No				
g. If yes, list dates.						
h. How often has the <u>POTW</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.				
i. How often has the <u>SIU</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never				
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☒ Yes ☐ No	☒ Yes ☐ No				
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No				
l. List: ☐ violations, ☐ corresponding enforcement actions, and ☐ whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	Violations	Enforcement Actions	In Compliance?	Violations	Enforcement Actions	In Compliance?
	See attachment			See attachment		
m. Additional Information						

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-15	SIU #590-06																		
a. SIU Name	Cadillac Renewable Energy	Avon Automotive																		
b. Categorical Classification (if applicable)	Power Generation	N/A																		
c. Date(s) Inspected	January 2011	January 2011																		
d. Permit Issued Date	1/1/2011	1/1/2011																		
e. Permit Expiration	12/31/2012	12/31/2012																		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No																		
g. If yes, list dates.																				
h. How often has the POTW sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.																		
i. How often has the SIU sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never																		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☐ Yes ☒ No	☒ Yes ☐ No																		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No																		
l. List: - o violations, - o corresponding enforcement actions, and - o whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr> <td>See attachment</td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?	See attachment						<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?						
Violations	Enforcement Actions	In Compliance?																		
See attachment																				
Violations	Enforcement Actions	In Compliance?																		
m. Additional Information																				

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-13-Mixed Cells	SIU #590-16																		
a. SIU Name	Wexford County Landfill, LLC	Mercy Hospital																		
b. Categorical Classification (if applicable)	N/a	N/a																		
c. Date(s) Inspected	March 2011	March 2011																		
d. Permit Issued Date	1/1/2011	1/1/2011																		
e. Permit Expiration	12/31/2012	12/31/2012																		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No																		
g. If yes, list dates.																				
h. How often has the <u>POTW</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.																		
i. How often has the <u>SIU</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never																		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☒ Yes ☐ No	☐ Yes ☒ No																		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' and attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No																		
l. List: ☐ violations, ☐ corresponding enforcement actions, and ☐ whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td></tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?							<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td></tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?						
Violations	Enforcement Actions	In Compliance?																		
Violations	Enforcement Actions	In Compliance?																		
m. Additional Information																				

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-08	SIU #590-07																		
a. SIU Name	Rec Boat Holding Inc. Sports	Rec Boat Holding Inc. Cruiser																		
b. Categorical Classification (if applicable)	N/A	N/A																		
c. Date(s) Inspected	January 2011	January 2011																		
d. Permit Issued Date	1/1/2011	1/1/2011																		
e. Permit Expiration	12/31/2012	12/31/2012																		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No																		
g. If yes, list dates.																				
h. How often has the <u>POTW</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.																		
i. How often has the <u>SIU</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never																		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☐ Yes ☒ No	☐ Yes ☒ No																		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' and attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No																		
l. List: ☐ violations, ☐ corresponding enforcement actions, and ☐ whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td></tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?							<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td></tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?						
Violations	Enforcement Actions	In Compliance?																		
Violations	Enforcement Actions	In Compliance?																		
m. Additional Information																				

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-01-RT	SIU #590-03																		
a. SIU Name	AAR manufacturing	Paulstra																		
b. Categorical Classification (if applicable)	Metal finisher	N/A																		
c. Date(s) Inspected	March 2011	March 2011																		
d. Permit Issued Date	1/1/2011	1/1/2011																		
e. Permit Expiration	12/31/2012	12/31/2012																		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No																		
g. If yes, list dates.																				
h. How often has the <u>POTW</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.																		
i. How often has the <u>SIU</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never																		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☒ Yes ☐ No	☒ Yes ☐ No																		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' and attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No																		
l. List: ☐ violations, ☐ corresponding enforcement actions, and ☐ whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td></tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?							<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td></tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?						
Violations	Enforcement Actions	In Compliance?																		
Violations	Enforcement Actions	In Compliance?																		
m. Additional Information																				

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-05	SIU #590-02 -E																		
a. SIU Name	MI Rubber	Borg Warner																		
b. Categorical Classification (if applicable)	N/A	N/A																		
c. Date(s) Inspected	March 2011	March 2011																		
d. Permit Issued Date	1/1/2011	1/1/2011																		
e. Permit Expiration	12/31/2012	12/31/2012																		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No																		
g. If yes, list dates.																				
h. How often has the <u>POTW</u> sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.																		
i. How often has the SIU sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never																		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☒ Yes ☐ No	☐ Yes ☒ No																		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' and attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No																		
l. List: ☐ violations, ☐ corresponding enforcement actions, and ☐ whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?							<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr> <td>See attachment</td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?	See attachment					
Violations	Enforcement Actions	In Compliance?																		
Violations	Enforcement Actions	In Compliance?																		
See attachment																				
m. Additional Information																				

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-19	SIU #590-18																		
a. SIU Name	Piranha Hose Inc.	Fiamm Technology Inc.																		
b. Categorical Classification (if applicable)	N/A	N/A																		
c. Date(s) Inspected	March 2011	December 2011																		
d. Permit Issued Date	1/1/2011	1/1/2011																		
e. Permit Expiration	12/31/2012	12/31/2012																		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No																		
g. If yes, list dates.																				
h. How often has the POTW sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.																		
i. How often has the SIU sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never																		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☐ Yes ☒ No	☐ Yes ☒ No																		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' and attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No																		
l. List: - o violations, - o corresponding enforcement actions, and - o whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr> <td>See Attachment</td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?	See Attachment						<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?						
Violations	Enforcement Actions	In Compliance?																		
See Attachment																				
Violations	Enforcement Actions	In Compliance?																		
m. Additional Information																				

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	590-10	SIU #590-20																		
a. SIU Name	Rec Boat Holding Inc. Cabinet	ARVCO Container Corp.																		
b. Categorical Classification (if applicable)	N/A	N/A																		
c. Date(s) Inspected	January 2011	December 2011																		
d. Permit Issued Date	1/1/2011	1/1/2011																		
e. Permit Expiration	12/31/2012	12/31/2012																		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No	☐ Yes ☒ No																		
g. If yes, list dates.																				
h. How often has the POTW sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.	As often as permit states. Do all testing at facilities.																		
i. How often has the SIU sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never	Never																		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☐ Yes ☒ No	☐ Yes ☒ No																		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' and attach copy of actual notice	☐ Yes ☒ No	☐ Yes ☒ No																		
l. List: ☐ violations, ☐ corresponding enforcement actions, and ☐ whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td></tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?							<table border="1"> <thead> <tr> <th>Violations</th> <th>Enforcement Actions</th> <th>In Compliance?</th> </tr> </thead> <tbody> <tr><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td></tr> </tbody> </table>	Violations	Enforcement Actions	In Compliance?						
Violations	Enforcement Actions	In Compliance?																		
Violations	Enforcement Actions	In Compliance?																		
m. Additional Information																				

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

	SIU #590-21		
a. SIU Name	Avon Protection		
b. Categorical Classification (if applicable)	N/A		
c. Date(s) Inspected	March 2011		
d. Permit Issued Date	1/1/2011		
e. Permit Expiration	12/31/2012		
f. Did this permit tee have an expired permit at anytime during the reporting period?	☐ Yes ☒ No		
g. If yes, list dates.			
h. How often has the POTW sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	As often as permit states. Do all testing at facilities.		
i. How often has the SIU sampled and analyzed for all regulated pollutants in accordance with 40 CFR 136 requirements?	Never		
j. Was this SIU in SNC (in non-compliance with limits, sampling, and reporting requirements) at any time during the reporting period? If 'No' go to l.	☐ Yes ☒ No		
k. If yes (in SNC), were notices *published in the newspaper? If 'Yes' and attach copy of actual notice	☐ Yes ☒ No		
l. List: o violations, o corresponding enforcement actions, and o whether or not the SIU has returned to compliance. (Attach extra sheets as necessary)	Violations	Enforcement Actions	In Compliance?
m. Additional Information			

* Publication of CIUs required, non-CIUs optional

Michigan Industrial Pretreatment Program Annual Report Form (Continued)

Fill in one column for each SIU:

INDUSTRIAL PRETREATMENT PROGRAM ANNUAL REPORT

CITY OF CADILLAC WWTP

NPDES Permit Number MI0020257

Reporting Period From

January 1, 2011 to December 31, 2011

Submittal Date: March 29, 2012

Contact: Hamid Rahbarnoohi
Address: City of Cadillac WWTP
1121 Plett Road
Cadillac, MI. 49601

Phone Number: 231-775-2841
Fax Number: 231-775-2876
E-mail: hrahbarnoohi@cadillac-mi.net

I. INDUSTRIAL USERS

- A. Total number of Industrial Users: See attached IPP Master List.
- B. Have there been any additions, deletions, or any other modifications to the previously submitted Industrial User Inventory? [40CFR 403.8 (f) (2) (i)]
 X yes no {see attachment A}
- C. Total number of Significant Industrial Users.....17
1. Number of Categorical Industrial Users..... 6
2. Number of Non-categorical Significant Industrial Users..... 11
- D. Have there been any additions, deletions, or any other modifications to the previously submitted Significant Industrial List? [40 CFR 403.8 (f) (6)]
 yes X no
{If yes, enclose Attachment B listing additions, deletions and/or modifications}
- E. Total number of SIUs without an individual control mechanism at any time during the reporting period. 0
{If any, enclose Attachment C listing names of SIUs without permits.}

II. POTW Compliance Monitoring Program

- A. Total number of SIUs not inspected by the Control Authority at least once during the reporting period. 0
{List any SIUs not inspected on Attachment D.}
- B. Total number of SIUs not sampled/monitored for all required pollutants by the Control Authority at least once during the reporting period. 0
{List any SIUs not sampled/monitored on Attachment E.}

III. SIU Reporting/Monitoring Program

- A. Number of CIUs submitting a complete Baseline Monitoring Report (BMR) during the reporting period per number required.0/0
- B. Number of CIUs submitting a complete 90-day Compliance Report during the reporting period per number required. 0/0
- C. Number of CIUs submitting complete periodic reports during the reporting period per number required. 6/6

- D. Number of noncategorical SIUs submitting complete compliance reports during the reporting period per number required.11/11
- E. Total number of SIUs who did not self-monitor in accordance with the requirements in their individual control mechanism during the reporting period, including the repeat sampling and analysis required per 40 CFR 403.12 (g) (2) when a violation occurred.0
{Provide a list of all SIUs who failed to monitor on Attachment G.}
- F. Does the POTW monitor in lieu of SIU self-monitoring requirements for any of the SIUs under their control. X yes no
{If yes, list all SIUs not monitored by the Control Authority on Attachment G.}

IV. Enforcement Program

- A. Total number of industrial users in Significant Non-compliance (SNC) during the reporting period. 7
{Complete Attachment H by providing a listing of industries in SNC.}
- B. Total number of industrial users in SNC during the reporting period published in the newspaper (SVPU). 0
- C. Number of SIUs in SNC with Compliance Schedules during the reporting period noted as SSNC. 0
- D. Number of formal (Non-Judicial) Enforcement Actions during the reporting period noted as FENF. 7
- E. Number of Civil/Criminal Judicial Suits filed in court against SIUs during the reporting period, noted as JUDI. 0
- F. Number of users from which monetary penalties/fines were collected during the reporting period, noted as IUPN. 0
{Complete Attachment I providing a summary of enforcement actions.}

V. Toxic Pollutant Data (Annual Average)

{Complete Attachment J providing annual averages of any sampling of toxic Pollutants that were collected during the reporting period for influent, effluent, And sludge.}

VI. Program Evaluation

{Complete Attachment K describing progress in meeting IPP goals, noteworthy activities, environmental effectiveness of IPP problems, including NPDES and sludge violations, ect. Also provide all proposed changes of modifications to the approved IPP.}

ATTACHMENT A

City of Cadillac – 2011 Annual IPP Report

Instructions: List any additions, deletions, or other modifications to the previously submitted Industrial User Inventory. Provide a brief explanation for each Industrial User listed (i.e. a categorical industrial user, a manufacturer which does not generate wastewater, a direct discharger (NPDES permit number), a discharger of sanitary wastewater only, wastewater only ect.)

Note: Industrial User Name Change and New Management:
Wexford DPW Landfill was sold to American Waste. The new name is Wexford County Landfill, LLC. New contact person.

CITY OF CADILLAC
WWTP MASTER LIST
3/29/2012

Non- Domestic User Database

BUSINESS NAME	SERVICE ADDRESS	CONTACT PERSON	TYPE OF BUSINESS OR MANUFACTURING	PROCESS CHEMICALS USED OR STORED	CLASS	WMTP PERMIT #	PERMIT EXPIRATION	FLOOR DRAINS	RPZ UNITS
1 B & B OIL	1010 N. MITCHELL	JOHN FREEMAN	MOTOR OIL CHANGE	OIL'S	I			INSPECT	
2 Rec Boat Holding Inc.	926 FRISBIE	DONNA KOLTUNIAK	CANVAS SEWING		I				
3 Rec Boat Holding Inc.	905 FRISBIE	DONNA KOLTUNIAK	ENGINEERING		I				YES
4 Rec Boat Holding Inc. CRUISIER DIV	609 WEST 13TH ST.	DONNA KOLTUNIAK	BOAT BUILDING	STYRENE, FIBERGLASS	III	590-07	January-11	INSPECT	YES
5 Rec Boat Holding Inc. SPORT & DIS	925 FRISBIE	DONNA KOLTUNIAK	BOAT BUILDING	STYRENE, FIBERGLASS	III	590-08	January-11	INSPECT	YES
6 Rec Boat Holding Inc. TRAILER	1552 MILTNER	DONNA KOLTUNIAK	BOAT TRAILER MANUF.	PHOSPHORIC ACID	III	590-09	January-11	INSPECT	YES
7 7-UP, INC.	1481 POTTHOFF	RUSS KELLEY	POP WAREHOUSE	SOFTDRINKS	I				
8 AAR B&P MATERIAL DIV.	612 SEVENTH	JACK KRAMER	AIDOLLEYS, RAMPS		I				YES
9 AAR CADILLAC MANUFACT.	201 HAYNES	JACK KRAMER	MFG. CARGO PALLETS ACID, TRICHLORO.		III	590-01	March-11	INSPECT	YES
10 AAR CADILLAC MANUFACT.	1405 6th Avenue	JACK KRAMER	MFG. CARGO PALLETS ACID, TRICHLORO.		III	590-17	March-11	INSPECT	YES
11 RICK'S CAR WASH	2811 SUNNYSIDE DR.	RICK	CAR WASH		I			INSPECT	
12 ARVCO	1649 LESSON	GORDON L. MARTIN	CORRUGATED CTNS.	R-976 TYPEWASH SOAP	I				
13 ARVCO	1355 MARTY PAUL	MIKE GORDON	CORRUGATED CTNS.	R-976 TYPEWASH SOAP	I	590-20	Dec-11	INSPECT	YES
15 AUTO ZONE	1042 N MITCHELL		AUTO PARTS						
16 AVON PROTECTION	512 SEVENTH	JERRY NEWHART	RUBBER PRODUCTS	SOLVENTS & DEGREAS	I	590-21	March-11	INSPECT	YES
17 AVON AUTOMOTIVE	603 SEVENTH	BILL SOMERS	RUBBER PRODUCTS	OIL'S SOLVENTS	III	590-06	January-11	INSPECT	YES
18 AVON RUBBER RECYCLING	400 SEVENTH	BILL SOMERS	RUBBER RECYCLING	NEW IN 1999					
19 AVON TECHNICAL	502 SEVENTH	BILL SOMERS	RUBBER PRODUCTS	SOLVENTS & DEGREAS	I			INSPECT	YES
20 LAKESIDE AUTOWASH	617 N MITCHELL	J.R.	CAR WASH		I			INSPECT	YES
21 BIG BOY	1310 S MITCHELL	Mgr.	RESTAURANT	GREASE, SOAPS	I				
22 BIG FOOT MANUFACTURING	1480 ED POTTHOFF	LYLE MATTESON	PLASTIC WELL POINTS	LUBRICANTS					
23 BILLS MOTOR SALES	1129 N MITCHELL	GREG BEAUDOIN	CAR SALES, WASH	SOAPS	I			INSPECT	
24 BLUE HERON	304 N MITCHELL	BRIAN WILLIAMS	BAKERY		I				
25 BODYCOTE	1515 6TH AVENUE	Mgr.	HEAT TREAT	OIL'S SALTS, ACID'S	III	590-04	31-Dec-08	INSPECT	YES
26 BORGWARNER	1100 WRIGHT ST.	STEVE TOWER	TRUCK PARTS, PAINT.	OILS, SOLVENTS	III	590-02	March-11	INSPECT	YES
27 BREIDENSTEIN REPAIR	502 S. MITCHELL		GAS AND OIL SALES	CAR REPAIR, OIL, GAS	I			INSPECT	
28 BRITE-N-CLEAN	131 PALUSTER	MERLE A GETTY	LAUNDRY, CLEANERS	SOLVENTS	I			INSPECT	YES
29 AJ'S PIZZERIA	528 HAYNES ST.	Mgr.	RESTAURANT	SOAP, GREASE	I				
30 CADILLAC WWTP	1121 PLETT RD.	HAMID RAHBARNOOHI	WASTEWATER	FERRIC CHLORIDE	II			INSPECT	YES
32 CADILLAC CLEANER'S	202 W. NORTH ST.	TERRY McBRIDE	LAUNDRY.	PERCHLOROETYLENE	II			INSPECT	YES
33 THE THISTLE PATCH	209 N MITCHELL		ARTS		I				
34 CADILLAC EVENING NEWS	130 N. MITCHELL	TOM HUCKLE	NEWS PAPER		I				
35 CADILLAC FABRICATION	1340 MARTY PAUL	TOM BOSCHER	STEEL FABRICATION		I				
36 CADILLAC JUNIOR HIGH	500 CHESTNUT	DAVE CHAMPION	SCHOOL		I				YES
37 CADILLAC PERIODONTAL	909 S CARMEL	DR. BROCK ARMS	DENTAL FACILITY		I				
38 CADILLAC PRINTING	214 S.MITCHELL	C.G.TOWNSEND	PRINTING		I				
39 CADILLAC QUICK LUBE	621 N.MITCHELL		QUICK OIL CHANGE	NEW IN 1999					
40 CADILLAC RENEWABLE ENER	1525 FRANK MILTNER	TIM SCHIMKE	WOOD POWER PLANT	ACIDS, ALKILIS, ETC.	III	590-15	January-11	INSPECT	YES
41 CADILLAC SANDS	M-115 AT M-55	JACK SIMCOCK	MOTOR INN, REST.		I				
42 CADILLAC SENIOR HIGH	400 LINDEN	BILL CHILMAN	SCHOOL		I				YES
43 CADILLAC WEST MALL	M-55	PHILIP PERALTA	STORES		I				YES
44 CADILLAC PARTY LOUNGE	516 N MITCHELL	RICHARD MAURY	BAR, RESTAURANT		I				
45 Rec Boat Holding Inc.	1644 RON WILSON ST.	DONNA KOLTUNIAK							
46 CAD.NAT. GUARD ARMORY	415 HAYNES ST.	ROBERT SPENCER	VEHICLE STORAGE	DEGREASER'S	II			INSPECT	YES
47 GOODWILL	901 N. MITCHELL		DEPARTMENT STORE		I				
48 GLENS FOOD CENTER	602 S. MITCHELL ST.	MIKE GOERBIG	GROCERY STORE	SURFACTANTS, ALKALI	I				
49 CASS SCHOOL	532 HAYNES	BILL CHILMAN	SCHOOL		I				YES

51 CITY GARAGE	1001 SIXTH	BOB JOHNSON	EQUIPMENT REPAIR	CHLORIDE, OILS	II	INSPECT	YES
52 CITY OF CADILLAC	200 LAKE STREET	BOB JOHNSON	OFFICE		I		YES
53 BLARNEY CASTLE OIL	6121 M-115		GAS STATION	GAS, STORE	I		
54 CADILLAC CASTINGS INC.	1500 FOURTH AVE	ERIK OLSON	MALLEABLE CASTINGS	SOLVENTS, RESINS	SE	January-11	INSPECT
55 CONSUMERS POWER CO.	330 W CHESTNUT	KEN WINKELMAN	ELECTRIC POWER	SOLVENTS.	II		INSPECT
56 WONDER HOSTESS BAKERY	838 N. MITCHELL		BREAD SALES		I		INSPECT
57 COOLEY SCHOOL	221 GRANITE	KEN GORLEWSKI	SCHOOL		I		YES
58 CRANDALL PRECISION	560 FIFTH ST.	LOYDE CRANDLE	MACHINE SHOP	OILS, LUBES, SMALL	I		
59 CRYSTAL FLASH OIL CO.	702 N. MITCHELL		GAS STATION		I		
60 CWT	1201 N. MITCHELL	VANCE EDWARDS	PUBLIC TRANS.	SOAP, SOLVENT	I		INSPECT
61 DAIRY QUEEN	901 S. MITCHELL	LARRY DAVY	RESTAURANT		I		
62 DAVENPORT SUPERWASH	1001 N. MITCHELL	KOLARVIC	TOUCHLESS CARWASH	NEW IN 1999			YES
63 DELTA TRUSS	103 10TH STREET	THOMAS KAPUSCINSKI	WOOD TRUSS		I		
64 DON'S AUTO CLINIC	1110 N. MITCHELL	RUSS NEDERHOED	AUTO REPAIR	DEGREASERS	I		INSPECT
65 BELLOW'S/MYERS/MCDONALD	120 PALUSTER	DR. MEYERS	MEDICAL OFFICE	X-RAY ?	I		
66 DR. CARL MEIER JR.	909 S CARMEL	DR. MEIER	MEDICAL OFFICE	X-RAY ?	I		
67 MERCY HOSPITAL	803 LYNN STREET		MEDICAL OFFICE	X-RAY ?	I		
68 CADILLAC EYE CLINIC	502 COBB STREET	CHRIS BUGGEMA	MEDICAL OFFICE	X-RAY ?	I		
69 GRAND TRAVERSE HEART ASSOC	440 COBB STREET	JACQUE KRUSE	MEDICAL OFFICE	X-RAY ?	I		
70 DR. LESTER ADKINS	504 HAYNES STREET	DR. ADKINS	MEDICAL OFFICE	X-RAY ?	I		
71 DR. JON TOEPLER	929 N. MITCHELL	DR. TOEPLER	MEDICAL OFFICE	X-RAY ?	I		
72 DR. DAVID PAYNE/TATARCHUK	828 OAK STREET	DR. PAYNE	MEDICAL OFFICE	X-RAY ?	I		
73 DR. STEPHEN BROWN	530 COBB STREET	DR. BROWN	MEDICAL OFFICE	X-RAY ?	I		
74 DR. THOMAS TWIGG	300 LAKE STREET	DR. TWIGG	MEDICAL OFFICE	X-RAY ?	I		
75 ELK'S TEMPLE	120 S. MITCHELL	DARWIN CARLSON	RESTAURANT	SOAP'S	I		
76 FERRIS AUTO.	845 N. MITCHELL	DAVE FERRIS	MACHINE SHOP	SOLVENTS DEGREASE	II		INSPECT
77 FIAMM TECHNOLOGIES	946 FRISBIE	JASON ROODRA	FABRICATED METAL		II	590-18	Dec-11 INSPECT
82 FIBER TECH IND INC	1637 MARTY PAUL	JERRY WEST	PANEL BUILDING	FIBERGLASS, SOLVENT	I		YES
83 FOUR SEASONS	319 N. MITCHELL		CAR SALES	DEGREASERS, SOLVEN	II		INSPECT
84 FRANKLIN ELEM. SCHOOL	505 LESTER	JOY HICKS	SCHOOL		I		YES
85 GOODRICH THEATERS	202 S. MITCHELL	CHUCK BRANDT	MOVIE THEATER		I		
86 GREAT LAKES FAMILY CARE	520 COBB ST.	KERRY AHRENS	PHYSICIANS OFFICE	CYANIDE, HG	II		INSPECT
87 G&D LIQUOR STORE	223 S. MITCHELL	PAUL KURTZMAN	RESTAURANT	SOAP'S	I		
88 COMPLETE INSURANCE PLANNING	201 SOUTH STREET		INSURANCE		I		
89 HAMPTON INN	1650 S MITCHELL	JULIE SNYDER	HOTEL				
90 HERMAN'S	214 N MITCHELL	HERMAN SUHS	RESTAURANT		I		
91 HILLCREST RESTUARANT	1250 S MITCHELL	DOUG KULMACZ	RESTAURANT	GREASE	I		INSPECT
92 HITESMAN FUNERAL HOME	620 N. MITCHELL	ROBERT HITESMAN	FUNERAL HOME	FORMALDEHYDE	I		
93 CHECKERS	1212 N. MITCHELL		RESTAURANT		I		YES
94 HOUSE OF HUNAN	505 N MITCHELL	MYOKON YAN TEGESA	RESTAURANT		I		
95 HL GREENS	107 S MITCHELL	CITY OF CADILLAC	3 STORES				
96 RJ GRANTS	107 S MITCHELL		CLOTHING				
97 INLAND LAKES FOUNDRY	312-314 HAYNES	GEORGE KUHN	MACHINE TOOLS		II		INSPECT
98 JACOBS CHIROPRACTIC CLIN.	222 HARRIS ST. E.	Dr. RON JACOBS JR.	CHIROPRACTOR	X-RAY	I		
99 JOHNSON'S BODY SHOP	110 W. PINE	GARY HAGEN	STORAGE		I		
100 JOYNT AUTO. PARTS	843 N MITCHELL	MAURICE SCHOPIERAY	AUTO, PARTS	SOLVENTS, DEGREASE	II		INSPECT
102 KENTUCKY FRIED CHICKEN	1011 S. MITCHELL	CHERYL/MGR	RESTAURANT		I		
103 KENWOOD ELEM. SCHOOL	1700 CHESTNUT	JIM HUNT	SCHOOL		I		YES
104 KENWOOD PARK & BEACH	N. BOULEVARD	CITY OF CADILLAC	RECREATION		I		
105 KIDDER MACHINE CO.	702 8TH STREET	DEAN KIDDER	MACHINE SHOP	COOLANTS, SOLVENTS	I		YES
106	850 N MITCHELL						
107 ROYAL LINEN SERVICE	701 SIXTH STREET		LAUNDRY	SOAP, BLEACH	II		INSPECT
108 LAKESIDE CHARLIES	301 S LAKE MITCHELL	CHARLES WINN	RESTAURANT	SOAP'S, CLEANER'S	I		
109 LAKEVIEW MANOR	460 PEARL ST.	ROB SIMCOCK	NURSING HOME		II		INSPECT
110 HERRADURAS	1700 S. MITCHELL	Mgr.	RESTAURANT	GREASE	I		YES

111 LDFA GROUNDWATER PLANT	1005 SIXTH STREET	LARRY CAMPBELL	WATER CLEANUP	ACID, CAUSTIC	II	INSPECT	YES
112 LINCOLN ELEM. SCHOOL	125 AYER STREET	SCOTT HANSON	SCHOOL		I		
113 CARE NET OF CADILLAC	419 LAKE STREET				I		
114 ADVANCE CHIROPRACTIC CTR	932 N MITCHELL	LORI	CHIROPRACTIC				
115 MAGGIE'S TAVERN	523 N MITCHELL	BRIAN JONES	TAVERN, RESTAURANT		I		
116 MAHAR TOOL	1001 N. MITCHELL		INDUSTRIAL SUPPLY		I		
117 LAURA LEE'S LANDING	1749 N BOULEVARD	LAURA LEE	CABINS, BOAT RENTAL		I		
118 MARINA RESTAURANT	M-55 WEST	JOHN SNIDER	RESTAURANT	SOAPS	I		
119 MARINA SHORES	600 S. LAKE STREET						
120 MASONIC TEMPLE	122 N. MITCHELL	CLARENCE JOHNSON	OFFICES		I		
121 MCKINLEY SCHOOL	601 E. NORTH	TONY SILVERI	SCHOOL		I		YES
122 MERCY HOSPITAL	400 HOBART	COREY CHRISTENSEN	HOSPITAL	LAB.WASTE	III 590-16	March-11	INSPECT YES
123 MERCY OFFICES	711 OAK	JERRY DANIALS	HOSPITAL OFFICE		I		YES
124 MERCY REHAB SVS	1406 N MITCHELL		HOSPITAL REHAB	XRAY			
125 CLASSIC CARPET CLEANING	1111 N. MITCHELL		CARPET CLEANING	DEGREASER'S	II		INSPECT
126 METAL PUNCH	907 SAUNDERS ST.	KERWIN HUTTENGGA	TOOL & DIE SHOP	WATER SOLUBLE COOL	II		INSPECT
127 MICHIGAN RUBBER	1200 EIGHTH	DALE RICE	PROD. RUBBER PARTS	OILS, DEGREASERS	III 590-05	March-11	INSPECT YES
128 AT&T	205 E HARRIS ST.	JAMES GOODWIN	TELEPHONE OFFICE		I		
129 AT&T	1311 WRIGHT ST.		VEHICLE STORAGE	SOLVENTS, GAS, OILS	I		
130 MIDAS MUFFLER	220 S. MITCHELL	L.D. WEATHERWAX	AUTO REPAIR	DEGREASERS	I		INSPECT
133 MITCHELL STATE PARK	E-M-115	JERRY WALTERS	CAMPING PARK	CLEANERS.	I		
134 MITCHELL TIRE	522 N MITCHELL	STEVE MITCHELL	AUTO REPAIR		I		INSPECT
135 MUFFLER MAN	823 N MITCHELL		AUTO REPAIR	FLOOR CLEANERS	I		INSPECT
136 NAVAL RESERVE CENTER	LINDEN & CHESTNUT	BOB JOHNSON	SENIORS, NMC		I		YES
137 NCC MENTAL HEALTH	527 COBB STREET	HAROLD MEEUWES	OFFICE		I		YES
138 NELSON PHOTOGRAPHY	110 N MITCHELL	JOHN NELSON	PHOTOGRAPHY		I		
139 NOC INDUSTRIES	1610 CORWIN	RON ANDREWS	NEEDS SKILL CENTER	SOAPS, CLEANERS	II		INSPECT
141 NORTHWEST MI. HUMAN SERV.	1640 MARTY PAUL	VALARIE BISHOP	FOOD PREPARATION		I		
142 SATURN JEMS	100 N.MITCHELL		JEWELRY SHOP		I		
143 PATTERSON'S FLOWERS	107 S MITCHELL	DON PATTERSON	FLOWER SALES		I		
144 PAULSTRA CRC	600 7TH STREET	KEITH ANDERSON	RUBBER MOLDER	WATER WASHER, PAIN	III 590-03	March-11	INSPECT YES
145 MR. CLEANS AUTO CLEANING	605 N MITCHELL	BRUCE WINKLEMAN	AUTO CLEAN UP/CAR WASH		I		INSPECT
146 PELL'S RADIO CENTER	415 N MITCHELL	JOHN PUTVIN	APPLIANCE REPAIR		I		
147 PETE'S RADIATOR	839 N. MITCHELL	BILL VERMILYEA	RADIATOR REPAIR	ANIT-FREEZE, SOLDER	II		INSPECT
148 PETERSON'S SERVICE	M-115	DON PETERSON	GAS STATION	NO SERVICE	I		INSPECT
149 PETERSON'S SERVICE	324 N. MITCHELL	DON PETERSON	GAS STATION	CAR WASH, SOLVENTS	I		INSPECT
150 PETERSON FUNERAL HOME	205 E CASS ST.	ROSS MEYERING	FUNERAL HOME		I		
151 PHOTO I INC.	207 S MITCHELL	KEVIN HUGHES	PHOTO FINISHING	SEE FILES	II		
153 PIRANAH HOSE PRODUCTS	2500 RAYMOND RTE	BRIAN BLAKE	RUBBER MOLDER		590-19	March-11	INSPECT YES
154 PONDEROSA	621 S. MITCHELL	JEFF LAMONDE	RESTAURANT		I		
156 PRIDE OF CADILLAC N.	1047 N. MITCHELL	CLYDE KAMPHUIS	CAR WASH	SOAPS	I		INSPECT YES
157 PRIDE OF CADILLAC S.	420 S MITCHELL	CLYDE KAMPHUIS	CAR WASH	SOAPS	I		INSPECT YES
158 PRINTMASTER	1215 N. MITCHELL		PRINTING & PHOTO	PHOTO DEVELOPMENT	II		
159 RENAL DIALYSIS CTR	203 PAULSTER		MEDICAL OFFICE	KIDNEY DIALYSIS			
160 PBS PARTY STORE	1010 S. MITCHELL	Mgt.	GAS STATION		I		
161 REXAIR, INC.	230 SEVENTH ST.	STAN ZAUCHA	MANUF. VACUUMS	SOLVENTS, VARNISH.	II		INSPECT YES
163 FEDEX	1501 RON WILSON		SHIPPING SERVICE				YES
164 SALVATION ARMY	725 WRIGHT ST.	JEREMIAH BURNS	CHURCH		I		
165 SEARS STORE	219 N. MITCHELL	BECKY ADAMS	STORE		I		
166 SECOND TIME AROUND	916 S.MITCHELL	BILL SLADE	CLOTHING		I		
167 SAVE-A-LOT	802 N MITCHELL	GLEN BARTHOLOMEW	GROCERY STORE	CLEANING DETERGENT	I		YES
168 BRIDAL EXPRESSIONS	119 S.MITCHELL	MRG	DEPT. STORE		I		
169 STANDARD ELECTRIC	210 SEVENTH STREET	JOE MATZKE	ELECTRIC SUPPLY		I		
171 ADMIRAL STATION	805 S.MITCHELL		GAS STATION		I		
172 TUFFY AUTO SERVICE CTR	1020 N MITCHELL		AUTO REPAIR		I		

173 TUSCOLA RAILWAY	1203 N. MITCHELL	RAY ROBERTSON	RAILROAD		I				INSPECT
174 UNIVERSAL TRIM - MITCHELL	514 WRIGHT	FRED CEBULSKI	AUTO. SEWING	START 09/98		I			
175 US FORESTRY SERVICE	1755 S. MITCHELL	STEVE KELLY	DISTRICT OFFICE			I			YES
176 U.P.S.	1421 EDWARD POTTHOFF		PACKAGE SHIPMENT	TRUCKS, OILS		I			YES
179 VANHOUTEN OIL CO.	923 S. MITCHELL ST.	WARREN VANHOUTEN	VEHICLE MAINTENANCE	SOLVENTS, OILS		I			INSPECT
180 WEDIN INTERNATIONAL	1111 SIXTH AVENUE	JACK RAYBUN	MACHINING	SOLVENTS, COOLANTS		II			INSPECT
181 WELLINGTON'S CLEANER	113 E. CHAPIN	ERNEST MONTER	LAUNDRY	PERCHLOR. SOAPS		II			INSPECT
182 LAKE CITY REDIMIX	510 FIFTH ST.		CONCRETE PRODUCTS	DEGREASERS, SOLVENT		II			INSPECT
183 WEXFORD COUNTY LANDFILL, LLC	990 N US 131, MANTON	DON SUCHOCKI	LANDFILL LEACHATE	BOD, SS, AMMONIA	III	590-13	March-11		INSPECT
184 WEX COUNTY SHERIFF	820 CARMEL ST.	RICHARD DEVUE	JAIL			I			
186 FIRST GLASS LLC	500 N. MITCHELL		GLASS SHOP						
187 B & P Manufacturing	8050 E. Boon Rd.		Delivery Products	SOLVENTS			June-11		INSPECT

ATTACHMENT B

City of Cadillac – 2011 Annual IPP Report

Significant Industrial User List

This is a list of all Significant Industrial Users as defined in 40 CFR 403.3(t) (including those industrial users meeting the criteria in 40 CFR 403.3(t) (1) (ii) that Control Authority has determined is not significant pursuant to 40 CFR 403.3(t) (2).

Use the CRITERIA CODES below for the CRITERIA CODES line on SIU LIST
(use more than one CRITERIA CODE if applicable)

CRITERIA CODES

CRITERIA CODE DESCRIPTIONS

- | | |
|-----------|---|
| C | All industrial users subject to Categorical Pretreatment Standard under 40 CFR 403.6 and 40 CFR Chapter 1, Subchapter N. |
| S1 | Industrial users other than Categorical Industrial Users (CIUs) that discharge and average of 25,000 gallons or more of process wastewater to the POTW (excluding sanitary, non-contact cooling and boiler blow down wastewater.) |
| S2 | Industrial users other than Categorical Industrial Users (CIUs) that contribute a process waste stream which makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant. |
| S3 | Industrial users other than Categorical Industrial Users (CIUs) that are designated as significant by control authority on the basis that the industrial user has a reasonable potential for adversely affecting the POTWs operation or for violating any pretreatment standard or requirement. |
| X | Industrial users that meet the criteria of S1 and S2, that the Control Authority has made a determination is not significant Pursuant to 40 CFR 403.3 (t) (2). |

**NOTE: IF AN INDUSTRIAL USER HAS MORE THAN ONE CONNECTION TO
SANITARY SEWER, EACH CONNECTION SHALL BE LISTED
SEPARATELY.**

Industry Name:

Address:

Industrial Waste Contact:

Phone Number:

Criteria Code:

Category:

Subcategory:

Type of Discharge:

Regulated Wastewater Flow:

Total Wastewater Flow:

Nature of Operation:

ATTACHMENT H
City of Cadillac – 2011 Annual IPP Report

Instruction: List the names of non-domestic users in SNC for each of the SNC criteria. SNC must be evaluated (every three months) using data from previous six months. See example below:

Evaluate March 31 for period covering Oct. 1 through March 31.

Evaluate June 30 for period covering Jan. 1 through June 30.

Evaluate September 30 for period covering April 1 through Sept. 30.

Evaluate December 31 for period covering July 1 through Dec. 31.

- A. Chronic violations of wastewater discharge limits, defined as those in which sixty-six percent or more of all of the measurements taken during a six-month period exceed (by any magnitude) the daily maximum limit or the average limit for the same pollutant parameter.

- | | |
|---|--------------------|
| 1. Rec Boats Holding Inc. Trailer Plant | 5. Michigan Rubber |
| 2. AAR RT | 6. |
| 3. Avon Automotive | 7. |
| 4. Cadillac Castings Inc. | 8. |

- B. Technical Review Criteria (TRC) violations, defined here as those in which thirty- three percent or more of all the measurements for each pollutant parameter taken during a six-month period equal to or exceeding the product of the daily maximum limit or the average limit multiplied by the applicable TRC (TRC=1.4 for BOD, TSS, oil and grease; a 1.2 for all other pollutants except pH).

- | | |
|---|-------------|
| 1. Rec Boats Holding Inc. Trailer Plant | 5. Paulstra |
| 2. Avon Automotive | 6. |
| 3. Michigan Rubber | 7. |
| 4. Wexford County Landfill, LLC | 8. |

- C. Any other violation of a pretreatment effluent limit (daily maximum or longer-term averages) that the permit-tee determined caused, alone or in combination with other discharges, interference or pass through (including endangering the health of the POTW personnel or the general public).

- | | |
|----|----|
| 1. | 3. |
| 2. | 4. |

- D. Any discharge of a pollutant that caused imminent endangerment to human health or welfare to the environment.

- | | |
|----|----|
| 1. | 3. |
| 2. | 4. |

ATTACHMENT I

City of Cadillac - 2011 Annual IPP Report

Industrial User	Nature of Violation	Enforcement Action	Date of Enforcement Action	Date of Return to Compliance
Rec Boats Holding Inc. Trailer Plant	Copper, Cyanide, and Zinc Violations	Phone Calls, Meetings, and IPP Reports	All 2011	Pending
AAR RT	Cyanide	Phone Calls, Meetings, and IPP Reports	First and Second Quarters	Third Quarter 2011
Avon Automotive	TS, Zinc	Phone Calls, Meetings, and IPP Reports	All 2011	Pending
Palstra	Copper, Zinc	Phone Calls, Meetings, and IPP Reports	All 2011	Pending
Wexford County Landfill, LLC	Copper	Phone Calls, Meetings, and IPP Reports	All 2011	Pending
Michigan Rubber	Copper, Zinc	Phone Calls, Meetings, and IPP Reports	First and Second Quarters	Third Quarter 2011
Cadillac Castings Inc.	Cadmium, Molybdenum	Phone Calls, Meetings, and IPP Reports	All 2011	Pending

ATTACHMENT J

City of Cadillac – 2011 Annual IPP Report

Influent and Effluent Metal Analysis

Mercury Testing

Effluent Volatile Organics Analysis

Bio-Solids Analysis

Toxicity

CITY OF CADILLAC WWTP - METALS 2011

MERCURY

NOTE: Concentration in ng/l

*Mercury by EPA 1631

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011			
FEBUARY ,2011	<200 low level	0.55*	#VALUE!
MARCH ,2011			
APRIL ,2011			
MAY ,2011	<200 low level	0.55*	#VALUE!
JUNE ,2011	86.5*		
JULY ,2011			
AUGUST ,2011	<500 low level	<0.5*	#VALUE!
SEPTEMBER ,2011			
OCTOBER ,2011			
NOVEMBER ,2011	<500 low level	<0.5*	#VALUE!
DECEMBER ,2011			

CHROMIUM

Concentration in µg/l

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	1.81	0.00	100.00
FEBUARY ,2011	5.11	1.67	67.32
MARCH ,2011	5.87	0.00	100.00
APRIL ,2011	5.43	3.01	44.66
MAY ,2011	4.30	0.00	100.00
JUNE ,2011	3.56	0.00	100.00
JULY ,2011	3.65	0.00	100.00
AUGUST ,2011	4.06	0.00	100.00
SEPTEMBER ,2011	5.54	0.00	100.00
OCTOBER ,2011	2.50	0.00	100.00
NOVEMBER ,2011	5.54	0.00	100.00
DECEMBER ,2011	3.56	0.00	100.00

NICKEL

Concentration in µg/l

NOTE: Less than detect for nickel

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	<50	<50	#VALUE!
FEBUARY ,2011	<50	<50	#VALUE!
MARCH ,2011	<50	<50	#VALUE!
APRIL ,2011	<50	<50	#VALUE!
MAY ,2011	<50	<50	#VALUE!
JUNE ,2011	<50	<50	#VALUE!
JULY ,2011	<50	<50	#VALUE!
AUGUST ,2011	<50	<50	#VALUE!
SEPTEMBER ,2011	<50	<50	#VALUE!
OCTOBER ,2011	<50	<50	#VALUE!
NOVEMBER ,2011	<50	<50	#VALUE!
DECEMBER ,2011	<50	<50	#VALUE!

CITY OF CADILLAC WWTP - METALS 2011

MOLYBDENUM Concentration in µg/l

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	12.33	8.67	29.66
FEBUARY ,2011	12.46	8.66	30.46
MARCH ,2011	34.47	26.01	24.54
APRIL ,2011	50.30	49.44	1.71
MAY ,2011	46.44	52.96	0.00
JUNE ,2011	52.90	57.53	0.00
JULY ,2011	69.28	54.40	21.48
AUGUST ,2011	48.04	45.95	4.35
SEPTEMBER ,2011	78.06	65.34	16.30
OCTOBER ,2011	36.96	35.54	3.84
NOVEMBER ,2011	22.58	24.47	0.00
DECEMBER ,2011	40.18	40.12	0.15

SILVER Concentration in µg/l

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	1.02	0.00	100.00
FEBUARY ,2011	0.39	0.28	30.20
MARCH ,2011	0.73	0.43	40.41
APRIL ,2011	0.57	0.00	100.00
MAY ,2011	0.83	0.00	100.00
JUNE ,2011	1.00	0.00	100.00
JULY ,2011	3.21	0.65	79.75
AUGUST ,2011	0.39	0.00	100.00
SEPTEMBER ,2011	0.39	0.00	100.00
OCTOBER ,2011	0.27	0.00	100.00
NOVEMBER ,2011	1.03	0.00	100.00
DECEMBER ,2011	0.22	0.00	100.00

ZINC Concentration in µg/l

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	136.19	70.00	48.60
FEBUARY ,2011	163.27	87.50	46.41
MARCH ,2011	147.67	54.50	63.09
APRIL ,2011	197.60	63.00	68.12
MAY ,2011	134.00	0.00	100.00
JUNE ,2011	165.00	59.33	64.04
JULY ,2011	173.20	0.00	100.00
AUGUST ,2011	187.33	0.00	100.00
SEPTEMBER ,2011	213.00	0.00	100.00
OCTOBER ,2011	135.00	0.00	100.00
NOVEMBER ,2011	128.17	58.17	54.62
DECEMBER ,2011	178.20	75.40	57.69

CITY OF CADILLAC WWTP - METALS 2011

CADMIUM Concentration in µg/l

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	0.71	0.00	100.00
FEBUARY ,2011	0.80	0.37	53.58
MARCH ,2011	1.27	0.20	84.09
APRIL ,2011	0.43	0.00	100.00
MAY ,2011	0.24	0.00	100.00
JUNE ,2011	0.41	0.00	100.00
JULY ,2011	0.34	0.00	100.00
AUGUST ,2011	0.59	0.93	0.00
SEPTEMBER ,2011	0.49	0.32	34.62
OCTOBER ,2011	0.44	0.00	100.00
NOVEMBER ,2011	0.23	0.22	1.76
DECEMBER ,2011	0.25	0.00	100.00

LEAD Concentration in µg/l

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	2.40	0.00	100.00
FEBUARY ,2011	3.26	2.77	15.26
MARCH ,2011	3.42	0.00	100.00
APRIL ,2011	4.66	0.00	100.00
MAY ,2011	2.92	0.00	100.00
JUNE ,2011	3.03	0.00	100.00
JULY ,2011	3.84	0.00	100.00
AUGUST ,2011	7.51	0.00	100.00
SEPTEMBER ,2011	5.05	0.00	100.00
OCTOBER ,2011	2.90	0.00	100.00
NOVEMBER ,2011	2.89	2.50	13.48
DECEMBER ,2011	2.90	0.00	100.00

COPPER Concentration in µg/l

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	93.67	0.00	100.00
FEBUARY ,2011	60.67	54.50	10.17
MARCH ,2011	110.33	0.00	100.00
APRIL ,2011	96.33	0.00	100.00
MAY ,2011	84.33	0.00	100.00
JUNE ,2011	108.33	0.00	100.00
JULY ,2011	114.00	0.00	100.00
AUGUST ,2011	66.33	0.00	100.00
SEPTEMBER ,2011	135.00	0.00	100.00
OCTOBER ,2011	50.00	74.33	0.00
NOVEMBER ,2011	91.67	0.00	100.00
DECEMBER ,2011	83.00	0.00	100.00

CITY OF CADILLAC WWTP - METALS 2011

SELENIUM Concentration in µg/l

SAMPLE DATE	INFLUENT	EFFLUENT	PERCENT REMOVAL
JANUARY ,2011	<2	<2	#VALUE!
FEBUARY ,2011	<2	<2	#VALUE!
MARCH ,2013	2.07	0.00	100.00
APRIL ,2011	<2	<2	#VALUE!
MAY ,2011	<2	<2	#VALUE!
JUNE ,2011	<2	<2	#VALUE!
JULY ,2011	<2	<2	#VALUE!
AUGUST ,2011	<2	<2	#VALUE!
SEPTEMBER ,2011	<2	<2	#VALUE!
OCTOBER ,2011	<2	<2	#VALUE!
NOVEMBER ,2011	<2	<2	#VALUE!
DECEMBER ,2011	2.42	2.22	8.26

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **110542**

Date Reported : **02/11/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: *Analysis of four aqueous samples for ultra-trace mercury.*

Sample ID : **"Effluent"**

Sampled By : *AV of City of Cadillac, Water Resources*

Sample Date : **02/07/11**

Sample Time : **1019**

Date Received : **02/08/11**

Sample Type : **aqueous**

KAR Sample No. : **110542-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	02/08/11	PML	
Mercury by EPA 1631	0.6	ng/L	EPA 1631	02/09/11	PML	

Sample ID : **"Effluent, Field Duplicate"**

Sampled By : *AV of City of Cadillac, Water Resources*

Sample Date : **02/07/11**

Sample Time : **1021**

Date Received : **02/08/11**

Sample Type : **aqueous**

KAR Sample No. : **110542-02**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	02/08/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	02/09/11	PML	

Sample ID : **"Field Blank"**

Sampled By :

Sample Date : **02/07/11**

Sample Time :

Date Received : **02/08/11**

Sample Type : **aqueous**

KAR Sample No. : **110542-03**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	02/08/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	02/09/11	PML	

Sample ID : **"Trip Blank"**

Sampled By :

Sample Date :

Sample Time :

Date Received : **02/08/11**

Sample Type : **Trip Blk**

KAR Sample No. : **110542-04**


Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	02/08/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	02/09/11	PML	

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **111726**

Date Reported : **05/09/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: *Analysis of four aqueous samples for ultra-trace mercury.*

Sample ID : **"Effluent"**

Sampled By : *AJV of City of Cadillac, Water Resources*

Date Received : **05/03/11**

Sample Date : **05/02/11**

Sample Type : **aqueous**

Sample Time : **1255**

KAR Sample No. : **111726-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	05/04/11	PML	
Mercury by EPA 1631	0.6	ng/L	EPA 1631	05/05/11	PML	

Sample ID : **"Effluent, Field Duplicate"**

Sampled By : *AJV of City of Cadillac, Water Resources*

Date Received : **05/03/11**

Sample Date : **05/02/11**

Sample Type : **aqueous**

Sample Time : **1257**

KAR Sample No. : **111726-02**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	05/04/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	05/05/11	PML	

Sample ID : **"Field Blank"**

Sampled By : *AJV of City of Cadillac, Water Resources*

Date Received : **05/03/11**

Sample Date : **05/02/11**

Sample Type : **aqueous**

Sample Time :

KAR Sample No. : **111726-03**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	05/04/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	05/05/11	PML	

Sample ID : **"Trip Blank"**

Sampled By :

Date Received : **05/03/11**

Sample Date :

Sample Type : **Trip Blk**

Sample Time :

KAR Sample No. : **111726-04**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	05/04/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	05/05/11	PML	

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **113397**

Date Reported : **08/22/11**

Attest:


David R. Alkema, Lab Manager

Project

Description: *Analysis of four aqueous samples for ultra-trace mercury.*

Sample ID : **"Effluent"**

Sampled By : *AJV of City of Cadillac, Water Resources*

Sample Date : *08/10/11*

Sample Time : *1121*

Date Received : **08/11/11**

Sample Type : **aqueous**

KAR Sample No. : **113397-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	08/17/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	08/18/11	PML	

Sample ID : **"Effluent, Field Duplicate"**

Sampled By : *AJV of City of Cadillac, Water Resources*

Sample Date : *08/10/11*

Sample Time : *1122*

Date Received : **08/11/11**

Sample Type : **aqueous**

KAR Sample No. : **113397-02**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	08/17/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	08/18/11	PML	

Sample ID : **"Field Blank"**

Sampled By : *AJV of City of Cadillac, Water Resources*

Sample Date : *08/10/11*

Sample Time :

Date Received : **08/11/11**

Sample Type : **aqueous**

KAR Sample No. : **113397-03**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	08/17/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	08/18/11	PML	

Sample ID : **"Trip Blank"**

Sampled By :

Sample Date :

Sample Time :

Date Received : **08/11/11**

Sample Type : **Trip Blk**

KAR Sample No. : **113397-04**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	08/17/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	08/18/11	PML	

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **114811**

Date Reported : **11/07/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: *Analysis of four aqueous samples for ultra-trace mercury.*

Sample ID : <u>"Effluent"</u>						
Sampled By : <i>AV of City of Cadillac, Water Resources</i>				Date Received : 11/02/11		
Sample Date : 11/01/11				Sample Type : aqueous		
Sample Time : 1009				KAR Sample No. : 114811-01		
Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	11/03/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	11/04/11	PML	

Sample ID : <u>"Effluent, Field Duplicate"</u>						
Sampled By : <i>AV of City of Cadillac, Water Resources</i>				Date Received : 11/02/11		
Sample Date : 11/01/11				Sample Type : aqueous		
Sample Time : 1010				KAR Sample No. : 114811-02		
Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	11/03/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	11/04/11	PML	

Sample ID : <u>"Field Blank"</u>						
Sampled By :				Date Received : 11/02/11		
Sample Date : 11/01/11				Sample Type : aqueous		
Sample Time :				KAR Sample No. : 114811-03		
Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	11/03/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	11/04/11	PML	

Sample ID : <u>"Trip Blank"</u>						
Sampled By :				Date Received : 11/02/11		
Sample Date :				Sample Type : Trip Blk		
Sample Time :				KAR Sample No. : 114811-04		
Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	11/03/11	PML	
Mercury by EPA 1631	<0.5	ng/L	EPA 1631	11/04/11	PML	

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **112521**

Date Reported : **06/24/11**

Attest:


David R. Alkema, Lab Manager

Project

Description: *Analysis of DMR/QA Study 31 PE sample, MI0020257.*

Sample ID : **DMR-QA Low Level Mercury, Lot #Q031-931**

Sampled By :

Date Received : **03/31/11**

Sample Date :

Sample Type : **QC**

Sample Time :

KAR Sample No. : **112521-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, 1631	Completed		EPA 1631	06/03/11	PML	
Mercury by EPA 1631	86.5	ng/L	EPA 1631	06/09/11	PML	

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **110539**

Date Reported : **02/17/11**

Attest:


David R. Alkema, Lab Manager

Project

Description: *Analysis of one aqueous sample for Mercury Minimization.*

Sample ID : **"Influent"**

Sampled By : *AV of City of Cadillac, Water Resources*

Date Received : **02/08/11**

Sample Date : **02/07/11**

Sample Type : **aqueous**

Sample Time : **0906**

KAR Sample No. : **110539-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep, Hg</i>	<i>Completed</i>		<i>EPA 245.2</i>	<i>02/11/11</i>	<i>DBL</i>	
<i>Mercury, total, low level</i>	<i><0.0002</i>	<i>mg/L</i>	<i>EPA 245.2</i>	<i>02/11/11</i>	<i>DBL</i>	


LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **111711**

Date Reported : **05/09/11**

Attest:


David R. Alkema, Lab Manager

Project

Description: *Analysis of one aqueous sample for Mercury Minimization.*

Sample ID : **"Influent"**

Sampled By : *AJV of City of Cadillac, Water Resources*

Date Received : **05/03/11**

Sample Date : **05/02/11**

Sample Type : **aqueous**

Sample Time : **1250**

KAR Sample No. : **111711-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, Hg	Completed		EPA 245.2	05/05/11	DBL	
Mercury, total, low level	<0.0002	mg/L	EPA 245.2	05/05/11	DBL	

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **113393**

Date Reported : **08/18/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: *Analysis of one Influent sample for Mercury.*

Sample ID : **"Influent"**

Sampled By : *AJV of City of Cadillac, Water Resources*

Date Received : **08/11/11**

Sample Date : **08/10/11**

Sample Type : **aqueous**

Sample Time : **1135**

KAR Sample No. : **113393-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, Hg	Completed		EPA 245.2	08/16/11	DBL	
Mercury, total	<0.0005	mg/L	EPA 245.2	08/16/11	DBL	

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **114816**

Date Reported : **11/09/11**

Attest:


David R. Alkema, Lab Manager

Project

Description: *Analysis of one Influent sample for Mercury.*

Sample ID : **"Influent"**

Sampled By : *AV of City of Cadillac, Water Resources*

Date Received : **11/02/11**

Sample Date : **11/01/11**

Sample Type : **aqueous**

Sample Time : **0729**

KAR Sample No. : **114816-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep, Hg</i>	<i>Completed</i>		<i>EPA 245.2</i>	<i>11/07/11</i>	<i>DBL</i>	
<i>Mercury, total</i>	<i><0.0005</i>	<i>mg/L</i>	<i>EPA 245.2</i>	<i>11/07/11</i>	<i>DBL</i>	

LABORATORY DETAIL REPORT

Client: **City of Cadillac, Water Resources**

KAR Project No. : **110856**

Date Reported : **03/16/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: **Analysis of two aqueous samples for NPDES permit.**

Sample ID : **"Plant Effluent, Composite"**

Sampled By : **AV of City of Cadillac, Water Resources**

Date Received : **03/02/11**

Sample Date : **03/01/11**

Sample Type : **aqueous**

Sample Time : **0738**

KAR Sample No. : **110856-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	03/03/11	PML	
Antimony, total, low level	<1	ug/L	EPA 200.8	03/11/11	PML	
Arsenic, total, low level	2	ug/L	EPA 200.8	03/15/11	PML	
Barium, total, low level	15	ug/L	EPA 200.8	03/11/11	PML	
Beryllium, total, low level	<1	ug/L	EPA 200.8	03/11/11	PML	
Boron, total, low level	182	ug/L	EPA 200.7	03/15/11	DBL	
Cadmium, total, low level	<0.2	ug/L	EPA 200.8	03/15/11	PML	
Chromium, total, low level	<5	ug/L	EPA 200.8	03/11/11	PML	
Copper, total, low level	15	ug/L	EPA 200.8	03/11/11	PML	
Lead, total, low level	<1	ug/L	EPA 200.8	03/11/11	PML	
Nickel, total, low level	<5	ug/L	EPA 200.8	03/11/11	PML	
Silver, total, low level	<0.5	ug/L	EPA 200.8	03/15/11	PML	
Thallium, total, low level	<1	ug/L	EPA 200.8	03/11/11	PML	
Hardness	223	mg/L (as CaCO3)	EPA 130.2	03/11/11	PML	
Prior. Poll. BN by 625	See below		EPA 625	03/08/11	KTL	
Prior. Poll. acids by 625	See below		EPA 625	03/08/11	KTL	
Prep, SV Acid/BN	Completed		EPA 625	03/07/11	KTL	
1,2,4-Trichlorobenzene 625	<5	ug/L	EPA 625	03/08/11	KTL	
1,2-Diphenylhydrazine	<5	ug/L	EPA 625	03/08/11	KTL	
2,4,6-Trichlorophenol	<5	ug/L	EPA 625	03/08/11	KTL	
2,4-Dichlorophenol	<5	ug/L	EPA 625	03/08/11	KTL	
2,4-Dimethylphenol	<5	ug/L	EPA 625	03/08/11	KTL	
2,4-Dinitrophenol	<20	ug/L	EPA 625	03/08/11	KTL	
2,4-Dinitrotoluene	<5	ug/L	EPA 625	03/08/11	KTL	
2,6-Dinitrotoluene	<5	ug/L	EPA 625	03/08/11	KTL	
2-Chloronaphthalene	<5	ug/L	EPA 625	03/08/11	KTL	
2-Chlorophenol	<5	ug/L	EPA 625	03/08/11	KTL	
2-Methyl-4,6-dinitrophenol	<20	ug/L	EPA 625	03/08/11	KTL	
2-Nitrophenol	<5	ug/L	EPA 625	03/08/11	KTL	
3,3'-Dichlorobenzidine	<20	ug/L	EPA 625	03/08/11	KTL	
4-Bromophenyl phenyl ether	<5	ug/L	EPA 625	03/08/11	KTL	
4-Chloro-3-methylphenol	<5	ug/L	EPA 625	03/08/11	KTL	
4-Chlorophenyl phenyl ether	<5	ug/L	EPA 625	03/08/11	KTL	
4-Nitrophenol	<20	ug/L	EPA 625	03/08/11	KTL	
Acenaphthene	<5	ug/L	EPA 625	03/08/11	KTL	
Acenaphthylene	<5	ug/L	EPA 625	03/08/11	KTL	
Anthracene	<5	ug/L	EPA 625	03/08/11	KTL	
Benzidine	<50	ug/L	EPA 625	03/08/11	KTL	
Benzo(a)anthracene	<5	ug/L	EPA 625	03/08/11	KTL	
Benzo(a)pyrene	<5	ug/L	EPA 625	03/08/11	KTL	
Benzo(b)fluoranthene	<5	ug/L	EPA 625	03/08/11	KTL	
Benzo(ghi)perylene	<5	ug/L	EPA 625	03/08/11	KTL	
Benzo(k)fluoranthene	<5	ug/L	EPA 625	03/08/11	KTL	

KAR Laboratories, Inc.

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **110856**

Date Reported : **03/16/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: *Analysis of two aqueous samples for NPDES permit.*

Sample ID : **"Plant Effluent, Composite"**

Sampled By : *AV of City of Cadillac, Water Resources*

Sample Date : **03/01/11**

Sample Time : **0738**

Date Received : **03/02/11**

Sample Type : **aqueous**

KAR Sample No. : **110856-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Bis(2-chloroethoxy)methane	<5	ug/L	EPA 625	03/08/11	KTL	
Bis(2-chloroethyl)ether	<5	ug/L	EPA 625	03/08/11	KTL	
Bis(2-chloroisopropyl)ether	<5	ug/L	EPA 625	03/08/11	KTL	
Bis(2-ethylhexyl)phthalate	<5	ug/L	EPA 625	03/08/11	KTL	
Butylbenzyl phthalate	<5	ug/L	EPA 625	03/08/11	KTL	
Chrysene	<5	ug/L	EPA 625	03/08/11	KTL	
Di-n-butyl phthalate	<5	ug/L	EPA 625	03/08/11	KTL	
Di-n-octyl phthalate	<5	ug/L	EPA 625	03/08/11	KTL	
Dibenzo(ah)anthracene	<5	ug/L	EPA 625	03/08/11	KTL	
Diethyl phthalate	<5	ug/L	EPA 625	03/08/11	KTL	
Dimethyl phthalate	<5	ug/L	EPA 625	03/08/11	KTL	
Fluoranthene	<5	ug/L	EPA 625	03/08/11	KTL	
Fluorene	<5	ug/L	EPA 625	03/08/11	KTL	
Hexachlorobenzene	<5	ug/L	EPA 625	03/08/11	KTL	
Hexachlorobutadiene	<5	ug/L	EPA 625	03/08/11	KTL	
Hexachlorocyclopentadiene	<5	ug/L	EPA 625	03/08/11	KTL	
Hexachloroethane	<5	ug/L	EPA 625	03/08/11	KTL	
Indeno(123cd)pyrene	<5	ug/L	EPA 625	03/08/11	KTL	
Isophorone	<5	ug/L	EPA 625	03/08/11	KTL	
N-Nitrosodi-n-propylamine	<5	ug/L	EPA 625	03/08/11	KTL	
N-Nitrosodimethylamine	<5	ug/L	EPA 625	03/08/11	KTL	
N-Nitrosodiphenylamine	<5	ug/L	EPA 625	03/08/11	KTL	
Naphthalene by Method 625	<5	ug/L	EPA 625	03/08/11	KTL	
Nitrobenzene	<5	ug/L	EPA 625	03/08/11	KTL	
Pentachlorophenol	<5	ug/L	EPA 625	03/08/11	KTL	
Phenanthrene	<5	ug/L	EPA 625	03/08/11	KTL	
Phenol	<5	ug/L	EPA 625	03/08/11	KTL	
Pyrene	<5	ug/L	EPA 625	03/08/11	KTL	

Sample ID : **"Plant Effluent, Grab"**

Sampled By : *AV of City of Cadillac, Water Resources*

Sample Date : **03/01/11**

Sample Time : **0740**

Date Received : **03/02/11**

Sample Type : **aqueous**

KAR Sample No. : **110856-02**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Phenols, total	<0.02	mg/L	EPA 420.4	03/04/11	ALK	
Prior. Poll. volatiles	See below		EPA 624	03/07/11	JAR	
Prep. VOA	Completed		EPA 624	03/07/11	JAR	
1,1,1-Trichloroethane	<1	ug/L	EPA 624	03/07/11	JAR	
1,1,2,2-Tetrachloroethane	<1	ug/L	EPA 624	03/07/11	JAR	

KAR Laboratories, Inc.

LABORATORY DETAIL REPORT

Client: **City of Cadillac, Water Resources**

KAR Project No. : **110856**

Date Reported : **03/16/11**

Attest:


David R. Alkema, Lab Manager

Project

Description: **Analysis of two aqueous samples for NPDES permit.**

Sample ID : **"Plant Effluent, Grab"**

Sampled By : **AV of City of Cadillac, Water Resources**

Sample Date : **03/01/11**

Sample Time : **0740**

Date Received : **03/02/11**

Sample Type : **aqueous**

KAR Sample No. : **110856-02**


Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,1,2-Trichloroethane	<1	ug/L	EPA 624	03/07/11	JAR	
1,1-Dichloroethane	<1	ug/L	EPA 624	03/07/11	JAR	
1,1-Dichloroethene	<1	ug/L	EPA 624	03/07/11	JAR	
1,2-Dichlorobenzene	<1	ug/L	EPA 624	03/07/11	JAR	
1,2-Dichloroethane	<1	ug/L	EPA 624	03/07/11	JAR	
1,2-Dichloropropane	<1	ug/L	EPA 624	03/07/11	JAR	
1,3-Dichlorobenzene	<1	ug/L	EPA 624	03/07/11	JAR	
1,4-Dichlorobenzene	<1	ug/L	EPA 624	03/07/11	JAR	
2-Chloroethylvinyl ether	<10	ug/L	EPA 624	03/07/11	JAR	
Acrolein	<20	ug/L	EPA 624	03/07/11	JAR	
Acrylonitrile	<2	ug/L	EPA 624	03/07/11	JAR	
Benzene	<1	ug/L	EPA 624	03/07/11	JAR	
Bromodichloromethane	<1	ug/L	EPA 624	03/07/11	JAR	
Bromoform	<1	ug/L	EPA 624	03/07/11	JAR	
Bromomethane	<1	ug/L	EPA 624	03/07/11	JAR	
Carbon tetrachloride	<1	ug/L	EPA 624	03/07/11	JAR	
Chlorobenzene	<1	ug/L	EPA 624	03/07/11	JAR	
Chloroethane	<1	ug/L	EPA 624	03/07/11	JAR	
Chloroform	<1	ug/L	EPA 624	03/07/11	JAR	
Chloromethane	<1	ug/L	EPA 624	03/07/11	JAR	
Cis-1,3-Dichloropropene	<1	ug/L	EPA 624	03/07/11	JAR	
Dibromochloromethane	<1	ug/L	EPA 624	03/07/11	JAR	
Ethylbenzene	<1	ug/L	EPA 624	03/07/11	JAR	
Methylene chloride	<1	ug/L	EPA 624	03/07/11	JAR	
Tetrachloroethene	<1	ug/L	EPA 624	03/07/11	JAR	
Toluene	<1	ug/L	EPA 624	03/07/11	JAR	
Trans-1,2-Dichloroethene	<1	ug/L	EPA 624	03/07/11	JAR	
Trans-1,3-Dichloropropene	<1	ug/L	EPA 624	03/07/11	JAR	
Trichloroethene	<1	ug/L	EPA 624	03/07/11	JAR	
Trichlorofluoromethane	<1	ug/L	EPA 624	03/07/11	JAR	
Vinyl chloride	<1	ug/L	EPA 624	03/07/11	JAR	

LABORATORY DETAIL REPORT

Client: **City of Cadillac, Water Resources**

KAR Project No. : **114264**

Date Reported : **10/18/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: **Analysis of two aqueous samples for NPDES permit.**

Sample ID : **"Plant Effluent, Composite"**

Sampled By : **AV of City of Cadillac, Water Resources**

Date Received : **10/04/11**

Sample Date : **10/03/11**

Sample Type : **aqueous**

Sample Time : **0745**

KAR Sample No. : **114264-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, metals	Completed		EPA 30xx,200.x	10/05/11	DBL	
Antimony, total, low level	<1	ug/L	EPA 200.8	10/11/11	PML	
Arsenic, total, low level	1	ug/L	EPA 200.8	10/11/11	PML	
Barium, total, low level	20	ug/L	EPA 200.8	10/11/11	PML	
Beryllium, total, low level	<1	ug/L	EPA 200.8	10/11/11	PML	
Boron, total, low level	216	ug/L	EPA 200.7	10/14/11	DBL	
Cadmium, total, low level	<0.2	ug/L	EPA 200.8	10/11/11	PML	
Chromium, total, low level	<5	ug/L	EPA 200.8	10/11/11	PML	
Copper, total, low level	8	ug/L	EPA 200.8	10/11/11	PML	
Lead, total, low level	<1	ug/L	EPA 200.8	10/11/11	PML	
Nickel, total, low level	<5	ug/L	EPA 200.8	10/11/11	PML	
Silver, total, low level	<0.5	ug/L	EPA 200.8	10/11/11	PML	
Thallium, total, low level	<1	ug/L	EPA 200.8	10/11/11	PML	
Hardness	217	mg/L (as CaCO3)	EPA 130.2	10/10/11	PML	
Prior. Poll. BN by 625	See below		EPA 625	10/11/11	KTL	
Prior. Poll. acids by 625	See below		EPA 625	10/11/11	KTL	
Prep, SV Acid/BN	Completed		EPA 625	10/07/11	KTL	
1,2,4-Trichlorobenzene 625	<5	ug/L	EPA 625	10/11/11	KTL	
1,2-Diphenylhydrazine	<5	ug/L	EPA 625	10/11/11	KTL	
2,4,6-Trichlorophenol	<5	ug/L	EPA 625	10/11/11	KTL	
2,4-Dichlorophenol	<5	ug/L	EPA 625	10/11/11	KTL	
2,4-Dimethylphenol	<5	ug/L	EPA 625	10/11/11	KTL	
2,4-Dinitrophenol	<20	ug/L	EPA 625	10/11/11	KTL	
2,4-Dinitrotoluene	<5	ug/L	EPA 625	10/11/11	KTL	
2,6-Dinitrotoluene	<5	ug/L	EPA 625	10/11/11	KTL	
2-Chloronaphthalene	<5	ug/L	EPA 625	10/11/11	KTL	
2-Chlorophenol	<5	ug/L	EPA 625	10/11/11	KTL	
2-Methyl-4,6-dinitrophenol	<20	ug/L	EPA 625	10/11/11	KTL	
2-Nitrophenol	<5	ug/L	EPA 625	10/11/11	KTL	
3,3'-Dichlorobenzidine	<20	ug/L	EPA 625	10/11/11	KTL	
4-Bromophenyl phenyl ether	<5	ug/L	EPA 625	10/11/11	KTL	
4-Chloro-3-methylphenol	<5	ug/L	EPA 625	10/11/11	KTL	
4-Chlorophenyl phenyl ether	<5	ug/L	EPA 625	10/11/11	KTL	
4-Nitrophenol	<20	ug/L	EPA 625	10/11/11	KTL	
Acenaphthene	<5	ug/L	EPA 625	10/11/11	KTL	
Acenaphthylene	<5	ug/L	EPA 625	10/11/11	KTL	
Anthracene	<5	ug/L	EPA 625	10/11/11	KTL	
Benzidine	<50	ug/L	EPA 625	10/11/11	KTL	
Benzo(a)anthracene	<5	ug/L	EPA 625	10/11/11	KTL	
Benzo(a)pyrene	<5	ug/L	EPA 625	10/11/11	KTL	
Benzo(b)fluoranthene	<5	ug/L	EPA 625	10/11/11	KTL	
Benzo(ghi)perylene	<5	ug/L	EPA 625	10/11/11	KTL	
Benzo(k)fluoranthene	<5	ug/L	EPA 625	10/11/11	KTL	

KAR Laboratories, Inc.

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **114264**

Date Reported : **10/18/11**

Attest:


David R. Alkema, Lab Manager

Project

Description: *Analysis of two aqueous samples for NPDES permit.*

Sample ID : **"Plant Effluent, Composite"**

Sampled By : *AV of City of Cadillac, Water Resources*

Sample Date : **10/03/11**

Sample Time : **0745**

Date Received : **10/04/11**

Sample Type : **aqueous**

KAR Sample No. : **114264-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Bis(2-chloroethoxy)methane	<5	ug/L	EPA 625	10/11/11	KTL	
Bis(2-chloroethyl)ether	<5	ug/L	EPA 625	10/11/11	KTL	
Bis(2-chloroisopropyl)ether	<5	ug/L	EPA 625	10/11/11	KTL	
Bis(2-ethylhexyl)phthalate	<5	ug/L	EPA 625	10/11/11	KTL	
Butylbenzyl phthalate	<5	ug/L	EPA 625	10/11/11	KTL	
Chrysene	<5	ug/L	EPA 625	10/11/11	KTL	
Di-n-butyl phthalate	<5	ug/L	EPA 625	10/11/11	KTL	
Di-n-octyl phthalate	<5	ug/L	EPA 625	10/11/11	KTL	
Dibenzo(ah)anthracene	<5	ug/L	EPA 625	10/11/11	KTL	
Diethyl phthalate	<5	ug/L	EPA 625	10/11/11	KTL	
Dimethyl phthalate	<5	ug/L	EPA 625	10/11/11	KTL	
Fluoranthene	<5	ug/L	EPA 625	10/11/11	KTL	
Fluorene	<5	ug/L	EPA 625	10/11/11	KTL	
Hexachlorobenzene	<5	ug/L	EPA 625	10/11/11	KTL	
Hexachlorobutadiene	<5	ug/L	EPA 625	10/11/11	KTL	
Hexachlorocyclopentadiene	<5	ug/L	EPA 625	10/11/11	KTL	
Hexachloroethane	<5	ug/L	EPA 625	10/11/11	KTL	
Indeno(123cd)pyrene	<5	ug/L	EPA 625	10/11/11	KTL	
Isophorone	<5	ug/L	EPA 625	10/11/11	KTL	
N-Nitrosodi-n-propylamine	<5	ug/L	EPA 625	10/11/11	KTL	
N-Nitrosodimethylamine	<5	ug/L	EPA 625	10/11/11	KTL	
N-Nitrosodiphenylamine	<5	ug/L	EPA 625	10/11/11	KTL	
Naphthalene by Method 625	<5	ug/L	EPA 625	10/11/11	KTL	
Nitrobenzene	<5	ug/L	EPA 625	10/11/11	KTL	
Pentachlorophenol	<5	ug/L	EPA 625	10/11/11	KTL	
Phenanthrene	<5	ug/L	EPA 625	10/11/11	KTL	
Phenol	<5	ug/L	EPA 625	10/11/11	KTL	
Pyrene	<5	ug/L	EPA 625	10/11/11	KTL	

Sample ID : **"Plant Effluent, Grab"**

Sampled By : *AV of City of Cadillac, Water Resources*

Sample Date : **10/03/11**

Sample Time : **0830**

Date Received : **10/04/11**

Sample Type : **aqueous**

KAR Sample No. : **114264-02**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Phenols, total	<0.02	mg/L	EPA 420.4	10/17/11	ALK	
Prior. Poll. volatiles	See below		EPA 624	10/10/11	JAR	
Prep. VOA	Completed		EPA 624	10/10/11	JAR	
1,1,1-Trichloroethane	<1	ug/L	EPA 624	10/10/11	JAR	
1,1,2,2-Tetrachloroethane	<1	ug/L	EPA 624	10/10/11	JAR	

KAR Laboratories, Inc.

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **114264**

Date Reported : **10/18/11**

Attest:


David R. Alkema, Lab Manager

Project

Description: *Analysis of two aqueous samples for NPDES permit.*

Sample ID : **"Plant Effluent, Grab"**

Sampled By : *AV of City of Cadillac, Water Resources*

Date Received : **10/04/11**

Sample Date : **10/03/11**

Sample Type : **aqueous**

Sample Time : **0830**

KAR Sample No. : **114264-02**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
1,1,2-Trichloroethane	<1	ug/L	EPA 624	10/10/11	JAR	
1,1-Dichloroethane	<1	ug/L	EPA 624	10/10/11	JAR	
1,1-Dichloroethene	<1	ug/L	EPA 624	10/10/11	JAR	
1,2-Dichlorobenzene	<1	ug/L	EPA 624	10/10/11	JAR	
1,2-Dichloroethane	<1	ug/L	EPA 624	10/10/11	JAR	
1,2-Dichloropropane	<1	ug/L	EPA 624	10/10/11	JAR	
1,3-Dichlorobenzene	<1	ug/L	EPA 624	10/10/11	JAR	
1,4-Dichlorobenzene	<1	ug/L	EPA 624	10/10/11	JAR	
2-Chloroethylvinyl ether	<10	ug/L	EPA 624	10/10/11	JAR	
Acrolein	<20	ug/L	EPA 624	10/10/11	JAR	
Acrylonitrile	<2	ug/L	EPA 624	10/10/11	JAR	
Benzene	<1	ug/L	EPA 624	10/10/11	JAR	
Bromodichloromethane	<1	ug/L	EPA 624	10/10/11	JAR	
Bromoform	<1	ug/L	EPA 624	10/10/11	JAR	
Bromomethane	<1	ug/L	EPA 624	10/10/11	JAR	
Carbon tetrachloride	<1	ug/L	EPA 624	10/10/11	JAR	
Chlorobenzene	<1	ug/L	EPA 624	10/10/11	JAR	
Chloroethane	<1	ug/L	EPA 624	10/10/11	JAR	
Chloroform	<1	ug/L	EPA 624	10/10/11	JAR	
Chloromethane	<1	ug/L	EPA 624	10/10/11	JAR	
Cis-1,3-Dichloropropene	<1	ug/L	EPA 624	10/10/11	JAR	
Dibromochloromethane	<1	ug/L	EPA 624	10/10/11	JAR	
Ethylbenzene	<1	ug/L	EPA 624	10/10/11	JAR	
Methylene chloride	<1	ug/L	EPA 624	10/10/11	JAR	
Tetrachloroethene	<1	ug/L	EPA 624	10/10/11	JAR	
Toluene	<1	ug/L	EPA 624	10/10/11	JAR	
Trans-1,2-Dichloroethene	<1	ug/L	EPA 624	10/10/11	JAR	
Trans-1,3-Dichloropropene	<1	ug/L	EPA 624	10/10/11	JAR	
Trichloroethene	<1	ug/L	EPA 624	10/10/11	JAR	
Trichlorofluoromethane	<1	ug/L	EPA 624	10/10/11	JAR	
Vinyl chloride	<1	ug/L	EPA 624	10/10/11	JAR	

Parameter	02/86	09/86	8/86	10/86	3/87	11/87	4/88	8/88	12/88	3/89	10/89	2/90	11/90	5/91	11/91	5/92	11/92	5/93	9/93	11/93	4/94	9/94
Kjeldahl Nitrogen %			2.8	2.4	3.2	3.3	3.1	2.1	5.5	3.9		4.8	9.4	1.5	4.7	4.3	2.2	13.8	8.8	11	5	6.1
Ammonia Nitrogen %			2.1	1.7	2.7	2.6	2	2	2.8	2.7	2.4	1.5	3.3	1	2.4	2.2	1.1	3.8	2.4	2.5	1.6	
Nitrate Nitrogen %				0.09	0.1	0.14	0.13	0.13		0.07	0.02	<0.003	0.0004	0.002	0.08	0.027	<0.0001	<0.0001	<0.0003	<0.0003	<0.0004	<0.001
Total Phosphorus %			3.3	2.9	2.2	4.4	4.2	4	3.9	3.7	8.8	11	3.3	4	3.5	4	5	4.2	3.8	0.4	3.8	3.6
Total Potassium mg/kg	2078	2221	18900		1872	2395	2000	1610	3100	28000	30000	27000	33000	35000	40000	43000	32000	42000	41000		37000	33000
Calcium mg/kg	38101	39691																			4800	3800
Magnesium mg/kg	92	93																			2700	2100
Sodium mg/kg																					2200	2700
Chloride mg/kg																					420	12000
Sulfate mg/kg																					7900	7700
Aluminum mg/kg																						
Cadmium mg/kg	8.8	10.1			8.1	7.4	7.8	11.4	7.8	10.5	<5.0	2.7	<8.4	4.8	<2.5	<2.3	3.9	<2.4	<2.6	<3.8	<2.1	<1.7
Chromium mg/kg	124	131			77	72	78	75	140	128	63	119	120	350	280	160	180	190	320	280	170	100
Copper mg/kg	840		805		810	731	760	655	830	766	775	855	1100	930	950	850	780	980	940	700	870	840
Lead mg/kg	192		272		216	112	100	173	167	224	200	250	210	270	250	200	210	250	240	170	200	150
Nickel mg/kg	38		41		57	75	81	98	78	89	<10	66	26	22	35	32	47	85	53	43	31	40
Zinc mg/kg	1273		1151		1754	1337	1280	1709	1580	1648	1600	1818	1500	2000	1600	1500	1300	1400	1300	1100	1200	1200
Arsenic mg/kg					<0.1	0.15			1.4	2.3	<3.9	<5.1	<5.4	<33	<25	<59	<13	<4.8	5.8	8.8	31	20
Mercury mg/kg					0.09	0.2			1.1	0.9	0.23	<1.0	<3.1	<19	<3.0	<2.4	1	<8.8	<1.8	<1.5	<1.7	<0.9
Silicon mg/kg						88						820	1400			<45	520	2800	2000		330	1800
Molybdenum mg/kg					0.51								<5.4									
Selenium mg/kg					<0.1								<3.1									
Total Cyanide mg/kg									<14	9.4	<10	<10										
Bis-phthalate mg/kg			33		500	14			40	<0.05	<0.6	3.7				19	180	130	2.8		520	5.3
Methylene Chloride mg/kg					0.28	0.008			0.28	<0.25	<0.01	<0.10	<0.10			<0.031	<0.024	<0.030	<0.825		0.75	<0.82
Toluene mg/kg			0.65		4.9	0.15			5	<0.25	0.04	<0.05	<0.05			0.52	1.3	1.9	<0.025		1	<0.82
1,1,1-TCA mg/kg					<0.125	0.082			<0.1	<0.25	<0.05	<0.05	<0.05			<0.37	<0.024	<0.030	<0.825		<0.025	<0.82
Ethylbenzene mg/kg											0.068		<0.05			0.098	0.089	0.077	<0.825		<0.025	<0.82
Phenol mg/kg													0.096			<5.0	<82	<20	<1.5		<1.6	<0.33
Dichlorobenzene, 1,4- mg/kg													0.033			<5.0	<82	<20	<1.5		<0.010	<0.33
Phenanthrene mg/kg													0.04			<5.0	<82	<20	<1.5		<1.6	<0.33
Pyrene mg/kg													0.053			<5.0	<82	<20	<1.25		<1.6	<0.33
Acetone mg/kg																0.3	1.7	0.88	<0.825		18	8.1
Xylene(s) mg/kg																0.132	0.164	0.101	<0.825		<0.025	<0.82
Carbon Disulfide mg/kg																	0.044	<0.030	<0.825		0.58	<0.82
2-Butanone mg/kg																	0.7	0.21	<0.825		3.3	1.4

Month and Year of Analysis

Month and Year of Analysis																									
10/84	4/85	8/85	10/85	05/86	10/86	05/87	10/87	05/88	10/88	4/89	10/89	04/90	10/90	04/91	10/91	05/92	09/92	05/93	10/93	04/94	10/94	10/95	01/96	04/96	08/96
5.8	4.7	5.6	5.8	5.7	4.7	4.5	5.7	5.7	2.3	5.5	5.2	5.1	6.1	4.5	7	5.4	4.3	4.9	5.1	7.99	6.31	5.53	7.8	9.55	8.02
2.3	1.9	2.5	1.8	1.8	2.1	1.9	3.2	2.8	1.1	2.8	2.8	2.6	2.7	1.7	3.8	2.8	2	1.9	2.3	5.5	3.2	0.7	6.4	6.3	5.2
<0.001	<0.02	<0.02	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	
3.2	3.1	2	3.4	2.9	3.1	3.1	3.0	2.9	1.2	3.2	5.0	6.3	4.4	5.4	4.1	3.5	4.4	2.5	4.4	3.8	3.9	6.0	4.4	4.1	3.5
1800	2480	3310	2120	2220	1990	3410	2400	2850	3070	2270	2470	1980	2170	1410	3490	2550	2180	1510	1980	6020	3070	2550	7700	8200	4860
24000	32300	38100	34400	33700	34300	27800	35400	35100	63300	33100	35100	28700	28500	25300	31000	28000	27500	25300	25200	28700	30000	32100	38500	34800	31900
2800	4280	4420	4500	4760	4870	3880	4570	4800	18700	3744	4170	4020	4240	3530	4540	4070	4300	3850	3710	5080	4440	4880	9600	9400	5550
2400	3160	3870	3220	2980	3080	3010	3340	4210	2070	4150	3700	3960	3440	2030	5430	3580	2880	2320	2850	9340	4940	5140	18000	18200	9720
3800	3700	4280	3580	4840	12900	2870	4120	4570	2320	4480	4320	4330	3370	1990	5700	4040	2810	3110	2420	10300	5380	6520	21400	18200	11900
2000	2820	2300	10200	<2500	<2500	<5000	<7000	<2500	374	1310	715	<300	<275	2340	1220	2230	2260	477	10800	808	<351	814	400	8050	<848
5000	8130	8840	8530	9140	8830	7010	6800	7500	13200	7880	7890	5980	9810	5440	5300	5240	8180	8110	8340	8690	7240	8950	5340	6830	7880
<1.4	<20	<20	12.1	13.4	10	37.7	<15	7	<1	6.84	7.9	8.7	5.9	4.5	4.3	3.7	3.5	2.1	7.3	2.8	4	10	5	5.5	8.3
80	113	110	123	135	90	105	99	102	75	143	107	125	119	104	119	113	109	114	101	90.7	117	109	105	105	134
580	880	1020	893	1010	870	830	880	912	413	856	883	581	954	950	821	831	903	825	869	894	1070	848	850	948	1080
110	180	168	169	150	98	115	118	143	67	128	142	136	116	103	88	82	82	61	61	48	76	<50	51	48	<125
27	11	55	58	44	32	40	37	48	32	57	38	50	45	44	49	25	31	28	25	27	30	33	35	28	<50
850	1150	1350	1280	1310	2050	2050	1920	3200	1030	2090	1880	1830	2570	1830	1880	1750	1430	1700	1580	1370	2050	4030	1740	1680	1700
10	<30	<30	<50	23.5	<23	20.8	<25	<25	11	12	24	25.2	28.9	25.6	20.1	27.4	20.3	21	22.6	25	28.3	35	19	28	20
0.8	<20	<20	<5	<20	2.5	1.8	<15	0.9	1.1	1.2	0.4	1.4	1.5	0.59	1.5	<5	6	2.59	1.8	0.88	1.4	1.49	1.16	1	1.2
1800																									
6	<30	<30	33	22	45	42	55	65	27	62	75	45	37	<12	48	38	37	37	34	31.5	42	34	34	28	<50
<1.1	<20	<20	<10	<4.2	<5.0	<15.0	<25	<12.1	<2	<15	6.5	1.8	<8	5	<9	<8.5	4.3	<10	4.1	<8.8	9.5	<10	<10	<8	
	<1.1	<9	140	<50	<250	<200		34		64		80		110		71		35		53				80	
	<1	<0.1	<0.05	<0.05	<0.05	<0.1		0.1		0.3	<1	<1	<1	<1	<1	<1	<1	<5		<1			<5	<5	
	0.4	0.22	2.2	3.8	0.8	2		0.2		<1		<1	<1	<1	<1	<1	<1	1.5		<1			<5	<5	
	<1	<0.1	<0.05	<0.05	<0.05	<0.1		<0.1		<0.1	<0.1	<1	<1	<1	<1	<1	<1	<5		<1			<5	<5	
	<0.1	<0.1	<0.1	0.075	<0.05	0.13		<0.1		<0.1	<0.1	<1	<1	<1	<1	<1	<1	<5		<1			0.5		
	<0.2	<9	<8	<25	<250	<200				<0.8	<9.5	<9.5	<9.5	<5.2	<5.2	<8.5	<8.5	<8.8		<2.3			<3.2		
	<0.2	<0.1	<8	<0.05	<250			0.3		<0.1	<9.5	<9.5	<9.5	<5.2	<5.2	<8.5	<8.5	<5		<1			<5		
	<0.2	<8	<8	<25	<250					<0.8	<9.5	<9.5	<9.5	<5.2	<5.2	<8.5	<8.5	<8.8		<2.3			<3.2		
	<0.2	<9	<8	<25	<250					<0.8	<9.5	<9.5	<9.5	<5.2	<5.2	<8.5	<8.5	<8.8		<2.3			<3.2		

09/07		10/07	05/08	11/08	05/09	11/09	3/10	9/10	EPA 503 Class "A" Limits		EPA 503 Ceiling Limits	Average 1986 to Present	Std. Dev. % STD DEV	
9.2	3.0	6.4	8.36	12.2	15.6	7.9	7.39					5.8	2.3	39
2.8	11.8	3.4	2.6	7.1	10.2	4.1	3.2					3.0	1.0	34
0.053	0.017	0.0449	<3.4	<87.1	<124	<0.47	<0.47					0.1	0.0	77
3.4	2.8	3.5	4.9	3.4	3.6	4.32	2.61					3.9	1.7	44
4180	1550	3910	2840	10400	9880	4410	3660					2899.0	1115.2	37
33200	25700	30200	33200	48900	47200	37100	32500					33225.3	7218.8	22
5070	3820	4900	4670	8850	6700	4830	4690					4637.8	2878.8	58
8220	2840	8140	5550	16400	18700	7190	6390					5431.8	3244.4	80
10500	3210	11000	7070	23800	25500	8500	8850					8657.6	3950.3	58
924	4890	3850	1740	28500	15900	9910	<483					4268.8	3288.4	77
5820	6110	6820	8870	8320	5840	6570	7170					7027.1	2056.3	29
4	8	10.8	13.4	11	11.4	9.3	7.5	39.0	85.0			8.2	6.2	75
115	118	113	108	137	82	89	93	1200.0	3000.0			128.1	61.8	49
758	884	1030	1030	1350	935	984	903	1500.0	4300.0			879.8	118.8	13
<50	65	50	81	48	<88	<48	<82	300.0	840.0			144.2	64.4	45
27	28	22	28	31	<88	<37	<37	420.0	420.0			42.5	17.8	42
1480	1780	1880	1930	1850	1760	1980	1680	2800.0	7500.0			1688.7	545.8	33
25	28	33	28.4	31	28.4	20.6	28.5	41.0	75.0			18.7	10.0	51
1.05	1.18	0.83	0.84	1.89	1.43	1	0.84	17.0	57.0			1.2	1.0	84
												1282.0	852.7	67
34	34	35	37	38	<88	<37	37	75.0	35.0			35.0	17.7	50
<10	5	<5	<7	<10	<12.5	<5	<5	39.0	100.0			4.7	2.6	57
												9.4	0.0	0
55	<2000			33000		<15000						1595.9	148.2	8
<2	<2			<10000		<2500						0.3	0.2	82
<2	<2			<10000		<2500						1.6	1.6	100
<2	<2			<5000		<2500						0.0	0.0	0
<2	<2			<5000		<2500						0.1	0.0	14
<1.2	<2300			<32000		<15000						0.1	0.0	0
<2	<2300			<10000		<2500						0.3	0.0	0
<1.2	<2300			<32000		<15000						0.0	0.0	0
<1.2	<2300			<32000		<15000						0.1	0.0	0
												5.8	6.7	116
												0.1	0.0	19
												0.3	0.3	88
												1.2	1.2	84

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **111573**

Date Reported : **05/04/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: *Analysis of one sludge sample for Spring Biosolids.*

Sample ID : **"Tank #4"**

Sampled By : *DG of City of Cadillac, Water Resources*

Sample Date : **04/18/11**

Sample Time :

Date Received : **04/20/11**

Sample Type : **sludge**

KAR Sample No. : **111573-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep, Hg	Completed		EPA 7471A	04/27/11	DBL	
Prep, metals	Completed		EPA 3050	04/26/11	PML	
Aluminum, total	8680	mg/kg total solids	EPA 6010B	04/29/11	DBL	Detection limit = 434
Arsenic, total	30.9	mg/kg total solids	EPA 6020	04/28/11	PML	Detection limit = 20
Cadmium, total	12.2	mg/kg total solids	EPA 6020	04/28/11	PML	Detection limit = 4
Calcium, total	78,100	mg/kg total solids	EPA 6010B	04/29/11	DBL	Detection limit = 434
Chromium, total	168	mg/kg total solids	EPA 6020	04/28/11	PML	Detection limit = 20
Copper, total	1470	mg/kg total solids	EPA 6020	04/28/11	PML	Detection limit = 20
Lead, total, by ICP	<218	mg/kg total solids	EPA 6010B	04/29/11	DBL	
Magnesium, total	11,900	mg/kg total solids	EPA 6010B	04/29/11	DBL	Detection limit = 434
Mercury, total	5.13	mg/kg total solids	EPA 7471A	04/27/11	DBL	Detection limit = 0.28
Molybdenum, total	49.8	mg/kg total solids	EPA 6020	04/28/11	PML	Detection limit = 20
Nickel, total	41.3	mg/kg total solids	EPA 6020	04/28/11	PML	Detection limit = 20
Potassium, total	14,100	mg/kg total solids	EPA 6010B	04/29/11	DBL	Detection limit = 434
Selenium, total	<20	mg/kg total solids	EPA 6020	04/28/11	PML	Elevated detection limit due to low solids content.
Silver, total	11.7	mg/kg total solids	EPA 6020	04/28/11	PML	Detection limit = 4
Sodium, total	23,800	mg/kg total solids	EPA 6010B	04/29/11	DBL	Detection limit = 4340
Zinc, total	2850	mg/kg total solids	EPA 6010B	04/29/11	DBL	Detection limit = 87
Chloride	33,600	mg/kg total solids	EPA 300.0A	04/29/11	ALK	Detection limit = 893
Nitrogen, ammonia	146,000	mg/kg total solids	EPA 350.1	05/03/11	ALK	Detection limit = 17,900
Nitrogen, nitrate	<18	mg/kg total solids	EPA 353.2	04/22/11	DRA	
Nitrogen, total kjeldahl	232,000	mg/kg total solids	EPA 351.2	05/02/11	JHB	Detection limit = 8930
Phosphorus, total (as P)	51,900	mg/kg total solids	SM 4500-P B5,E	04/28/11	JHB	Detection limit = 1790
Solids, total	0.56	% by weight	EPA 160.3	04/21/11	JHB	Detection limit = 0.01
Solids, volatile	58.44	% of total solids	EPA 160.4	04/21/11	JHB	Detection limit = 0.01
Sulfate	2490	mg/kg total solids	EPA 300.0A	04/29/11	ALK	Detection limit = 1790
Waste pH	8.1	S.U.	EPA 9045C	05/04/11	GJE	

LABORATORY DETAIL REPORT

Client: *City of Cadillac, Water Resources*

KAR Project No. : **113960**

Date Reported : **09/29/11**

Attest: 
David R. Alkema, Lab Manager

Project

Description: *Analysis of one sludge sample for Fall Biosolids.*

Sample ID : **"Digester"**

Sampled By : *DR of City of Cadillac, Water Resources*

Date Received : **09/15/11**

Sample Date : **09/14/11**

Sample Type : **sludge**

Sample Time : **1315**

KAR Sample No. : **113960-01**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
Prep. Hg	Completed		EPA 7471A	09/22/11	DBL	
Prep. metals	Completed		EPA 3050	09/26/11	PML	
Aluminum, total	6010	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 115
Arsenic, total	29.3	mg/kg total solids	EPA 6020	09/29/11	PML	Detection limit = 3
Cadmium, total	5.9	mg/kg total solids	EPA 6020	09/29/11	PML	Detection limit = 0.6
Calcium, total	36,800	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 115
Chromium, total	86.9	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 12
Copper, total	946	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 12
Lead, total, by ICP	40.4	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 12
Magnesium, total	4430	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 115
Mercury, total	1.22	mg/kg total solids	EPA 7471A	09/22/11	DBL	Detection limit = 0.16
Molybdenum, total	53.2	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 12
Nickel, total	23.7	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 12
Potassium, total	3230	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 115
Selenium, total	4.8	mg/kg total solids	EPA 6020	09/29/11	PML	Detection limit = 3
Silver, total	7.6	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 6
Sodium, total	4420	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 115
Zinc, total	1510	mg/kg total solids	EPA 6010B	09/28/11	PML	Detection limit = 12
Chloride	5730	mg/kg total solids	EPA 300.0A	09/26/11	ALK	Detection limit = 147
Nitrogen, ammonia	29,800	mg/kg total solids	EPA 350.1	09/23/11	JWW	Detection limit = 585
Nitrogen, nitrate	<30	mg/kg total solids	EPA 353.2	09/27/11	ALK	
Nitrogen, total kjeldahl	69,800	mg/kg total solids	EPA 351.2	09/26/11	JHB	Detection limit = 2930
Phosphorus, total (as P)	35,100	mg/kg total solids	SM 4500-P B5,E	09/23/11	JHB	Detection limit = 2930
Solids, total	3.42	% by weight	EPA 160.3	09/16/11	JWW	Detection limit = 0.01
Solids, volatile	57.09	% of total solids	EPA 160.4	09/16/11	JWW	Detection limit = 0.01
Sulfate	350	mg/kg total solids	EPA 300.0A	09/26/11	ALK	Detection limit = 300
Waste pH	7.9	S.U.	EPA 9045C	09/26/11	HES	

TOXICITY TESTING SUMMARY - 2011

TESTING FACILITY	DATE OF TEST	TYPE OF TEST	TEST RESULTS
Paragon Laboratories	1/6- 1/13,2011	WET, C.dudia	No toxicity
Paragon Laboratories	2/10-2/17, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	3/3-3/10, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	4/7-4/14, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	5/5-5/12, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	6/9-6/16, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	7/12-7/19, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	8/4-8/11, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	9/8-9/15, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	10/6-10/13, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	11/3-11/15, 2011	WET, C.dudia	No toxicity
Paragon Laboratories	12/8-12/15, 2011	WET, C.dudia	No toxicity