

PUBLIC NOTICE

Date: August 20, 2013
Permit No. MI0020257
Cadillac WWTP

The Department of Environmental Quality (Department) proposes to reissue a discharge permit to: the City of Cadillac for the Cadillac Wastewater Treatment Plant (WWTP) located at 1121 Plett Road, Cadillac, Michigan 49601. The applicant collects and treats municipal wastewater from the City of Cadillac and Haring, Cherry Grove & Clam Lake Townships. The applicant discharges treated municipal wastewater to the Clam River, in the NE1/4, NE1/4, Section 33, Town 22N, Range 9W, Wexford County.

The draft permit includes the following modifications to the previously-issued permit: The final effluent limitation for Total Mercury has been changed to 2.0 ng/l, which is the Discharge-Specific Level Currently Achievable based on a multiple discharger variance from the water quality-based effluent limit of 1.3 ng/l, pursuant to Rule 323.1103(9) of the Michigan Water Quality Standards. Ammonia limits for December through April are lowered. Monitoring for Total Zinc and Total Selenium are removed because there is not a reasonable potential for either parameter to be discharged at levels exceeding Michigan Water Quality Standards (WQS). Limits are added for Available Cyanide because previous monitoring showed there is a reasonable potential for Available Cyanide to be discharged at concentrations exceeding Michigan WQS. Monitoring is added for Total Copper due to elevated concentrations of copper found in the final effluent. Acute and Chronic Toxicity testing frequency is reduced from monthly to quarterly. Storm water requirements are removed because storm water associated with industrial activities is no longer generated at the WWTP. Requirements for Asset Management are added.

Comments or objections to the draft permit received by September 19, 2013, will be considered in the final decision to issue the permit. Persons desiring information regarding the draft permit, procedures for commenting, or requesting a hearing should contact Mike Bitondo, Permits Section, Water Resources Division, Department of Environmental Quality, P.O. Box 30458, Lansing, Michigan 48909, telephone: 517-335-3303, e-mail: bitondom@michigan.gov.

Copies of the permit application, Public Notice, Fact Sheet, and draft permit may be obtained via the Internet (<http://www.deq.state.mi.us/owis> - click on 'Permits on Public Notice') or at the Water Resources Division Cadillac District Office located at 120 West Chapin Street, Cadillac, Michigan 49601-2158, telephone: 231-876-4474.

The Discharge-Specific Level Currently Achievable for Total Mercury was developed in accordance with the Department's approved Multiple Discharger Variance (MDV). A copy of the MDV may be obtained via the Internet at (<http://www.michigan.gov/deqnpdes> - click on 'Applicable Rules and Regulations') or it can be obtained at the District Office.