

BASIS FOR DECISION MEMO

Processor: Mike Bitondo
Permit No. MI0020257

Designated Name: **Cadillac WWTP**

Date: July 8, 2015
PID #: 95475.2

Monitoring Point 001: Authorization to discharge 3.2 MGD of treated municipal wastewater from Monitoring Point 001A through Outfall 001. Outfall 001 discharges to Clam River.

<u>Parameter</u>	<u>Maximum Limits for Quantity or Loading</u>			<u>Units</u>	<u>Maximum Limits for Quality or Concentration</u>			<u>Units</u>	<u>Frequency of Analysis</u>	<u>Sample Type</u> Report Total Daily Flow	<u>Basis for Limits</u> PWJ
	<u>Monthly</u> (report)	<u>7-Day</u> ---	<u>Daily</u> (report)		<u>Monthly</u> ---	<u>7-Day</u> ---	<u>Daily</u> ---				
Flow	(report)	---	(report)	MGD	---	---	---	---	Daily		
Carbonaceous Biochemical Oxygen Demand (CBOD5)											
May 1 – Nov. 30	190	270	---	lbs/day	7	---	10	mg/l	5x/Week	24-Hr Composite	AB
Dec. 1 – Mar. 31	670	910	---	lbs/day	25	---	34	mg/l	5x/Week	24-Hr Composite	AB
Apr. 1 – Apr. 30	450	670	---	lbs/day	17	---	25	mg/l	5x/Week	24-Hr Composite	AB
Total Suspended Solids											
May 1 – Nov. 30	530	800	---	lbs/day	20	30	---	mg/l	5x/Week	24-Hr Composite	PWJ
Dec. 1 – Apr. 30	800	1200	---	lbs/day	30	45	---	mg/l	5x/Week	24-Hr Composite	STS
Ammonia Nitrogen (as N)											
May 1 – Nov. 30	24	53	---	lbs/day	0.9	---	2.0	mg/l	5x/Week	24-Hr Composite	AB
Dec. 1 – Mar. 31	99	---	---	lbs/day	3.7	---	---	mg/l	5x/Week	24-Hr Composite	WQBEL
Apr. 1 – Apr. 30	130	---	---	lbs/day	4.8	---	---	mg/l	5x/Week	24-Hr Composite	WQBEL
Total Phosphorus (as P)											
May 1 – Mar. 31	13	---	---	lbs/day	0.5	---	---	mg/l	5x/Week	24-Hr Composite	WQBEL
Apr. 1 – Apr. 30	17	---	---	lbs/day	0.65	---	---	mg/l	5x/Week	24-Hr Composite	WQBEL
Fecal Coliform Bacteria	---	---	---	---	200	400	---	cts/100ml	5x/Week	Grab	WQS
Acute Toxicity	---	---	---	---	---	---	(report)	TU _A	Quarterly	24-Hr Composite	PWJ
Chronic Toxicity	---	---	---	---	1.1	---	---	TU _C	Quarterly	24-Hr Composite	WQBEL
Available Cyanide	0.16	---	---	lbs/day	5.9	---	(report)	μg/l	Monthly	Grab	WQBEL
Total Copper	---	---	---	---	---	---	(report)	μg/l	Quarterly	24-Hr Composite	WQC
Total Mercury	(report)	---	---	lbs/day	(report)	---	---	ng/l	Quarterly	Grab	PWJ

	12-Month Rolling Average				12-Month Rolling Average						
Total Mercury	0.000053	---	---	lbs/day	2.0	---	---	ng/l	Quarterly	Calculation	WQV
					Minimum Monthly						
Total Suspended Solids Minimum % Removal Dec 1 – April 30	---	---	---	---	85	---	---	%	Monthly	Calculation	STS
					Minimum Daily		Maximum Daily				
pH	---	---	---	---	6.5	---	9.0	S.U.	Daily	Grab	WQS
Dissolved Oxygen											
May 1 – Nov. 30	---	---	---	---	6.0	---	---	mg/l	5X/Week	Grab	WQBEL
Dec. 1 – Mar. 31	---	---	---	---	5.0	---	---	mg/l	5X/Week	Grab	AB
Apr. 1 – Apr. 30	---	---	---	---	5.0	---	---	mg/l	5X/Week	Grab	WQBEL

PERMIT CONDITIONS:

Final Effluent Limitations, Monitoring Point 001A

Additional Monitoring Requirements

Pollutant Minimization Program for Total Mercury

Untreated or Partially Treated Sewage Discharge Reporting and Testing Requirements

Operation, Maintenance & Replacement/Asset Management (revised to settle the contested case filed by the applicant.)

Facility Contact

Monthly Operating Reports

Michigan Industrial Pretreatment Program

Residuals Management Program for Land Application of Biosolids

Limit and Permit Conditions Change Key

Normal Type = existing requirement – carried over from previous version

Bold Type = new requirement – not in previous version

Italic = deleted requirement – not carried over from previous version

Basis for Limits Key

WQBEL - Water Quality Based Effluent Limit, STS – Secondary Treatment Standards, WQS - Water Quality Standards, WQV – Water Quality Variance

PWJ - Permit Writer's Judgment, AB - Antibacksliding