

MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY

INTEROFFICE COMMUNICATION

December 13, 2015

Briefing Memorandum to the NPDES Permit Decision-maker:

Re: Cadillac WWTP -- NPDES Permit No. MI0020257
Permit ID.v: 21871.2

Briefing Statement and History:

The application from City of Cadillac for the Cadillac WWTP located at 1121 Plett Road, Cadillac, Michigan 49601 has been processed in accordance with Act 451, Public Acts of 1994, as amended, Parts 31 and 41, and the Part 4 and Part 21 Rules (Rules 323.1041 through 323.1117 and 323.2101 through 323.2192 of the Michigan Administrative Code). Staff has determined that the attached permit is consistent with all applicable state and federal requirements and proposes it for reissuance. Also attached are other informational documents associated with this permit.

The permit was reissued on September 26, 2003, and contested by the City of Cadillac on November 24, 2004. Specifically the City contested the Mercury limit, the Lindane limit, and the chronic toxicity limit. Additional monitoring data on each of the three parameters and new operational information was submitted by the City and evaluated by WD staff. The facility had installed proposed UV disinfection system and removed chlorination equipment at the time of the resolution meeting. Based on facility changes that decreased discharge toxicity, a previous data point indicating a toxicity problem (and requiring a limit according to new GLI procedures) was no longer considered representative of the discharge and was replaced by new data. The chronic toxicity limit was eliminated. Quarterly monitoring was required.

Review of additional Lindane data resulted in elimination of the limit, retaining quarterly monitoring. Review of mercury data resulted in no change. The mercury limit must be met one year after the date of this resolution. This revised permit is acceptable to the permittee.

There are no substantial and relevant unresolved issues regarding reissuance of this permit.

Conclusions and Recommendations:

Staff recommends reissuance of NPDES Permit No. MI0020257 to the City of Cadillac for the Cadillac WWTP located at 1121 Plett Road, Cadillac, Michigan 49601.

Prepared by:

Concurred:

Diane Carlson
Permit Processor

Daniel Dell, Chief
Lakes Michigan and Superior Permits Unit
Date: _____

Attachments: Order of Dismissal
Proposed Permit